



ESKOM HOLDINGS LIMITED

PANEL B CONSULTANTS JOINT VENTURE

KUSILE POWER STATION

SDD SETTLING TANKS

DETAILED DESIGN REPORT 5452/80/021 REV 0

Task Order Number: PBC JV – TO #31

MAY 2010



ESKOM HOLDINGS LIMITED

KUSILE POWER STATION

SDD SETTLING TANKS

DETAILED DESIGN REPORT 5452/80/021 REV 0

TABLE OF CONTENTS

Section	Description	Page
1	INTRODUCTION	1
	1.1 Background	1
	1.2 Scope	1
	1.3 Client User Requirement Specification	2
	1.4 Drawings	2
2	SDD SETTLING TANKS DESIGN	4
	2.1 Overview	4
	2.2 Design Parameters	4
	2.2.1 Location and Size	4
	2.2.2 Capacity	4
	2.2.3 Operation	5
	2.3 Particle Size Settlement Calculations	5
	2.4 Concrete Works	6
	2.5 Geotechnical Conditions	7
	2.6 Inlet Details	7
	2.7 Oil/Water Separation	8
	2.8 Outlet Details	8
	2.9 Emergency Spillway	8
	2.10 Inlet and Outlet Pipes and Junction Boxes	8
	2.11 Perimeter Access Road	8
	2.12 Construction	9
3	REFERENCES	10

APPENDICES:

Appendix A – Drawings

Appendix B – Calculation Records

ESKOM HOLDINGS LIMITED

KUSILE POWER STATION

SDD SETTLING TANKS

DETAILED DESIGN REPORT 5452/80/021 REV 0

MAY 2010

1 INTRODUCTION

The Panel B Consultants Joint Venture (CJV) has been appointed by Eskom Enterprises to carry out the civil design of the water license structures for the Kusile Power Station.

This report details the design of the Station Dirty Dams Settling Tanks (SDD ST).

1.1 Background

Eskom is the principal supplier of electricity in South Africa. In order to meet the growing need for electricity, and in support of the growth and development strategy of the national government, Eskom has embarked on an expansion program to build new power stations. Part of this expansion program includes the construction of two large coal-fired power stations.

Located near Witbank and Kendal Power Station in the Mpumalanga province, Kusile Power Station will be a 4,800 MW coal-fired power plant. Kusile Power Station is currently under construction with a target commissioning date of June 2014 for the first of its six units.

1.2 Scope

Panel B CJV is responsible for the engineering design and construction drawings for the Pollution Control Dams (PCDs) at Kusile Power Station. This is the detailed design report for the SDD ST. It addresses all client requirements, as well as all relevant South African regulatory requirements. These include:

- The National Water Act, No. 36 of 1998.
- Section 117(c)(i) of the National Water Act, 1998, relating to dams with a safety risk.
- Government Notice No. 704, Regulations on use of water for mining and related activities aimed at the protection of water resources, in terms of the National Water Act (Act 36 of 1998)
- SANS 1200: Standardised Specifications for Civil Engineering Construction

1.3 Client User Requirement Specification

The design criteria for the CSY ST satisfy the requirements of the Eskom User Requirement Specification (URS) as detailed in *Section 5.2.2: Water Management*.

1.4 Drawings

All SDD ST detailed design drawings are listed below. Those that are relevant to the water use license application are marked with an asterisk and are provided in Appendix A.

- *K5452-80-033: Settling Tanks: Typical Details Sheet 1 of 2;
- *K5452-80-034: Settling Tanks: Typical Details Sheet 2 of 2;
- *K5452-80-035: SDD Settling Tanks: General Arrangement;
- *K5452-80-036: SDD Settling Tanks: Typical Sections and Details;
- *K5452-80-037: SDD Settling Tanks: Surface Bed Layout and Details;
- *K5452-80-038: SDD Settling Tanks: Energy Dissipator – GA and Details;
- *K5452-80-039: SDD Settling Tanks: Outlet – GA and Details;
- K5452-80-061: Settling Tanks Floor Reinforcement Details Sheet 1;
- K5452-80-062: Settling Tanks Floor Reinforcement Details Sheet 2;
- K5452-80-063: Settling Tanks Wall Reinforcement Details;
- K5452-80-064: Settling Tanks Inlet Reinforcement Details;
- K5452-80-065: Settling Tanks Outlet Reinforcement Details;
- K5452-80-066: SDD Settling Tanks: Dissipator Reinforcement Details;
- K5452-80-068: Settling Tanks Typical Reinforcement Details;
- *K5452-80-071: SDD Settling Tanks Inlet and Outlet Pipeworks: General Arrangement;
- *K5452-80-072: SDD Settling Tanks Inlet and Outlet Pipeworks: Sections and Details;
- *K5452-80-100: SDD Settling Tanks Inlet and Outlet Pipeworks: Sections;
- K5452-80-103: SDD Settling Tanks Junction Box Details: GA, Sections and Reinforcement JBK9A;
- K5452-80-104: SDD Settling Tanks Junction Box Details: Reinforcement Sections, Elevations, and Schedules JBK9A;
- K5452-80-105: SDD Settling Tanks Junction Box Details: GA, Sections and Reinforcement JBK9B;
- K5452-80-106: SDD Settling Tanks Junction Box Details: Reinforcement Sections, Elevations, and Schedules JBK9B;
- K5452-80-107: SDD Settling Tanks Junction Box Details: GA, Sections and Reinforcement JBK10;
- K5452-80-108: SDD Settling Tanks Junction Box Details: Reinforcement Sections, Elevations, and Schedules JBK10;
- K5452-80-109: SDD Settling Tanks Junction Box Details: GA, Sections and Reinforcement JBK11;
- K5452-80-111: SDD Settling Tanks Junction Box Details: Reinforcement Sections, Elevations, and Schedules JBK11;
- K5452-80-112: SDD Settling Tanks Junction Box Details: GA, Sections and Slab Reinforcement JBK12;

PANEL B CONSULTANTS JOINT VENTURE

- K5452-80-113: SDD Settling Tanks Junction Box Details: Sections and Walls Reinforcement JBK12;
- K5452-80-114: SDD Settling Tanks Junction Box Details: GA, Sections and Slab Reinforcement JBK13;
- K5452-80-115: SDD Settling Tanks Junction Box Details: Sections and Walls Reinforcement JBK13;
- K5452-80-116: SDD Settling Tanks Junction Box Details: GA, Sections and Reinforcement JBK14;
- K5452-80-117: SDD Settling Tanks Junction Box Details: Reinforcement Sections, Elevations, and Schedules JBK14;
- K5452-80-118: SDD Settling Tanks Junction Box Details: Reinforcement Bending Schedules JBK12;
- K5452-80-119: SDD Settling Tanks Junction Box Details: Reinforcement Bending Schedules JBK13;

2 SDD SETTLING TANKS DESIGN

2.1 Overview

The Station Dirty Dams Settling Tanks (SDD ST) are located to the north-west of the main power block, and south-east of the Station Dirty Dams (SDD).

All potentially contaminated water on the Kusile Power Station is managed in a closed system.

The SDD ST consists of two equal capacity concrete basins that clarify contaminated water from the power station terrace before it travels by gravity pipeline to the Station Dirty Dams (SDD). The SDD ST will receive dirty water inflows from the main power station terrace, via the *Black and Veatch* pipeline that terminates at JB 509. At JB 509, *Knight Piesold* continues the pipeline design to the SDD ST and ultimately to the SDD.

The SDD ST general arrangement and typical sections are provided on Drawings K5452-80-035 and K5452-80-036.

2.2 Design Parameters

The SDD ST was designed to meet the following location and capacity requirements:

2.2.1 Location and Size

The SDD ST will receive gravity discharges of dirty water from the power station terrace. The overall site layout dictated an optimal location north-west of the power station terrace, and south-east of the SDD. This position is down-gradient of the power station terrace and in close proximity to the SDD.

The SDD ST terrace is at elevation 1462.5 masl. The two compartments of the settling tank are partially excavated into the natural ground and partially built in a fill terrace. The terrace elevation was carefully planned in conjunction with the inlet and outlet pipe hydraulic requirements. Refer to *Appendix B: Calculation Records* for inlet and outlet pipeworks calculations.

The layout of the SDD ST is shown on K5406-80-035. The structure was designed with the exact same geometrical parameters as the Coal Stockyard Settling Tanks (CSY ST) for consistency and reduced costs in terms of design and construction efforts. Refer to *5452/80/009 Rev1: Coal Stockyard Settling Tanks – Detailed Design Report* for reference.

2.2.2 Capacity

Government Notice Regulation 704 specifies that a dirty water system may not spill into a clean water system more than once in 50 years, and that 800 mm freeboard be supplied above the maximum operating level.

The plant terrace hydrology calculations were performed by *Black and Veatch* and yielded a 1:50 year, peak instantaneous storm inflow of 10.8 m³/s. The SDD ST

hydraulic design, including gate sizing, freeboard checks, and flow velocities was performed based on the *Black and Veatch* hydrology. The calculations are presented in *Appendix B: Calculation Records*.

The SDD ST is designed to pass all of the dirty water runoff from its inflow sources for the 1:50 year, peak instantaneous storm event. The SDD ST is designed with an emergency spillway to accommodate larger events, as indicated in schematic on *Figure 2-2*.




Figure 2-2: SDD ST Operating Levels

The SDD ST is designed with two equal capacity compartments which can each pass $6.55 \text{ m}^3/\text{s}$. The water enters each compartment of the SDD ST via four sluice gates, 1.75 m square (K5452-80-036). Having two compartments allows for occasional maintenance and inspection access (preferably during the dry season) without interrupting the functionality of the structure under normal circumstances.

2.2.3 Operation

Normally the gates to both compartments of the SDD ST will be open, and each compartment will receive half of the total inflow. Except during maintenance, the SDD ST settling chambers will be full at all times due to the presence of the overflow wall at the outlet end of the tanks. A compartment can be emptied by first closing the gates at the entrance, and then installing a submersible pump that discharges to the outlet chamber.

The settling efficiency is at its highest with very low inflows, because the detention time of the impounded water is large. As flow increases towards the design inflow event, the detention time decreases and the particle size that can be settled increases. *Section 2.3* describes the particle size settling calculations.

2.3 Particle Size Settlement Calculations

The particle size settling calculations are based on standard industry theory for viscous fluids. The tank parameters used for calculating particle settling are presented in *Table 2-1*. Note that although the main settling chamber is 125 m long, the effective settling length has been reduced by 10 percent to account for turbulence at the inlet and outlet ends of the tank. This is considered to be a conservative

design approach. The effective width accounts for the average equivalent rectangular shape of the trapezoidal tank.

Figure 2-1 indicates the particle size settling characteristics for various inflow rates to one compartment of the SDD ST, as per the tank geometry presented in Table 2-1. These calculations are based on an assumed water temperature of 15°C, a particle specific gravity of 1.5 and a particle shape factor of 0.9. Appendix B: Calculation Records contains all the relevant particle settling calculations.

Table 2-1 : Settling Compartment Parameters

Settling Compartment Parameters	
Effective Width (m)	16.0
Length (m)	125.0
Effective Length (m)	112.5
Depth (m)	2.0
Length/Width Ratio	7.8
Storage Volume (m ³)	3987.5
Cross Sectional Area (m ²)	31.9




Figure 2-3: Particle Size Settled vs. Inflow Rate

2.4 Concrete Works

The SDD ST are required to be fully concrete structures due to the maintenance equipment that will be used to clean the floors. The structures consist of 250 mm thick base and side wall slabs and maintenance access ramps, concrete cantilever end walls, overflow walls, and central dividing wall, and a concrete energy dissipator at the inlet end. The structural reinforcement design is included in Appendix B: Calculation Records.

The concrete reinforcing drawings for the SDD ST are K5452-80-

2.5 Geotechnical Conditions

The SDD ST will be excavated into a terrace built primarily above the natural ground level. However, in some areas, the floor of the tank will be below natural ground level.

The geotechnical information supplied by Partridge Maud and Associates, report reference number 1-6/07 entitled *Project Bravo - Report on Geotechnical Investigations Undertaken at the Power Station Site* indicates the overall geotechnical conditions of the plant site.

It is anticipated that poor geotechnical conditions could be encountered in the area of the SDD ST. This could include organic material underlain by saturated decomposed diabase.

Foundation preparations will depend on the geotechnical conditions encountered, and will likely include the complete removal of organics and decomposed diabase in the vicinity of the SDD ST, down to refusal on competent bedrock, or a minimum bearing capacity of 300 kPa. Selected backfill will then be placed in 200 mm lifts and compacted to 96% Mod. AASHTO.

The possibility of a high water table necessitates the installation of groundwater finger drains beneath the concrete to prevent possible uplift forces. The configuration of the groundwater finger drains is shown on K5452-80-035.

The drains will be formed by excavating a 500 mm deep, trapezoidal trench. A 160 mm diameter HDPE flexible slotted drainage pipe (Drainex or similar approved) will be installed, the trench filled with 19 mm washed stone and the pipe and stone wrapped in a non-woven needled punched geofabric (Bidim A4 or similar approved) with a minimum overlap of 300 mm. (Refer to K5452-80-023 for details). The drains will conform to the bottom slope of the SDD ST. Where the drains exit from beneath the footprint of the structure, the perforated pipe will change to an un-perforated 160 mm OD PVC-U class 12 outlet pipe. The outlet pipe will daylight to a groundwater finger drain outlet structure at a 1 percent grade. Refer to Drawing K5452-80-033 for the finger drain outlet structure details.

2.6 Inlet Details

Inflow to the SDD ST will be through one 1,950 mm ND Class 100D concrete pipe (Rocla or similar), as indicated on Drawing K5452-80-071. The inflow will impact an energy dissipator that prevents damage to the SDD ST. The energy dissipator has been sized to handle the 1:50 year, design instantaneous inflow of 10.8 m³/s. The energy dissipator is detailed on Drawing K5452-80-038.

2.7 Oil/Water Separation

At the end of the settling chambers of the SDD ST, water spills over a wall and into the oil/water separation chamber. A Drizit TPCS300 oil/water separator with floating weir skimmer and process pump (or equally approved equipment) will extract oils and other floating contaminants before the water exits the chamber through a submerged 4m x 1m opening.

2.8 Outlet Details

At the north end of the SDD ST, the water spills over a wall and into the outlet chamber. The outlet chamber has a 1950 ND Class 100D Rocla (or similar) outlet pipe that is the start of the long pipeline to the SDD. Drawing K5452-80-039 details the outlet configuration.

2.9 Emergency Spillway

A 5 m wide, 500 mm deep trapezoidal spillway is provided at the west side of the SDD ST to protect the SDD ST terrace in flood events that exceed the 1:50 year, instantaneous discharge event. The spillway is detailed on Drawing K5452-80-037.

2.10 Inlet and Outlet Pipes and Junction Boxes

Drawings K5452-50-071, K5452-80-072, and K5452-80-100 show the arrangement and details for the inlet and outlet pipes of the SDD ST and the SDD. Dirty water inlet pipes have been designed with a minimum of 2% gradient when possible to ensure they are self cleaning of sludge or grit that may be in the water. In some instances, pipe battery limits and required invert levels along the pipeline required a shallower gradient. Calculations for pipe capacities are included in *Appendix B: Calculation Records*.

Drawings K5452-80-103 through K5452-80-119 (except drawing K5452-80-110) detail the junction boxes along the inlet and outlet pipelines of the SDD and SDD ST. The structural reinforcement design calculations are included in Appendix B: Calculation Records.

2.11 Perimeter Access Road

The SDD ST perimeter access roads will be 5 m wide. The road layer works will comprise a base, sub-base and wearing course layers. The layer specifications are summarised in Table 2-1.

Table 2-2: Access Road Layer Specifications

Layer name	Thickness (mm)	Type
Base	150	G3
Upper Sub-Base	150	G4
Lower Sub-Base	150	G7
Upper Selected	150	G9
Lower Selected/Sub-Grade	150	G10

2.12 Construction

All construction activities are to comply with the terms of SANS 1200, Standard Specifications for Civil Engineering Construction. Particular attention to the foundation preparation (removal of organics and weathered diabase, compaction of selected granular backfill) must be paid in order to ensure the stability of the structure.

3 REFERENCES

1. National Water Act, 1998.
2. Government Notice No.704, Regulations on use of water for mining and related activities aimed at the protection of water resources, in terms of the National Water Act (Act 36 of 1998)
3. Project Bravo – Report on Geotechnical Investigations undertaken at the Power Station site, No. 1-6/07, Partridge Maude and Associates, March 2008.
4. SANS 1200: Standardised Specifications for Civil Engineering Construction
5. 5452/80/009 Rev1: Coal Stockyard Settling Tanks – Detailed Design Report

PANEL B CONSULTANTS JOINT VENTURE




4 DOCUMENT CONTROL SHEET

CLIENT : ESKOM HOLDINGS LIMITED

PROJECT : KUSILE POWER STATION

PROJECT No : 5452/80

TITLE : STATION DIRTY DAMS – DESIGN REPORT

	Prepared by	Reviewed by	Approved by
ORIGINAL	NAME S REES	NAME JRG WILLIAMSON	NAME D GRANT-STUART
DATE 11 May 2010	SIGNATURE 	SIGNATURE 	SIGNATURE 
	NAME	NAME	NAME
DATE	SIGNATURE	SIGNATURE	SIGNATURE
	NAME	NAME	NAME
DATE	SIGNATURE	SIGNATURE	SIGNATURE

This report, and information or advice, which it contains, is provided by PANEL B CJV solely for internal use and reliance by its Client in performance of PANEL B CJV duties and liabilities under its contract with the Client. Any advice, opinions, or recommendations within this report should be read and relied upon only in the context of the report as a whole. The advice and opinions in this report are based upon the information made available to PANEL B CJV at the date of this report and on current SA standards, codes, technology and construction practices as at the date of this report. Following final delivery of this report to the Client, PANEL B CJV will have no further obligations or duty to advise the Client on any matters, including development affecting the information or advice provided in this report. This report has been prepared by PANEL B CJV in their professional capacity as Consulting Engineers. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion. This report is prepared in accordance with the terms and conditions of the PANEL B CJV contract with the Client. Regard should be had to those terms and conditions when considering and/or placing any reliance on this report. Should the Client wish to release this report to a Third Party for that party's reliance, PANEL B CJV may, at its discretion, agree to such release provided that:

- (a) PANEL B CJV written agreement is obtained prior to such release, and
- (b) By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against PANEL B CJV and PANEL B CJV, accordingly, assume no duties, liabilities or obligations to that Third Party, and
- (c) PANEL B CJV accepts no responsibility for any loss or damage incurred by the Client or for any conflict of PANEL B CJV interests arising out of the Client's release of this report to the Third Party.

APPENDIX A

DRAWINGS

K5452-80-033: Settling Tanks: Typical Details Sheet 1 of 2;

K5452-80-034: Settling Tanks: Typical Details Sheet 2 of 2;

K5452-80-035: SDD Settling Tanks: General Arrangement;

K5452-80-036: SDD Settling Tanks: Typical Sections and Details;

K5452-80-037: SDD Settling Tanks: Surface Bed Layout and Details;




K5452-80-038: SDD Settling Tanks: Energy Dissipator – GA and Details;

K5452-80-039: SDD Settling Tanks: Outlet – GA and Details;


K5452-80-071: SDD Settling Tanks Inlet and Outlet Pipeworks: General Arrangement;

K5452-80-072: SDD Settling Tanks Inlet and Outlet Pipeworks: Sections and Details;


K5452-80-100: SDD Settling Tanks Inlet and Outlet Pipeworks: Sections;




LAYERWORKS DETAIL
TYPICAL AGGREGATE SURFACED ROAD (5m)
SCALE 1:10




TYPICAL FINGER DRAIN DETAIL - UNDER SLAB
(FOR GROUNDWATER INTERCEPTION)
SCALE 1:25




TYPICAL DRAIN DETAIL - UNDER LINER
(FOR GROUNDWATER INTERCEPTION)




DETAIL 2
SCALE 1:10
TYPICAL CONSTRUCTION JOINT IN FLOOR SLABS (C.J.)





DETAIL 1
SCALE 1:10
TYPICAL CONTRACTION (SAW-CUT) JOINT IN FLOOR SLABS (S.C.J.)



DETAIL 3
SCALE 1:10
TYPICAL CONSTRUCTION JOINT IN FLOOR SLABS ON INCLINED SLOPE (C.J.)




DETAIL 4
SCALE 1:10
TYPICAL CONSTRUCTION JOINT IN FLOOR SLABS ON INCLINED SLOPE (C.J.)



TYPICAL PLAN ON GROUNDWATER DRAIN OUTLET


- NOTES:**
1. ALL BRICKWORK TO BE ENGINEERING UNITS TO SANS 227.
 2. ALLOW EXPOSED CONCRETE TO BE STEEL TROWEL FINISH.

NO.	REV.	DATE	DESCRIPTION
1	1		ISSUED FOR CONSTRUCTION
2	1		ISSUED FOR CONSTRUCTION
3	1		ISSUED FOR CONSTRUCTION
4	1		ISSUED FOR CONSTRUCTION
5	1		ISSUED FOR CONSTRUCTION
6	1		ISSUED FOR CONSTRUCTION
7	1		ISSUED FOR CONSTRUCTION
8	1		ISSUED FOR CONSTRUCTION
9	1		ISSUED FOR CONSTRUCTION
10	1		ISSUED FOR CONSTRUCTION
11	1		ISSUED FOR CONSTRUCTION
12	1		ISSUED FOR CONSTRUCTION
13	1		ISSUED FOR CONSTRUCTION
14	1		ISSUED FOR CONSTRUCTION
15	1		ISSUED FOR CONSTRUCTION
16	1		ISSUED FOR CONSTRUCTION
17	1		ISSUED FOR CONSTRUCTION
18	1		ISSUED FOR CONSTRUCTION
19	1		ISSUED FOR CONSTRUCTION
20	1		ISSUED FOR CONSTRUCTION
21	1		ISSUED FOR CONSTRUCTION
22	1		ISSUED FOR CONSTRUCTION
23	1		ISSUED FOR CONSTRUCTION
24	1		ISSUED FOR CONSTRUCTION
25	1		ISSUED FOR CONSTRUCTION
26	1		ISSUED FOR CONSTRUCTION
27	1		ISSUED FOR CONSTRUCTION
28	1		ISSUED FOR CONSTRUCTION
29	1		ISSUED FOR CONSTRUCTION
30	1		ISSUED FOR CONSTRUCTION
31	1		ISSUED FOR CONSTRUCTION
32	1		ISSUED FOR CONSTRUCTION
33	1		ISSUED FOR CONSTRUCTION
34	1		ISSUED FOR CONSTRUCTION
35	1		ISSUED FOR CONSTRUCTION
36	1		ISSUED FOR CONSTRUCTION
37	1		ISSUED FOR CONSTRUCTION
38	1		ISSUED FOR CONSTRUCTION
39	1		ISSUED FOR CONSTRUCTION
40	1		ISSUED FOR CONSTRUCTION
41	1		ISSUED FOR CONSTRUCTION
42	1		ISSUED FOR CONSTRUCTION
43	1		ISSUED FOR CONSTRUCTION
44	1		ISSUED FOR CONSTRUCTION
45	1		ISSUED FOR CONSTRUCTION
46	1		ISSUED FOR CONSTRUCTION
47	1		ISSUED FOR CONSTRUCTION
48	1		ISSUED FOR CONSTRUCTION
49	1		ISSUED FOR CONSTRUCTION
50	1		ISSUED FOR CONSTRUCTION
51	1		ISSUED FOR CONSTRUCTION
52	1		ISSUED FOR CONSTRUCTION
53	1		ISSUED FOR CONSTRUCTION
54	1		ISSUED FOR CONSTRUCTION
55	1		ISSUED FOR CONSTRUCTION
56	1		ISSUED FOR CONSTRUCTION
57	1		ISSUED FOR CONSTRUCTION
58	1		ISSUED FOR CONSTRUCTION
59	1		ISSUED FOR CONSTRUCTION
60	1		ISSUED FOR CONSTRUCTION
61	1		ISSUED FOR CONSTRUCTION
62	1		ISSUED FOR CONSTRUCTION
63	1		ISSUED FOR CONSTRUCTION
64	1		ISSUED FOR CONSTRUCTION
65	1		ISSUED FOR CONSTRUCTION
66	1		ISSUED FOR CONSTRUCTION
67	1		ISSUED FOR CONSTRUCTION
68	1		ISSUED FOR CONSTRUCTION
69	1		ISSUED FOR CONSTRUCTION
70	1		ISSUED FOR CONSTRUCTION
71	1		ISSUED FOR CONSTRUCTION
72	1		ISSUED FOR CONSTRUCTION
73	1		ISSUED FOR CONSTRUCTION
74	1		ISSUED FOR CONSTRUCTION
75	1		ISSUED FOR CONSTRUCTION
76	1		ISSUED FOR CONSTRUCTION
77	1		ISSUED FOR CONSTRUCTION
78	1		ISSUED FOR CONSTRUCTION
79	1		ISSUED FOR CONSTRUCTION
80	1		ISSUED FOR CONSTRUCTION
81	1		ISSUED FOR CONSTRUCTION
82	1		ISSUED FOR CONSTRUCTION
83	1		ISSUED FOR CONSTRUCTION
84	1		ISSUED FOR CONSTRUCTION
85	1		ISSUED FOR CONSTRUCTION
86	1		ISSUED FOR CONSTRUCTION
87	1		ISSUED FOR CONSTRUCTION
88	1		ISSUED FOR CONSTRUCTION
89	1		ISSUED FOR CONSTRUCTION
90	1		ISSUED FOR CONSTRUCTION
91	1		ISSUED FOR CONSTRUCTION
92	1		ISSUED FOR CONSTRUCTION
93	1		ISSUED FOR CONSTRUCTION
94	1		ISSUED FOR CONSTRUCTION
95	1		ISSUED FOR CONSTRUCTION
96	1		ISSUED FOR CONSTRUCTION
97	1		ISSUED FOR CONSTRUCTION
98	1		ISSUED FOR CONSTRUCTION
99	1		ISSUED FOR CONSTRUCTION
100	1		ISSUED FOR CONSTRUCTION




PLAN OF SPILLWAY STATION DIRTY DAM SETTLING TANKS
1 No. OFF + 1 No. SIMILAR

SCALE 1:200




SECTION E
 SCALE 1:200



PLAN OF OIL EXTRACTOR AT STATION DIRTY DAM SETTLING TANK


2 No. OFF

SCALE 1:100



SECTION A
 SCALE 1:100


SECTION B
 SCALE 1:100



PLAN OF OIL EXTRACTOR AT COAL STOCKYARD SETTLING TANK


2 No. OFF

SCALE 1:100




SECTION C
 SCALE 1:100

SECTION D
 SCALE 1:100



SECTION F
 SCALE 1:100



SECTION G
 SCALE 1:100

REVISIONS		DATE		BY		CHECKED		SCALE		SHEET		PROJECT	
NO.	DESCRIPTION												
1	ISSUED FOR CONSTRUCTION	21	08	AM									
2	ISSUED FOR CONSTRUCTION	21	08	AM									
3	ISSUED FOR CONSTRUCTION	21	08	AM									

SCALE	1:100
SHEET	1
PROJECT	SETTLING TANKS
PROJECT	TYPICAL DETAILS SHEET 2/2
PROJECT	DRG. No. K 5452-80-034
PROJECT	0.90/2405

SCALE	1:100
SHEET	1
PROJECT	SETTLING TANKS
PROJECT	TYPICAL DETAILS SHEET 2/2
PROJECT	DRG. No. K 5452-80-034
PROJECT	0.90/2405


COORDINATE LIST PLANT GRID		
POINT	N-COORD	E-COORD
ST10	10711.861	8656.414
ST11	10711.861	8754.714
ST12	10853.361	8754.714
ST13	10841.861	8743.214
ST14	10853.361	8743.214
ST15	10853.361	8649.714
ST16	10853.361	8669.914
ST17	10845.361	8656.414
ST18	10698.461	8679.914
ST19	10698.461	8733.214
ST20	10701.461	8706.564
ST21	10689.061	8719.514
ST22	10666.061	8719.514
ST23	10689.061	8683.614
ST24	10684.061	8683.614
ST25	10689.061	8744.714
ST26	10686.061	8744.714
ST27	10689.061	8671.414
ST28	10689.061	8679.914
ST29	10689.061	8679.914
ST30	10543.911	8733.214
ST31	10543.911	8706.564

NOTES:

1. All works to be carried out in accordance with SABS 1200 D – as amended 1998 purposes only.
2. Contour values are given for descriptive purposes only.
3. All setting out shall be from tabulated points and levels or from dimensions given.
4. All levels indicated are to finished surface.
5. Co-ordinate system is PLANT.


CONCRETE NOTES:

1. CONCRETE TO BE GRADE 35/19. MIX DESIGNS FOR CONCRETE TO BE SUBMITTED TO THE ENGINEER FOR APPROVAL PRIOR TO COMMENCEMENT OF CONCRETE WORK.
2. FINISHING:
 - 2.1 SMOOTH FINISH TO ALL SHUTTERED SIDES.
 - 2.2 WOODFLOAT TO TOPS OF WALLS AND SLABS.
 - 2.3 10mm CORNER FILLETS TO ALL EXPOSED EDGES.
3. TOLERANCES TO BE IN ACCORDANCE WITH SABS 1200G CLASS 1.
4. COVER TO REINFORCEMENT: AS INDICATED.
5. CURING OF ALL CONCRETE SURFACES TO BE DONE USING WET BURLAP OR WHITE PIGMENTED CURING COMPOUND.
6. ALL WORK TO BE CARRIED OUT IN CONFORMANCE WITH THE RELEVANT SABS 1200 SPECIFICATIONS.
7. ALL CONCRETE IS TO BE PROPERLY VIBRATED. HEAVING OF CONCRETE MUST BE CONTINUOUS.
8. ALL WORK TO BE CHECKED BY SUPERVISOR TO ENGINEER PRIOR TO POURING OF CONCRETE (MINIMUM 24 HOURS NOTICE).
9. AN ALLOWABLE FOUNDATION BEARING PRESSURE OF 300KPa ON COMPETENT SOIL IS REQUIRED. REMOVE AND REPLACE IN SITU MATERIAL AS REQUIRED.
10. ALL DIMENSIONS TO BE CONFIRMED ON SITE.
11. ALL STRUCTURES SHALL BE CONSTRUCTED ON A SUB-FUNDATION CARPET OF 15MPa/19mm BLINDING CONCRETE, NOT LESS THAN 75mm THICK.



GENERAL ARRANGEMENT OF STATION DIRTY DAMS SETTLING TANKS

SCALE 1:500



SECTION A


PART SECTION E

SCALE 1:250


SCALE 1:250

KUSILE POWER STATION		STATION DIRTY DAM SETTLING TANKS		GENERAL ARRANGEMENT	
NO.	DESCRIPTION	DATE	BY	CHKD.	APPD.
1	ISSUE FOR CONSTRUCTION	31	BM		
2	ISSUE FOR APPROVAL				
3	ISSUE FOR CONSTRUCTION				
4	ISSUE FOR CONSTRUCTION				
5	ISSUE FOR CONSTRUCTION				


SCALE	1:1000
DWG. NO.	K 5452-80-035
DATE	09/02/2006
PROJECT	ESKOM
REV.	1
REV.	2
REV.	3




SECTION B
SCALE 1:100




SECTION C
SCALE 1:100




SECTION B1
SCALE 1:50




SECTION B2
SCALE 1:50




SECTION C1
SCALE 1:50



SECTION C2
SCALE 1:50




SECTION D
SCALE 1:250




SECTION E
SCALE 1:250

REVISIONS		DATE		BY		CHK		APP		SCALE	
NO.	DESCRIPTION	DATE	BY	CHK	APP	SCALE	SCALE	SCALE	SCALE	SCALE	SCALE
1	ISSUED FOR CONSTRUCTION	21	AM								
2	ISSUED FOR REVIEW	14	AM								
3	ISSUED FOR REVIEW	14	AM								
4	ISSUED FOR REVIEW	14	AM								
5	ISSUED FOR REVIEW	14	AM								
6	ISSUED FOR REVIEW	14	AM								
7	ISSUED FOR REVIEW	14	AM								
8	ISSUED FOR REVIEW	14	AM								
9	ISSUED FOR REVIEW	14	AM								
10	ISSUED FOR REVIEW	14	AM								


KUSILE POWER STATION		STATION DIRTY DAMS		TYPICAL SECTIONS & DETAILS	
NO.	DESCRIPTION	DATE	BY	CHK	APP
1	ISSUED FOR CONSTRUCTION	21	AM		
2	ISSUED FOR REVIEW	14	AM		
3	ISSUED FOR REVIEW	14	AM		
4	ISSUED FOR REVIEW	14	AM		
5	ISSUED FOR REVIEW	14	AM		
6	ISSUED FOR REVIEW	14	AM		
7	ISSUED FOR REVIEW	14	AM		
8	ISSUED FOR REVIEW	14	AM		
9	ISSUED FOR REVIEW	14	AM		
10	ISSUED FOR REVIEW	14	AM		




DETAIL 1
SCALE 1:10
TYPICAL CONTRACTION (SAW-CUT) JOINT IN FLOOR SLABS (S.C.J.)




DETAIL 2
SCALE 1:10
TYPICAL CONSTRUCTION JOINT IN FLOOR SLABS (C.J.)



DETAIL 3
SCALE 1:10
TYPICAL CONSTRUCTION JOINT IN FLOOR SLABS ON INCLINED SLOPE (C.J.)



DETAIL 4
SCALE 1:10
TYPICAL CONSTRUCTION JOINT IN FLOOR SLABS ON INCLINED SLOPE (C.J.)




FENCE OMITTED FOR CLARITY
REFER TO DRG. 5452-80-033 FOR TYPICAL JOINT DETAILS
REFER TO DRG. 5452-80-035 FOR CONCRETE NOTES

NO.	DATE	DESCRIPTION	BY	CHKD	APP'D
1	15/08/12	ISSUED FOR TENDER			
2	20/08/12	REVISED FOR COMMENTS			
3	28/08/12	REVISED FOR COMMENTS			
4	02/09/12	REVISED FOR COMMENTS			
5	05/09/12	REVISED FOR COMMENTS			
6	11/09/12	REVISED FOR COMMENTS			
7	12/09/12	REVISED FOR COMMENTS			
8	14/09/12	REVISED FOR COMMENTS			
9	18/09/12	REVISED FOR COMMENTS			
10	20/09/12	REVISED FOR COMMENTS			
11	21/09/12	REVISED FOR COMMENTS			
12	21/09/12	REVISED FOR COMMENTS			
13	21/09/12	REVISED FOR COMMENTS			
14	21/09/12	REVISED FOR COMMENTS			
15	21/09/12	REVISED FOR COMMENTS			
16	21/09/12	REVISED FOR COMMENTS			
17	21/09/12	REVISED FOR COMMENTS			
18	21/09/12	REVISED FOR COMMENTS			
19	21/09/12	REVISED FOR COMMENTS			
20	21/09/12	REVISED FOR COMMENTS			
21	21/09/12	REVISED FOR COMMENTS			
22	21/09/12	REVISED FOR COMMENTS			
23	21/09/12	REVISED FOR COMMENTS			
24	21/09/12	REVISED FOR COMMENTS			
25	21/09/12	REVISED FOR COMMENTS			
26	21/09/12	REVISED FOR COMMENTS			
27	21/09/12	REVISED FOR COMMENTS			
28	21/09/12	REVISED FOR COMMENTS			
29	21/09/12	REVISED FOR COMMENTS			
30	21/09/12	REVISED FOR COMMENTS			
31	21/09/12	REVISED FOR COMMENTS			
32	21/09/12	REVISED FOR COMMENTS			
33	21/09/12	REVISED FOR COMMENTS			
34	21/09/12	REVISED FOR COMMENTS			
35	21/09/12	REVISED FOR COMMENTS			
36	21/09/12	REVISED FOR COMMENTS			
37	21/09/12	REVISED FOR COMMENTS			
38	21/09/12	REVISED FOR COMMENTS			
39	21/09/12	REVISED FOR COMMENTS			
40	21/09/12	REVISED FOR COMMENTS			
41	21/09/12	REVISED FOR COMMENTS			
42	21/09/12	REVISED FOR COMMENTS			
43	21/09/12	REVISED FOR COMMENTS			
44	21/09/12	REVISED FOR COMMENTS			
45	21/09/12	REVISED FOR COMMENTS			
46	21/09/12	REVISED FOR COMMENTS			
47	21/09/12	REVISED FOR COMMENTS			
48	21/09/12	REVISED FOR COMMENTS			
49	21/09/12	REVISED FOR COMMENTS			
50	21/09/12	REVISED FOR COMMENTS			
51	21/09/12	REVISED FOR COMMENTS			
52	21/09/12	REVISED FOR COMMENTS			
53	21/09/12	REVISED FOR COMMENTS			
54	21/09/12	REVISED FOR COMMENTS			
55	21/09/12	REVISED FOR COMMENTS			
56	21/09/12	REVISED FOR COMMENTS			
57	21/09/12	REVISED FOR COMMENTS			
58	21/09/12	REVISED FOR COMMENTS			
59	21/09/12	REVISED FOR COMMENTS			
60	21/09/12	REVISED FOR COMMENTS			
61	21/09/12	REVISED FOR COMMENTS			
62	21/09/12	REVISED FOR COMMENTS			
63	21/09/12	REVISED FOR COMMENTS			
64	21/09/12	REVISED FOR COMMENTS			
65	21/09/12	REVISED FOR COMMENTS			
66	21/09/12	REVISED FOR COMMENTS			
67	21/09/12	REVISED FOR COMMENTS			
68	21/09/12	REVISED FOR COMMENTS			
69	21/09/12	REVISED FOR COMMENTS			
70	21/09/12	REVISED FOR COMMENTS			
71	21/09/12	REVISED FOR COMMENTS			
72	21/09/12	REVISED FOR COMMENTS			
73	21/09/12	REVISED FOR COMMENTS			
74	21/09/12	REVISED FOR COMMENTS			
75	21/09/12	REVISED FOR COMMENTS			
76	21/09/12	REVISED FOR COMMENTS			
77	21/09/12	REVISED FOR COMMENTS			
78	21/09/12	REVISED FOR COMMENTS			
79	21/09/12	REVISED FOR COMMENTS			
80	21/09/12	REVISED FOR COMMENTS			
81	21/09/12	REVISED FOR COMMENTS			
82	21/09/12	REVISED FOR COMMENTS			
83	21/09/12	REVISED FOR COMMENTS			
84	21/09/12	REVISED FOR COMMENTS			
85	21/09/12	REVISED FOR COMMENTS			
86	21/09/12	REVISED FOR COMMENTS			
87	21/09/12	REVISED FOR COMMENTS			
88	21/09/12	REVISED FOR COMMENTS			
89	21/09/12	REVISED FOR COMMENTS			
90	21/09/12	REVISED FOR COMMENTS			
91	21/09/12	REVISED FOR COMMENTS			
92	21/09/12	REVISED FOR COMMENTS			
93	21/09/12	REVISED FOR COMMENTS			
94	21/09/12	REVISED FOR COMMENTS			
95	21/09/12	REVISED FOR COMMENTS			
96	21/09/12	REVISED FOR COMMENTS			
97	21/09/12	REVISED FOR COMMENTS			
98	21/09/12	REVISED FOR COMMENTS			
99	21/09/12	REVISED FOR COMMENTS			
100	21/09/12	REVISED FOR COMMENTS			


KUSILE POWER STATION
STATION DIRTY DAM
SETTLING TANKS
SURFACE BED LAYOUT & DETAILS
DRG. No. K 5452-80-037
SCALE: 1:500
DATE: 15/08/12
DRAWN BY: [Name]
CHECKED BY: [Name]
APPROVED BY: [Name]

HOT DIPPED GALVANISED
CAT LADDER
STRINGERS 65x10 FLATS
HOOPS AND VERTICALS 50x8
#20 RINGS (PLUG WELDED)
FRAMING BOLTS M16 STAINLESS STEEL

CARBON STEEL RALEY CA-TM90 OR SIMILAR
APPROVED.
2 No. 16# RAWL BOLTS PER STANCHION.
MENSIS INTERLINK HANDRAILING NT90




PLAN ON INLET ENERGY DISSIPATOR
SCALE 1:100



300mm STRIP VEGETATION
AND TOPSOIL AND STOCKPILE
AT DESIGNATED AREA THEN
RIP AND RECOMPACT


SECTION F
SCALE 1:100

SUB-SURFACE DRAIN OMITTED
ON THIS SECTION FOR CLARITY
SEE DRG K5452-80-035




SECTION J
SCALE 1:100

SUB-SURFACE DRAIN DETAIL
REFER TO DRG K5452-80-040




SECTION H
SCALE 1:100


SECTION J1
SCALE 1:50




SECTION J1
SCALE 1:50




SECTION I
SCALE 1:50



SECTION H1
SCALE 1:50



SECTION L
SCALE 1:100



SECTION K
SCALE 1:100


- CONCRETE NOTES:
- CONCRETE TO BE GRADE 35/19.
 - CONCRETE TO BE CAST AND FINISHED TO THE ENGINEER FOR APPROVAL PRIOR TO COMMENCEMENT OF CONCRETE WORK.
 - FINISHING:
 - SMOOTH FINISH TO ALL SHUTTERED SIDES.
 - WOOD-FLOAT TO TOPS OF WALLS AND SLABS.
 - 25x25mm CORNER FILLETS TO ALL EXPOSED EDGES.
 - TOLERANCES TO BE IN ACCORDANCE WITH SABS 1200G CLASS 1.
 - COVER TO REINFORCEMENT: AS INDICATED.
 - CURING OF ALL CONCRETE SURFACES TO BE DONE USING SAMSON'S WAX BASED WHITE PIGMENTED CURING COMPOUND.
 - ALL WORK TO BE CARRIED OUT IN CONFORMANCE WITH THE RELEVANT SABS 1200 SPECIFICATIONS.
 - ALL CONCRETE IS TO BE PROPERLY VIBRATED. HEAVING OF CONCRETE MUST BE PREVENTED.
 - CURING OF CONCRETE TO BE CONTINUED.
 - ALL WORK TO BE CHECKED BY SUPERVISING ENGINEER PRIOR TO POURING OF CONCRETE (MINIMUM 24 HOURS NOTICE).
 - AN ALLOWABLE FOUNDATION BEARING PRESSURE OF 300kPa ON COMPETENT SOIL IS REQUIRED. REMOVE AND REPLACE IN-SITU MATERIAL AS REQUIRED.
 - ALL DIMENSIONS TO BE CONFIRMED ON-SITE.
 - ALL STRUCTURES SHALL BE CONSTRUCTED ON A SUB-FOUNDATION CARPET OF 15MPa/19mm BLINDING CONCRETE, NOT LESS THAN 75mm THICK.

NO.	DATE	BY	CHKD.	APP'D.	DESCRIPTION
1					ISSUED FOR TENDER
2					ISSUED FOR CONSTRUCTION


NO.	DATE	BY	CHKD.	APP'D.	DESCRIPTION
1					ISSUED FOR TENDER
2					ISSUED FOR CONSTRUCTION

NO.	DATE	BY	CHKD.	APP'D.	DESCRIPTION
1					ISSUED FOR TENDER
2					ISSUED FOR CONSTRUCTION


NO.	DATE	BY	CHKD.	APP'D.	DESCRIPTION
1					ISSUED FOR TENDER
2					ISSUED FOR CONSTRUCTION




PLAN ON OUTLET STRUCTURE
SCALE 1:200




SECTION G
SCALE 1:100



SECTION M
SCALE 1:100



SECTION N
SCALE 1:100




SECTION N1
SCALE 1:50

SECTION P
SCALE 1:100

SECTION M1
SCALE 1:50

- CONCRETE NOTES:**
1. CONCRETE TO BE GRADE 35/19. MIX DESIGNS FOR CONCRETE TO BE SUBMITTED TO THE ENGINEER FOR APPROVAL PRIOR TO COMMENCEMENT OF CONCRETE WORK FINISHING:
 - 2.1. SMOOTH FINISH TO ALL SHUTTERED WALLS
 - 2.2. WOODFLOAT TO TOPS OF WALLS AND SLABS.
 - 2.3. 25x25mm CORNER FILLETS TO ALL EXPOSED EDGES.
 3. TOLERANCES TO BE IN ACCORDANCE WITH SABS 12006 CLASS 1.
 4. COVER TO REINFORCEMENT: AS INDICATED.
 5. CURING OF ALL CONCRETE SURFACES TO BE DONE USING SAMSON'S WAX BASED WHITE PIGMENTED CURING COMPOUND.
 6. ALL WORK TO BE CARRIED OUT IN CONFORMANCE WITH THE RELEVANT SABS 1200 SPECIFICATIONS.
 7. CONCRETE TO BE PROPERLY ABRASING TO BE PROPERLY TO BE AVOIDED. CASTING OF CONCRETE MUST BE CONTINUOUS.
 8. ALL WORK TO BE CHECKED BY SUPERVISING ENGINEER PRIOR TO POURING OF CONCRETE (MINIMUM 24 HOURS NOTICE).
 9. AN ALLOWABLE FOUNDATION BEARING PRESSURE OF 500Kpa ON COMPETENT GROUND TO BE USED TO RECALCULATE IN-SITU MATERIALS AS REQUIRED.
 10. ALL DIMENSIONS TO BE CONFIRMED ON SITE.
 11. ALL STRUCTURES SHALL BE CONSTRUCTED ON A SUB-FOUNDATION CAPABLE OF 15MPa/19mm BLINDING CONCRETE, NOT LESS THAN 75mm THICK.





SECTION P1
SCALE 1:50

CARBON STEEL RALEX CA-TM90 OR SIMILAR WITH 2 No. 166 RAWL BOLTS PER STANCHION. ALTERNATE: MENTIS INTERLINK HANDRAILING NT90

NO.	DATE	BY	CHK	APP	DESCRIPTION

NO.	DATE	BY	CHK	APP	DESCRIPTION


KUSILE POWER STATION					
STATION DIRTY DAMS					
SETTLING TANKS - OUTLET					
GENERAL ARRANGEMENT & DETAILS					
DRG. No. K 5452-80-039					
ESKOM 0.90/2410					
NO.	DATE	BY	CHK	APP	DESCRIPTION



PLAN
1 : 1000

KEY
 KP KNIGHT PIESOLD/ESKOM
 BATTERY LIMIT
 WETLANDS AREA

BATTERY LIMITS CO-ORDINATES		JUNCTION BOX CO-ORDINATES	
POINT NAME	N-COORDINATE	E-COORDINATE	E-COORDINATE
D1	10380.244	8779.861	8692.279
D2	10380.282	8773.965	8692.279
A	10701.461	8706.564	8609.391
B	10701.461	8706.564	8609.391
C	10701.461	8706.564	8609.391
D	10701.461	8706.564	8609.391
E	10701.461	8706.564	8609.391
F	10701.461	8706.564	8609.391
G	10701.461	8706.564	8609.391
H	10701.461	8706.564	8609.391
I	10701.461	8706.564	8609.391
J	10701.461	8706.564	8609.391
K	10701.461	8706.564	8609.391
L	10701.461	8706.564	8609.391
M	10701.461	8706.564	8609.391
N	10701.461	8706.564	8609.391
O	10701.461	8706.564	8609.391
P	10701.461	8706.564	8609.391
Q	10701.461	8706.564	8609.391
R	10701.461	8706.564	8609.391
S	10701.461	8706.564	8609.391
T	10701.461	8706.564	8609.391
U	10701.461	8706.564	8609.391
V	10701.461	8706.564	8609.391
W	10701.461	8706.564	8609.391
X	10701.461	8706.564	8609.391
Y	10701.461	8706.564	8609.391
Z	10701.461	8706.564	8609.391



TYPICAL SECTION — CONCRETE PIPE
NOT TO SCALE

SECTION E — TYPICAL SECTION
NOT TO SCALE — CONCRETE INTERLOCKING JOINT PIPE

BATTERY LIMITS CO-ORDINATES		JUNCTION BOX CO-ORDINATES	
POINT NAME	N-COORDINATE	E-COORDINATE	E-COORDINATE
D1	10380.244	8779.861	8692.279
D2	10380.282	8773.965	8692.279
A	10701.461	8706.564	8609.391
B	10701.461	8706.564	8609.391
C	10701.461	8706.564	8609.391
D	10701.461	8706.564	8609.391
E	10701.461	8706.564	8609.391
F	10701.461	8706.564	8609.391
G	10701.461	8706.564	8609.391
H	10701.461	8706.564	8609.391
I	10701.461	8706.564	8609.391
J	10701.461	8706.564	8609.391
K	10701.461	8706.564	8609.391
L	10701.461	8706.564	8609.391
M	10701.461	8706.564	8609.391
N	10701.461	8706.564	8609.391
O	10701.461	8706.564	8609.391
P	10701.461	8706.564	8609.391
Q	10701.461	8706.564	8609.391
R	10701.461	8706.564	8609.391
S	10701.461	8706.564	8609.391
T	10701.461	8706.564	8609.391
U	10701.461	8706.564	8609.391
V	10701.461	8706.564	8609.391
W	10701.461	8706.564	8609.391
X	10701.461	8706.564	8609.391
Y	10701.461	8706.564	8609.391
Z	10701.461	8706.564	8609.391


NOTE:
REFER TO K5452-80-070 FOR JUNCTION BOX DETAILS

KUSILE POWER STATION		SOD SETTLING TANKS		INLEADING PIPE ARRANGEMENT	
DRG. No. K 5452-80-071		0.90/2442		ESKOM	
DATE	BY	DATE	BY	DATE	BY
1	2	3	4	5	6
7	8	9	10	11	12
13	14	15	16	17	18
19	20	21	22	23	24
25	26	27	28	29	30
31	32	33	34	35	36
37	38	39	40	41	42
43	44	45	46	47	48
49	50	51	52	53	54
55	56	57	58	59	60
61	62	63	64	65	66
67	68	69	70	71	72
73	74	75	76	77	78
79	80	81	82	83	84
85	86	87	88	89	90
91	92	93	94	95	96
97	98	99	100	101	102
103	104	105	106	107	108
109	110	111	112	113	114
115	116	117	118	119	120
121	122	123	124	125	126
127	128	129	130	131	132
133	134	135	136	137	138
139	140	141	142	143	144
145	146	147	148	149	150
151	152	153	154	155	156
157	158	159	160	161	162
163	164	165	166	167	168
169	170	171	172	173	174
175	176	177	178	179	180
181	182	183	184	185	186
187	188	189	190	191	192
193	194	195	196	197	198
199	200	201	202	203	204
205	206	207	208	209	210
211	212	213	214	215	216
217	218	219	220	221	222
223	224	225	226	227	228
229	230	231	232	233	234
235	236	237	238	239	240
241	242	243	244	245	246
247	248	249	250	251	252
253	254	255	256	257	258
259	260	261	262	263	264
265	266	267	268	269	270
271	272	273	274	275	276
277	278	279	280	281	282
283	284	285	286	287	288
289	290	291	292	293	294
295	296	297	298	299	300

OUTLET FROM SDD SETTLING TANKS
 N = 10701.461
 E = 8706.564


1950 ND CLASS 1000 CONCRETE PIPE

INLET TO SDD COMPARTMENT 1
 N = 11032.619
 E = 8460.967






SECTION A LONGITUDINAL SECTION
 SCALE 1:500
 SDD SETTLING TANK OUTLET TO SDD1

INLET TO SDD COMPARTMENT 2
 N = 11032.619
 E = 8266.967



SECTION B LONGITUDINAL SECTION
 SCALE 1:500
 SDD SETTLING TANK OUTLET TO SDD2



SCHEMATIC SECTION - PIPE BEDDING
 CLASS C BED
 NOT TO SCALE

NOTES:
 THE CONTRACTOR SHALL COMPLY WITH ALL RELEVANT CLAUSES FOR PIPE BEDDING AS STIPULATED IN SABS 1200 LB-1983.
 WHEN TWO PIPES ARE IN THE SAME TRENCH, PROVIDE 800 CLEARANCE TO ALLOW FOR PROPER COMPACTION.

NO.	REVISION	DATE	BY	CHKD.	APP'D.	SCALE	SHEET	NO.
1	ISSUED FOR TENDER	15/08/2019	1	2
2	ISSUED FOR CONSTRUCTION	15/08/2019	2	2

PROJECT: SDD SETTLING TANKS INLET SECTIONS AND DETAILS
 DRAWING NO: K 5452-70-072
 SCALE: 0.90/2443

ESKOM

APPENDIX B
CALCULATION RECORDS

PANEL B CONSULTANTS JOINT VENTURE Calculation Record

Client Name: ESKOM **Page:** 1 **of** 10

Project Name: Kusile Power Station **Job No:** 303-00098/06

Calculation Title: Hydraulic Calculations : Station Dirty Dam Settling Tank

Calculation No./File No.: _____

Calculation is: Preliminary Final

Objective: Detailed hydraulic design of the Station Dirty Dam Settling Tank, including energy Dissipators, baffle walls, spillways and sluice gates.

Unverified assumptions requiring subsequent verification			
No.	Assumption	Verified by	Date
	None		

This section applies to computer generated calculations	
Program Name/Number: <u>N/A</u>	Version: _____
Program Name/Number: <u>N/A</u>	Version: _____
Evidence of or reference to computer program verification, if applicable:	
Bases or reference thereto supporting application of the computer program to the physical problem:	

Review and approval						
Rev	Prepared by	Date	Verified by	Date	Approved by	Date
0	Nicholas Pilz	Mar 10				

1. PURPOSE:

To calculate the size of various hydraulic structures involved in Station Dirty Dam settling tanks. The detailed calculations include energy dissipators, the overspill sections, submerged openings and the sizing of the isolating sluice gates.

2. REFERENCES:

1.	SETTLING TANKS TYPICAL DETAILS SHEET 1	5452-80-033	Rev	
2.	SETTLING TANKS TYPICAL DETAILS SHEET 2	5452-80-034	Rev	
3.	SDD SETTLING TANKS - GENERAL ARRANGEMENT	5452-80-035	Rev	
4.	SDD SETTLING TANKS - TYPICAL SECTIONS & DETAILS	5452-80-036	Rev	
5.	SDD SETTLING TANKS -SURFACE BED LAYOUT & DETAILS	5452-80-037	Rev	
6.	SDD SETTLING TANKS ENERGY DISSIPATOR GA & DETAILS	5452-80-038	Rev	
7.	SDD SETTLING TANKS OUTLET GA & DETAILS	5452-80-039	Rev	
8.	SETTLING TANKS - FLOOR REINFORCING DETAILS SHEET 1	5452-80-061	Rev	
9.	SETTLING TANKS - FLOOR REINFORCING DETAILS SHEET 2	5452-80-062	Rev	
10.	SETTLING TANKS - WALL REINFORCING DETAILS SHEET 1	5452-80-063	Rev	
11.	SETTLING TANKS - TYPICAL REINFORCING DETAILS SHEET 1	5452-80-068	Rev	
12.	SDD SETTLING TANKS INLET & OUTLET PIPEWORKS - GA	5452-70-071	Rev	
13.	SDD SETTLING TANKS INLET & OUTLET PIPEWORKS - SECTIONS & DETAILS	5452-70-072	Rev	
14.	SDD SETTLING TANKS INLET & OUTLET PIPEWORKS SECTIONS	5452-80-100	Rev	

3. ASSUMPTIONS

Density of water = 1000kg/m^3
Acceleration due to gravity = 9.81m/s^2

Additional assumptions are listed in the detailed hydraulic calculations, where applicable.

4. HYDRAULIC CALCULATIONS

APPENDICES

- Appendix A – Energy Dissipator Design Calculations
- Appendix B – Sluice Gate Design


4.1 Calculation title

STATION DIRTY DAM SETTLING TANK

- SETTLING TANK DESIGNED TO FUNCTION PROPERLY UP TO DESIGN FLOW = $6.55 \text{ m}^3/\text{s}$
- $3.275 \text{ m}^3/\text{s}$ per TANK

- ANY FLOW GREATER WILL PASS THROUGH TANK
- SETTLING FLOW CAPABLE OF PASSING 1:50 yr 24h STORM

* SETTLING TANK OUTLET:



AT (A)

$$Q = C \sqrt{BH^{3/2}}$$

$$3.275 = 1.704 + 12.930 \cdot H^{1/2}$$

$$\therefore H = 0.28 \text{ m} \approx 0.30 \text{ m}$$


AT (B)

$$1. \cdot \frac{Q^2}{2gA^2} = y_2 + \frac{Q^2}{2g(y_2 + t)^2}$$

$$\therefore 2.60 + \frac{3.275^2}{2 \cdot 18781} = 2.59 + \frac{3.275^2}{2g(0.64 + t)^2}$$

$$\therefore y_2 = 1.05 \times 100 \text{ m}$$

* SETTLING TANK INLET:



AT (B)

ASSUMING $y_a = 1.500m$

$$y_1 \cdot \frac{Q^2}{A_1^2 z_1} = y_2 \cdot \frac{Q^2}{(y_0 + 1.5)^2 z_2}$$

$$\therefore y_1 = \frac{0.243}{y_1^2} = 2.364$$

$$\therefore y_1 = 2.32m$$

∴ TOTAL OF 4 OPENINGS PER TANK, EACH FITTED WITH SLUICE GATE

∴ CRITICAL SCENARIO WHEN ALL GATES CLOSED AND 1:50 yr EVENT

$$1:50 \text{ yr FLOOD} = 10.78 \text{ m}^3/\text{s} \quad (\text{FROM PLANS})$$

∴ TOP OF TERRACE = 1:50 yr FLOOD EVENT + 300mm FREEBOARD

∴ OVERSPILL SECTION AT (A)

$$Q = C \cdot B \cdot H^{3/2}$$

$$\therefore H = 0.90m$$

∴ 1:50 yr FLOOD LEVEL = 1460.60 m + 300mm FREEBOARD

**PANEL B
CONSULTANTS
JOINT
VENTURE**

Client: ESKOM
Project: Kusile Power Station Component: SDDST
Job no.: 303-00098/06 File no.: _____
Title: Hydraulic Calculations : Station Dirty Dam Settling Tank

Computed by: Nicholas Pilz
Date: March 2010
Checked by: _____
Date: _____
Page: 5 of 10


APPENDIX A

Energy Dissipator Design Calculations

Inlet flow from Plant Terrace

Q = 10.78m³/s
 Area Culvert 1950Ø = 3.976m²
 v = 2.71m/s
 $y_e = (A/2)^{1/2} = 1.409m$
 $Fr = u / \sqrt{gL} = 0.729$
 $H_0 = y_e + v^2/2g = 1.783m$

From Figure 8-C-2,



$H_0/W = 0.4053$
 $W = 4.88m$

The energy dissipator has the following dimensions based on Figure 8-C-1 :

$h_1 = 3.70m$	$w_2 = 1.00m$
$L = 6.50m$	$t_3 = 0.30m$
$h_2 = 1.80m$	$t_2 = 0.30m$
$h_3 = 0.80m$	$t_1 = 0.25m$
$L_1 = 2.75m$	$t_4 = 0.30m$
$L_2 = 3.75m$	$t_5 = 0.15m$
$h_4 = 2.00m$	$w_1 = 0.40m$




Figure 8-C-1. Baffle - Wall Energy Dissipator - USBR Type VI

**PANEL B
CONSULTANTS
JOINT
VENTURE**

Client: ESKOM
Project: Kusile Power Station Component: CSY Hydraulics
Job no.: 303-00098/06 File no.: _____
Title: Hydraulic Calculations : Coal Stock Yard Settling Tank

Computed by: Nicholas Pilz
Date: September 2009
Checked by: _____
Date: _____
Page: 8 of 10

APPENDIX B


Sluice Gate Design

Technical

		Item no : 1.
G.A. Sketch No.		Q-5297 / 1.
Opening width x height (w x h)	mm	1500 x 1500
Invert to top of wall (X)	mm	4400
Max. Unbalanced head on gate (Hm)	m	2,50
Max. Operating head (Ho)	m	2,50
Direction of flow		Off-seating
Type of Invert		Flush
Spindle type		Rising
Spindle diameter	mm	45
Operating gear		Manual
Handwheel diameter	mm	600
Gearbox ratio (Twin Input)		3,5 & 7 : 1
Force to raise gate	N	92
Electric actuator		N/A

Materials of construction

Gate and Frame	3CR12
Seals	E.P.D.M.
Podestal / Bracket	3CR12
Wall bracket	3CR12
Spindle	S/S (304)
Spindle guide	BRONZE
Cover tube	PERSPEX
Handwheel	ALUMINIUM
Fasteners and or Anchor bolts	S/S (304)



Wall-mounted Sluice Gate

PANEL B CONSULTANTS JOINT VENTURE Calculation Record

Client Name: ESKOM **Page:** 1 **of** 5

Project Name: Kusile Power Station **Job No:** 303-00098/06

Calculation Title: Particle Settling Calculations : SDD Settling Tanks

Calculation No./File No.: _____

Calculation is: Preliminary Final

Objective: Particle Settling calculations for the CSY Settling Tanks to quantify the size of particle that can be removed in the tank.

Unverified assumptions requiring subsequent verification			
No.	Assumption	Verified by	Date
	None		

This section applies to computer generated calculations	
Program Name/Number: <u>N/A</u>	Version: _____
Program Name/Number: <u>N/A</u>	Version: _____
Evidence of or reference to computer program verification, if applicable:	
Bases or reference thereto supporting application of the computer program to the physical problem:	

Review and approval						
Rev	Prepared by	Date	Verified by	Date	Approved by	Date
0	Scott Rees	Mar 10	JRW	Mar 10		

1. PURPOSE:

To calculate the size of particle that can be settled for the design inflow rate.

2. REFERENCES:

1.	SDD SETTLING TANKS GENERAL ARRANGEMENT	5452/80/035	Rev	
.				

3. ASSUMPTIONS

Density of water = 1000kg/m³
Acceleration due to gravity = 9.81m/s²

Additional assumptions are listed in the detailed hydraulic calculations, where applicable.

4. HYDRAULIC CALCULATIONS

APPENDICES

None

Calculations

Settling Compartment Parameters	
Effective Width (m)	16.0
Length (m)	125.0
Effective Length (m)	112.5
Depth (m)	2.0
Length/Width Ratio	7.8
Storage Volume (m ³)	3987.5
Cross Sectional Area (m ²)	31.9

- Width is the average rectangular section representing the trapezoidal shape of the settling tank cross section

UNHINDERED PARTICLE SETTLING

Parameters	Variable	Units	Input
Specific Gravity of Solids	S _s	Dimensionless	1.5
Specific Gravity of Fluid	S _f	Dimensionless	1.0
Kinematic Viscosity of Fluid	ν	m ² /s	1.141E-06
Gravity	g	m/s ²	9.81
Particle Diameter	D	m	9.212E-05
Particle Shape Factor	S _f	Dimensionless	0.90

Terminal Velocity of Settling Particles , V_T

$$V_T = S_f * Y * [\nu * g * (S_s - S_f)]^{1/3}$$

where

$$Y = 0.0556 * X^2, \quad \text{if } X < 4 \quad (\text{Laminar Flow / Stokes' Law}),$$

$$Y = 0.21 * X, \quad \text{if } 4 < X < 70 \quad (\text{Transitional Flow / Allen's Law})$$

$$Y = 1.739 * X^{0.5}, \quad \text{if } X > 70 \quad (\text{Turbulent Flow / Newton's Law})$$

and

$$X = [(S_s - S_f) * g / \nu]^{1/3} * D$$

Drag Coefficient, C_D

$C_D = 24 / Re_p$, if Laminar Flow

$C_D = 14 / Re_p^{0.5}$, if Transitional Flow

$C_D = 0.44$, if Turbulent Flow

TERMINAL SETTLING VELOCITY OF PARTICLES

X = 1.433

Y = 0.114

Y = 0.000

Y = 0.000

Y = 0.114

$V_T = 1.83E-03$ m/s


**Re = 1.47E-01 LAMINAR
SETTLING**

$C_D = 162.86$

Impoundment Time (s):	1095.802
Impoundment Time (min):	18.26
Impoundment time (hrs):	0.30

Settling Velocity V_T (m/s):	1.83E-03
Time Required to Settle Selected Particles (s):	1095.70
Distance Required to Settle Selected Particles (m):	112.49
Required Settling Achieved?	YES

Figure illustrating particle size settled versus inflow rate to the settling tank (note as inflow rate increases the particle size settled becomes larger, ie. The tank becomes less effective due to shorter retention time)



PANEL B CONSULTANTS JOINT VENTURE Calculation Record

Client Name: ESKOM **Page:** 1 **of** 28

Project Name: SDD SETTLING TANKS **Job No:** K5452-80-035

Calculation Title: INLET & OUTLET WALLS

Calculation No./File No.: K5452-80-035 R2 (REPORT 1 OF 3)

Calculation is: Preliminary Final

Objective: Determine concrete sizes and required reinforcement areas for ULS & SLS on retaining walls

Unverified assumptions requiring subsequent verification

No.	Assumption	Verified by	Date
1	Fluid density – 10kN/m ³	KG	01/08/2009
2	Soil pressure (see “Annexure A”)	KG	01/08/2009
3	Founding on non-yielding material	KG	01/08/2009

See page ____ of this calculation for additional assumptions.

This section applies to computer generated calculations

Program Name/Number:	Autodesk Robot Structural Analysis 2010	Version:	V23.0.1.3128
Program Name/Number:	Autodesk Revit Structure 2010	Version:	V2010
Evidence of or reference to computer program verification, if applicable: See “Annexure B”			
Bases or reference thereto supporting application of the computer program to the physical problem: Finite element analysis (FEA) method can be implemented with acceptable standards to South Africa			

Review and approval

Rev	Prepared by	Date	Verified by	Date	Approved by	Date
1	C Vorster	01/08/09	AR Gorman PrEng	01/08	K Georgala PrEng	05/08

1. PURPOSE:

Determination of structure dimensions and required reinforcement under specified load.

2. REFERENCES:

<input type="checkbox"/>	1. Concrete layout drawing	K5452-80-035	Rev	R2
<input type="checkbox"/>	2.		Rev	

3. LOAD CASES AND COMBINATIONS

Load Cases:

1. Self Weight
2. Soil Pressure


Load Combinations:

10. Self+Soil-ULS
11. Self+Soil-SLS

4. APPLICATIONS:

INLET WALLS:

STRUCTURAL MODEL VIEW:




Note:


A 25mm expansion joint (in walls only), present at gridlines 2 & 3.

Concrete sizes & Reinforcement:

-Side walls on gridline A, between gridlines 1-3 & 3-4:



Reinforcement area diagram:




(cm²/m)


Continued on next page.

**PANEL B
CONSULTANTS
JOINT
VENTURE**


Client:	ESKOM	Computed by:	CV
Project:	Kusile Power Station	Date:	01/08/2009
Job no.:	5452-80-040	Checked by:	KG & ARG
Title:	SDD SETTLING TANK	Date:	01/07/2009
	Structural design calculations and reports	Page:	4 of 28



-Inlet box walls between gridlines 2 & 3, excluding baffle wall:




Reinforcement area diagram:




(cm²/m)


Suggested reinforcement:



Wall corner details:





OUTLET WALLS:
STRUCTURAL MODEL VIEW:




Concrete sizes & Reinforcement:

-Side wall on Eastern side, on gridline E, between gridlines 1 & 2:





**EAST OUTLET WALL
LOWER PORTION**



EAST OUTLET WALL UPPER PORTION


-Side wall on Western side, on gridline E, between gridlines 4 & 5:






WEST OUTLET WALL

-Outlet back wall, on gridline F, between gridlines 2 & 4:




OUTLET BACK WALL

-Strap beams between gridline E & F:



STRAP BEAMS

-Inlet wall on gridline E, between gridlines 2 & 4:




INLET WALL

**PANEL B
CONSULTANTS
JOINT
VENTURE**

Client: ESKOM
Project: Kusile Power Station Component: WALLS
Job no.: 5452-80-040 File no.: 5452
Title: SDD SETTLING TANK
Structural design calculations and reports

Computed by: CV
Date: 01/08/2009
Checked by: KG & ARG
Date: 01/07/2009
Page: 12 of 28

-Side walls on gridlines 2 and 4, between gridlines E & F :



SIDE WALLS

PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	CV	
	Project:	Kusile Power Station	Component:	WALLS	Date:	01/08/2009
	Job no.:	5452-80-040	File no.:	5452	Checked by:	KG & ARG
	Title:	SDD SETTLING TANK		Date:	01/07/2009	
		Structural design calculations and reports		Page:	13 of 28	

5. PROCEDURE/METHODOLOGY OF DESIGN:

- 5.1 The Robot Retaining wall module has been applied for this analysis
- 5.2 2 Load cases and 2 Load combinations have been analyzed, as indicated in "Annexure A"

6. ASSUMPTIONS:

- 6.1 Assumptions requiring verification will be listed on the cover sheet

7. DEFINITION OF UNITS AND CONSTANTS:

Refer to "Annexure A"

8. ANALYSIS/SOLUTION:(see body of calculation for analysis and solutions)

Note: Detailed calculations output data to be provided on request.

9. METHOD OF RESULTS GENERATION:

All loads and load combinations are defined as load cases within Robot Structural Analysis, combinations have the addition of factors applied as explained on pages 14-28 of this document, and are governed by ULS or SLS criteria.

The results displayed in this document, represents the worst cases of all possible cases, where each case has been analyzed individually as well as specified in combination cases.

10. APPENDICES TO CALCULATIONS:

- 10.1 Appendix A – Calculations
- 10.2 Appendix B – Autodesk Robot Structural Analysis 2010 verification report


PANEL B	Client:	ESKOM	Computed by:	CV
CONSULTANTS	Project:	Kusile Power Station	Date:	01/08/2009
JOINT	Job no.:	5452-80-040	Checked by:	KG & ARG
VENTURE	Title:	SDD SETTLING TANK	Date:	01/07/2009
		Structural design calculations and reports	Page:	14 of 28

APPENDIX A

CALCULATIONS

8.1 SDD WALL DESIGN

STRUCTURE VIEW:



CALCULATION NOTE

Code preferences:

- **BS 8110** – CONCRETE DESIGN
- **BS8004 / PN-83/B-03010** – SOIL CODE
- **SABS 1060** – CODE COMBINATIONS
- **PN-B-03264(2002)** – RETAINING WALL DESIGN

Retaining wall : SIDE WALL

1. Calculation parameters:


MATERIAL:

- **CONCRETE:** class B 30, fck = 30.00 (MN/m²),
unit weight = 24.00 (kN/m³)
- **STEEL:** class A - III, fyk = 450.00 (MN/m²)

OPTIONS:

- Calculations according to: concrete code: **BS8110**
soil code: **BS8004**
- Cover: c1 = 50.0 (mm), c2 = 50.0 (mm)
- Exposure: X0
- Retainig wall design according to:
 - Capacity m = 0.810 g = 2.000
 - Sliding m = 0.720 g = 2.000
 - Overturning m = 0.720 g = 2.000
- Retainig wall verification according to:
 - Average settlement:
S_{dop} = 100.00 (mm)
 - Settlement differences:
DS_{dop} = 50.00 (mm)
- Reduction factors for:
 - Soil cohesion 100.000 %
 - Soil frictions 0.000 %
 - Wall passive pressure 50.000 %
 - Key passive pressure 100.000 %
- Wall/soil friction angle:
 - Passive pressure for cohesive soils -1/3×φ
 - Cohesive soil pressure 1/2×φ
 - Passive pressure for non-cohesive soils -1/3×φ
 - Pressure for non-cohesive soils 1/2×φ

2. Geometry:



3. Soil:


- **Soil parameter selection - method: B**
- **Backfill** Soil depth (behind the wall) Ho = 3000.00 (mm)
- **Original layers:**

Description:

No.	Soil name	Level [mm]	Thickness [mm]	Consolidation type	Moisture type	I _p /I _L
1.	clayey fine sands	500.00	-	-	-	0.000

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1.	67.03	18.00	21.21	29.65	29.65



- **Soils (behind the wall):**

Description:

No.	Soil name	Level* [mm]	Thickness [mm]	Consolidation type	Moisture type	I _p /I _L
1	well graded gravels	500.00	500.00	-	-	0.000

* With respect to the lower right footing point

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1	0.00	42.00	21.99	199.50	199.50

- **Soils (before the wall):**


Description:

No.	Soil name	Level* [mm]	Thickness [mm]	Consolidation type	Moisture type	I _p /I _L
1	well graded gravels	5700.00	5700.00	-	-	0.000


* With respect to the lower left footing point

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1	0.00	42.00	21.99	199.50	199.50



4. Loads



- **Load report**

5. Results (soils)

PRESSURES

Soil pressure and passive pressure : according to wall displacements
 Factors for pressures and passive pressures for soils:

Average backfill slope angle $\varepsilon = 0.00$ (Deg)

Wall inclination angle $\beta = 0.00$ (Deg)

$$K_a = \frac{\cos^2 \cdot (\beta - \phi)}{\cos^2 \beta \cdot \cos(\beta + \delta_2) \cdot \left(1 + \sqrt{\frac{\sin(\phi + \delta_2) \cdot \sin(\phi - \varepsilon)}{\cos(\beta + \delta_2) \cdot \cos(\beta - \varepsilon)}} \right)^2}$$

$$K_p = \frac{\cos^2 \cdot (\beta + \phi)}{\cos^2 \beta \cdot \cos(\beta + \delta_2) \cdot \left(1 - \sqrt{\frac{\sin(\phi - \delta_2) \cdot \sin(\phi + \varepsilon)}{\cos(\beta + \delta_2) \cdot \cos(\beta - \varepsilon)}} \right)^2}$$

$$K_o = \frac{\sigma_x}{\sigma_z} = \frac{\nu}{1 - \nu}$$

$$K_a \leq K_o \leq K_p$$

Soils (behind the wall):

No.	Soil name	Level [mm]	Friction angle [Deg]	Ka	Ko	Kp
1.	well graded gravels	500.00	42.00	0.183	0.331	9.569

- Generalized limit displacements

passive pressure

0.132

pressure 0.013

Soils (before the wall):

No.	Soil name	Level [mm]	Friction angle [Deg]	Ka	Ko	Kp
1.	well graded gravels	0.00	42.00	0.528	0.691	1.894
2.	well graded gravels	5700.00	42.00	0.198	0.331	5.045

- Generalized limit displacements

passive pressure

0.117

pressure 0.012

PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM	Computed by:	CV
	Project:	Kusile Power Station	Component:	WALLS
	Job no.:	5452-80-040	File no.:	5452
	Title:	SDD SETTLING TANK	Date:	01/08/2009
		Structural design calculations and reports	Checked by:	KG & ARG
		Date:	01/07/2009	
		Page:	20	of 28

CAPACITY

- Soil type under footing: not layered
- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -372.82 \text{ (kN/m)}$ $M_y = 286.76 \text{ (kN} \cdot \text{m)}$ $F_x = 213.00 \text{ (kN/m)}$
- Equivalent footing dimension: $A = 2467.02 \text{ (mm)}$
- Coefficient of load capacity and influence of load inclination:

$N_B = 0.745$	$i_B = 0.059$
$N_C = 11.768$	$i_C = 0.266$
$N_D = 4.419$	$i_D = 0.442$

- Soil limit pressure: $Q_f = 1049.17 \text{ (kN/m)}$
- Safety factor: $Q_f \cdot m / N_r = 2.279 > 2.000$

SETTLEMENT

- Soil type under foundation: not layered
- Design combination: $1.000 \cdot PM + 1.000 \cdot P'a + 1.000 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -407.17 \text{ (kN/m)}$ $M_y = 348.60 \text{ (kN} \cdot \text{m)}$ $F_x = 218.72 \text{ (kN/m)}$
- Unit load of total loads: $q = 0.10 \text{ (MN/m}^2\text{)}$
- Thickness of the actively settling soil: $z = 3000.00 \text{ (mm)}$
- Stress on the level z:
 - additional: $s_{zd} = 0.01 \text{ (MN/m}^2\text{)}$
 - caused by soil weight: $s_{zg} = 0.08 \text{ (MN/m}^2\text{)}$
- Settlement: $S = 3.29 \text{ (mm)} < S_{dop} = 100.00 \text{ (mm)}$

OVERTURNING

- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -372.82 \text{ (kN/m)}$ $M_y = 286.76 \text{ (kN} \cdot \text{m)}$ $F_x = 213.00 \text{ (kN/m)}$
- Overturning moment: $M_o = 187.38 \text{ (kN} \cdot \text{m)}$
- Moment preventing foundation overturning: $M_{uf} = 1311.98 \text{ (kN} \cdot \text{m)}$
- Safety factor: $M_{uf} \cdot m / M_o = 5.041 > 2.000$

SLIDING


- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -372.82 \text{ (kN/m)}$ $M_y = 286.76 \text{ (kN} \cdot \text{m)}$ $F_x = 213.00 \text{ (kN/m)}$
- Equivalent footing dimension: $A = 4250.00 \text{ (mm)}$
- Friction coefficient:
 - of soil (on the settlement level): $\mu = 0.034$
- Soil cohesion reduction factor = 100.000 %
- Cohesion: $C = 7.10 \text{ (kN/m}^2\text{)}$
- Sliding force value: $Q_{tr} = 213.00 \text{ (kN/m)}$
- Value of force preventing wall sliding:
 - $Q_{tf} = N \cdot \mu + C \cdot A$
 - - on the foundation level: $Q_{tf} = 42.91 \text{ (kN/m)}$
- Safety factor: $Q_{tf} \cdot m / Q_{tr} = 1.768 < 2.000$

OVERTURNING ANGLES

- Soil type under foundation: not layered
- Design combination: $1.000 \cdot PM + 1.000 \cdot P'a + 1.000 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -407.17 \text{ (kN/m)}$ $M_y = 348.60 \text{ (kN}\cdot\text{m)}$ $F_x = 218.72 \text{ (kN/m)}$
- Maximum unit stresses from total loads:
 $q_{max} = 0.20 \text{ (MN/m}^2\text{)}$
- Minimum unit stresses from total loads:
 $q_{min} = 0.00 \text{ (MN/m}^2\text{)}$
- Overturning angle: $\theta = -0.13 \text{ (Deg)}$
- Coordinates of wall rotation point:
 $X = 237.28 \text{ (mm)}$
 $Z = 0.00 \text{ (mm)}$
- Safety factor: $5.544 > 2.000$

6. Results of RC design

- Moments



(kN*m)

Element	Moments	Value [kN*m]	Position [mm]	Combination
Wall	maximum	0.00	5700.00	$0.900 \cdot PM + 1.100 \cdot P'a + 0.900 \cdot Pa + 1.000 \cdot W$
Wall	minimum	-268.67	500.00	$0.900 \cdot PM + 1.100 \cdot P'a + 1.320 \cdot Pa + 1.000 \cdot W$
Footing	maximum	24.14	3750.00	$1.100 \cdot PM + 1.100 \cdot P'a + 1.320 \cdot Pa + 1.000 \cdot W$
Footing	minimum	-266.58	3250.00	$0.900 \cdot PM + 1.100 \cdot P'a + 1.320 \cdot Pa + 1.000 \cdot W$

Retaining wall : INLET BOX WALLS

1. Calculation parameters:


MATERIAL:

- **CONCRETE:** class B 30, fck = 30.00 (MN/m²),
unit weight = 24.00 (kN/m³)
- **STEEL:** class A - III, fyk = 450.00 (MN/m²)

OPTIONS:

- Calculations according to: concrete code: **BS8110**
soil code: **BS8004**
- Cover: c1 = 50.0 (mm), c2 = 50.0 (mm)
- Exposure: X0
- Retainig wall design according to:
 - Capacity m = 0.810 g = 2.000
 - Sliding m = 0.720 g = 2.000
 - Overturning m = 0.720 g = 2.000
- Retainig wall verification according to:
 - Average settlement:
S_{dop} = 100.00 (mm)
 - Settlement differences:
DS_{dop} = 50.00 (mm)
- Reduction factors for:
 - Soil cohesion 100.000 %
 - Soil frictions 0.000 %
 - Wall passive pressure 50.000 %
 - Key passive pressure 100.000 %
- Wall/soil friction angle:
 - Passive pressure for cohesive soils -1/3×φ
 - Cohesive soil pressure 1/2×φ
 - Passive pressure for non-cohesive soils -1/3×φ
 - Pressure for non-cohesive soils 1/2×φ

2. Geometry:



3. Soil:


- **Soil parameter selection - method: B**
- **Backfill** Soil depth (behind the wall) Ho = 3000.00 (mm)
- **Original layers:**

Description:

No.	Soil name	Level [mm]	Thickness [mm]	Consolidation type	Moisture type	I _p /I _L
1.	clayey fine sands	500.00	-	-	-	0.000

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1.	67.03	18.00	21.21	29.65	29.65



- **Soils (behind the wall):**

Description:

No.	Soil name	Level* [mm]	Thickness [mm]	Consolidation type	Moisture type	I _p /I _L
1	well graded gravels	500.00	500.00	-	-	0.000

* With respect to the lower right footing point

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1	0.00	42.00	21.99	199.50	199.50

- **Soils (before the wall):**


Description:

No.	Soil name	Level* [mm]	Thickness [mm]	Consolidation type	Moisture type	I _p /I _L
1	well graded gravels	5200.00	5200.00	-	-	0.000


* With respect to the lower left footing point

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1	0.00	42.00	21.99	199.50	199.50



4. Loads



- **Load report**

5. Results (soils)

PRESSURES

Soil pressure and passive pressure : according to wall displacements
 Factors for pressures and passive pressures for soils:

Average backfill slope angle $\epsilon = 0.00$ (Deg)

Wall inclination angle $\beta = 0.00$ (Deg)

$$K_a = \frac{\cos^2 \cdot (\beta - \phi)}{\cos^2 \beta \cdot \cos(\beta + \delta_2) \cdot \left(1 + \sqrt{\frac{\sin(\phi + \delta_2) \cdot \sin(\phi - \epsilon)}{\cos(\beta + \delta_2) \cdot \cos(\beta - \epsilon)}} \right)^2}$$

$$K_p = \frac{\cos^2 \cdot (\beta + \phi)}{\cos^2 \beta \cdot \cos(\beta + \delta_2) \cdot \left(1 - \sqrt{\frac{\sin(\phi - \delta_2) \cdot \sin(\phi + \epsilon)}{\cos(\beta + \delta_2) \cdot \cos(\beta - \epsilon)}} \right)^2}$$

$$K_o = \frac{\sigma_x}{\sigma_z} = \frac{\nu}{1 - \nu}$$

$$K_a \leq K_o \leq K_p$$

Soils (behind the wall):

No.	Soil name	Level [mm]	Friction angle [Deg]	Ka	Ko	Kp
1.	well graded gravels	500.00	42.00	0.183	0.331	9.569

- Generalized limit displacements

passive pressure

0.132

pressure 0.013

Soils (before the wall):

No.	Soil name	Level [mm]	Friction angle [Deg]	Ka	Ko	Kp
1.	well graded gravels	0.00	42.00	0.528	0.691	1.894
2.	well graded gravels	5200.00	42.00	0.198	0.331	5.045

- Generalized limit displacements

passive pressure

0.117

pressure 0.012

PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	CV	
	Project:	Kusile Power Station	Component:	WALLS	Date:	01/08/2009
	Job no.:	5452-80-040	File no.:	5452	Checked by:	KG & ARG
	Title:	SDD SETTLING TANK		Date:	01/07/2009	
		Structural design calculations and reports		Page:	26	of 28

CAPACITY

- Soil type under footing: not layered
- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -288.30$ (kN/m) $M_y = 171.33$ (kN*m) $F_x = 208.95$ (kN/m)
- Equivalent footing dimension: $A = 1963.77$ (mm)
- Coefficient of load capacity and influence of load inclination:

$N_B = 0.745$	$i_B = 0.059$
$N_C = 11.768$	$i_C = 0.266$
$N_D = 4.419$	$i_D = 0.442$

- Soil limit pressure: $Q_f = 816.41$ (kN/m)
- Safety factor: $Q_f \cdot m / N_r = 2.294 > 2.000$

SETTLEMENT

- Soil type under foundation: not layered
- Design combination: $1.000 \cdot PM + 1.000 \cdot P'a + 1.000 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -311.92$ (kN/m) $M_y = 205.45$ (kN*m) $F_x = 214.09$ (kN/m)
- Unit load of total loads: $q = 0.10$ (MN/m²)
- Thickness of the actively settling soil: $z = 2625.00$ (mm)
- Stress on the level z:
 - additional: $s_{zd} = 0.01$ (MN/m²)
 - caused by soil weight: $s_{zg} = 0.08$ (MN/m²)
- Settlement: $S = 2.54$ (mm) < $S_{dop} = 100.00$ (mm)

OVERTURNING

- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -288.30$ (kN/m) $M_y = 171.33$ (kN*m) $F_x = 208.95$ (kN/m)
- Overturning moment: $M_o = 152.37$ (kN*m)
- Moment preventing foundation overturning: $M_{uf} = 878.36$ (kN*m)
- Safety factor: $M_{uf} \cdot m / M_o = 4.150 > 2.000$

SLIDING


- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -288.30$ (kN/m) $M_y = 171.33$ (kN*m) $F_x = 208.95$ (kN/m)
- Equivalent footing dimension: $A = 3500.00$ (mm)
- Friction coefficient:
 - of soil (on the settlement level): $\mu = 0.042$
- Soil cohesion reduction factor = 100.000 %
- Cohesion: $C = 8.62$ (kN/m²)
- Sliding force value: $Q_{tr} = 208.95$ (kN/m)
- Value of force preventing wall sliding:
 - $Q_{tf} = N \cdot \mu + C \cdot A$
 - - on the foundation level: $Q_{tf} = 42.13$ (kN/m)
- Safety factor: $Q_{tf} \cdot m / Q_{tr} = 1.895 < 2.000$

OVERTURNING ANGLES

- Soil type under foundation: not layered
- Design combination: $1.000 \cdot PM + 1.000 \cdot P'a + 1.000 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -311.92 \text{ (kN/m)}$ $M_y = 205.45 \text{ (kN}\cdot\text{m)}$ $F_x = 214.09 \text{ (kN/m)}$
- Maximum unit stresses from total loads:
 $q_{max} = 0.20 \text{ (MN/m}^2\text{)}$
- Minimum unit stresses from total loads:
 $q_{min} = 0.00 \text{ (MN/m}^2\text{)}$
- Overturning angle: $\theta = -0.14 \text{ (Deg)}$
- Coordinates of wall rotation point:
 $X = 303.59 \text{ (mm)}$
 $Z = 0.00 \text{ (mm)}$
- Safety factor: $6.368 > 2.000$

6. Results of RC design

- Moments



(kN*m)

Element	El	Moments	Value [kN*m]	Position [mm]	Combination
Wall		maximum	0.00	5200.00	$1.100 \cdot PM + 0.765 \cdot P'a + 1.320 \cdot Pa + 1.000 \cdot W$
Wall		minimum	-197.86	500.00	$0.900 \cdot PM + 1.100 \cdot P'a + 1.320 \cdot Pa + 1.000 \cdot W$
Footing		maximum	22.98	3000.00	$1.100 \cdot PM + 1.100 \cdot P'a + 1.320 \cdot Pa + 1.000 \cdot W$
Footing		minimum	-159.20	2500.00	$0.900 \cdot PM + 1.100 \cdot P'a + 1.320 \cdot Pa + 1.000 \cdot W$

PANEL B	Client:	ESKOM	Computed by:	CV
CONSULTANTS	Project:	Kusile Power Station	Date:	01/08/2009
JOINT	Job no.:	5452-80-040	Checked by:	KG & ARG
VENTURE	Title:	SDD SETTLING TANK	Date:	01/07/2009
		Structural design calculations and reports	Page:	28 of 28

APPENDIX B

AUTODESK ROBOT STRUCTURES 2010 VERIFICATION

CONCRETE


1. BS 9/1/96 – RC columns

VERIFICATION EXAMPLE 1 - Column subjected to axial load and biaxial bending

DESCRIPTION OF THE EXAMPLE:

Following example illustrates the procedure of dimensioning of biaxial bending of column, which is non-sway in one direction, whereas sway in the other. The results of the program are accompanied by the „manual” calculations.

1. SECTION DIMENSIONS



2. MATERIALS

Concrete	: C20	$f_{cu} = 20.00$ (MPa)
Longitudinal reinforcement	: T	$f_y = 460.00$ (MPa)
Transversal reinforcement	: R	$f_y = 250.00$ (MPa)

3. BUCKLING MODEL

Direction Y

Off

Structure

Non-sway

Sway

$L_{oy} =$ m

$\beta_y =$

Direction Z

Off

Structure

Non-sway

Sway

$L_{oz} =$ m

$\beta_z =$

As can be seen the sway column is assumed for Z direction, and the non-sway column for Y direction.


4. LOADS

No.	Case	Nature	Group	H (kH)	MyA (kH'm)	MyB (kH'm)	MyC (kH'm)	MzA (kH'm)	MzB (kH'm)	MzC (kH'm)	γ
1	DL1	dead load	1	400.00	150.00	30.00	102.00	20.00	30.00	50.00	1.40
2	LL1	Live	1	150.00	120.00	30.00	84.00	10.00	20.00	40.00	1.60
*											

NOTE: Let us assume, the moments in Y direction are linearly distributed along the height of the column. Thus, we define only the ends' moments for Y direction. In Z direction however, we assume the mid-height moment is not a result of the linear distribution. For such a case, Robot let the user define the moments in the mid-section explicitly.

5. CALCULATED REINFORCEMENT:

Program generates the reinforcement 14 ϕ 20.




6. RESULTS OF THE SECTION CALCULATIONS:

The dimensioning combination is 1.4DL1+1.6LL1

The dimensioning section (where the most unfavorable set of forces is found) is for that combination the section in the mid-height of the column (marked as (C)).

Intersection			
Load types <input checked="" type="radio"/> Basic <input type="radio"/> Accidental			
Description	H (kN)	My (kN*m)	Mz (kN*m)
1.40DL1+1.60LL1 (A)	800.00	423.33	71.04
1.40DL1+1.60LL1 (C)	800.00	319.87	161.04
1.40DL1+1.60LL1 (B)	800.00	111.33	101.04
1.40DL1 (A)	560.00	224.93	46.93
1.40DL1 (C)	560.00	172.67	88.93
1.40DL1 (B)	560.00	56.93	60.93
1.00DL1+1.60LL1 (A)	640.00	359.07	57.63
1.00DL1+1.60LL1 (C)	640.00	270.53	135.63
1.00DL1+1.60LL1 (B)	640.00	95.07	83.63

Rd / Sd	1.00	<	1.05
MRd / MSd	1.00	<	1.05
NRd / NSd	1.00	<	1.76



Since the column is found as slender, in both direction the second-order effects are taken into account.

In parallel the other sections (at the ends of the column) are checked for all combinations of loads. All the results of total forces for each combination and each section of the column may be seen in the table "Intersection" at the Column-results layout.

7. CALCULATIONS OF TOTAL MOMENT:

7.1. LOADS

For the dimensioning combination, the loads are:

	Case	N (kN)	MyA (kN*m)	MyB (kN*m)	MyC (kN*m)	MzA (kN*m)	MzB (kN*m)	MzC (kN*m)
1	DL1	400	150	30	102	20	30	50*
2	LL1	150	120	30	84	10	20	40*
Dimensioning combination	1.4DL1+1.6LL1	800	402	90	277.2	44	74	134

,where A, B and C denote upper, lower and mid-height sections of the column respectively.

* - the values are written "by hand" by the user (see point 4 – Loads)

7.2. THE INFLUENCE OF SLENDERNESS

Two independent calculations of the total moment for both directions are carried out.

Slenderness analysis acc. to 3.8.1.3:

$$l_{ey} / h = 13.33 < 15 \text{ (non-sway for Y direction)}$$

$$l_{ez} / b = 13.0 > 10 \text{ (sway for Z direction)}$$

Since the ratio l_{ez} / b exceeds the limit, the column is found as **slender**.

Y DIRECTION

Calculation of minimum eccentricity e_{min} and minimum moment M_{min} – 3.8.2.4

$$e_{min} = \min(0.05 \cdot h; 0.02m) = 0.02 \text{ (m)}$$

$$M_{min} = N \cdot e_{min} = 16.0 \text{ (kNm)}$$

Calculation of initial moment M_i – eq. 36

For the mid-height section, we have:

$$M_i = 0.4 \cdot M_1 + 0.6 \cdot M_2 = 277.2 \text{ (kNm)} > 0.4 \cdot M_2 = 160.8 \text{ (kNm)}$$

Calculation of second-order eccentricity a_u – eq. 32

$$a_u = \beta_a K h = 0.053 \text{ (m)}$$

$$\beta_a = \frac{1}{2000} \left(\frac{l_e}{h} \right) = 0.088$$

$$K = \min \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}}; 1 \right)$$

$$N_{uz} = \frac{2}{3} \frac{f_{cu}}{\gamma_c} A_c + \frac{f_y}{\gamma_s} A_{sc} = 4060.18 \text{ (kN)}$$

$$A_c = 0.24 \text{ (m}^2\text{)}$$

$$A_{sc} = 43.98 \text{ (cm}^2\text{)}$$

$N_{bal} = 1222.64 \text{ (kN)}$ – note that this value is calculated in detail for the state equilibrium in a section. Using the approximated code formula one would obtain

$$N_{bal} = 1173.33 \text{ (kN)}$$

$$K = \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}} \right) = \quad \text{- thus, } K = 1 \text{ was assumed}$$

Calculation of second-order moment M_{add}

$$M_{add} = N \cdot a_u = 42.67 \text{ (kNm)}$$

NOTE: The second-order effects in Robot are taken into account dependent upon the section and upon the parameter sway/non sway in a following way:

- in non-sway structures, M_{add} is added for the mid-height section, while $0.5 M_{add}$ is added for the end sections. Such addition is carried out disregarding the distribution of the first-order moment.
- in sway structures, M_{add} is added to each of three sections of column. Such addition is carried out disregarding the distribution of the first-order moment.

The total moment M_y :

$$M_y = M_i + M_{add} = 319.87 \text{ (kNm)} > 16.00 \text{ (kNm)} = M_{min}$$

Z DIRECTION

Calculation of minimum eccentricity e_{min} and minimum moment M_{min} – 3.8.2.4

$$e_{min} = \min(0.05 \cdot b; 0.02m) = 0.02 \text{ (m)}$$

$$M_{min} = N \cdot e_{min} = 16.0 \text{ (kNm)}$$

Calculation of initial moment M_i – eq. 36

For the mid-height section, we have the moment fixed directly by the user:

$$M_i = 134 \text{ (kNm)}$$

Calculation of second-order eccentricity a_u – eq. 32

$$a_u = \beta_a K h = 0.034 \text{ (m)}$$

$$\beta_a = \frac{1}{2000} \left(\frac{l_e}{b} \right) = 0.0845$$

$$K = \min \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}}; 1 \right)$$

$$N_{uz} = \frac{2}{3} \frac{f_{cu}}{\gamma_c} A_c + \frac{f_y}{\gamma_s} A_{sc} = 4060.18 \text{ (kN)}$$

$$A_c = 0.24 \text{ (m}^2\text{)}$$

$$A_{sc} = 43.98 \text{ (cm}^2\text{)}$$

$N_{bal} = 1222.64 \text{ (kN)}$ – note that this value is calculated in detail for the state equilibrium in a section. Using the approximated code formula one would obtain

$$N_{bal} = 1173.33 \text{ (kN)}$$

$$K = \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}} \right) = \quad \text{- thus, } K = 1 \text{ was assumed}$$

Calculation of second-order moment M_{add}

$$M_{add} = N \cdot a_u = 27.04 \text{ (kNm)}$$

NOTE: The second-order effects in Robot are taken into account dependent upon the section and upon the parameter sway/non sway in a following way:

- in non-sway structures, M_{add} is added for the mid-height section, while $0.5 M_{add}$ is added for the end sections. Such addition is carried out disregarding the distribution of the first-order moment.

- in sway structures, M_{add} is added to each of three sections of column. Such addition is carried out disregarding the distribution of the first-order moment.

The total moment M_z :

$$M_z = M_i + M_{add} = 161.04 \text{ (kNm)} > 16.00 \text{ (kNm)} = M_{\min}$$

7.3. FINAL RESULT

$$M_y = 320 \text{ (kNm)}$$

$$M_z = 161 \text{ (kNm)}$$

8. CONCLUSIONS

The algorithm of calculations of the total moments (i.e. slenderness effects) in non-sway/sway column has been presented. The results obtained with the program (see point 6 – Results of the Section Calculations) are in agreement with the manual calculations (see point 7.3 – Final Result)

LITERATURE

[1] British Standard BS 8110: 1985. Structural use of concrete. British Standard Institution, 1985.

PANEL B CONSULTANTS JOINT VENTURE Calculation Record

Client Name: ESKOM **Page:** 1 **of** 24

Project Name: SDD SETTLING TANK **Job No:** K5452-035

Calculation Title: INTERNAL WALLS

Calculation No./File No.: K5452-035 R1d (REPORT 2 OF 3)

Calculation is: Preliminary Final

Objective: Determine concrete sizes and required reinforcement areas for ULS & SLS on retaining walls

Unverified assumptions requiring subsequent verification

No.	Assumption	Verified by	Date
1	Fluid density – 10kN/m ³	KG	18/06/2009
2	Soil pressure (see “Annexure A”)	KG	18/06/2009
3	Founding on non-yielding material	KG	18/06/2009

See page ____ of this calculation for additional assumptions.

This section applies to computer generated calculations

Program Name/Number:	Autodesk Robot Structural Analysis 2010	Version:	V23.0.1.3128
Program Name/Number:	Autodesk Revit Structure 2010	Version:	V2010
Evidence of or reference to computer program verification, if applicable: See “Annexure B”			
Bases or reference thereto supporting application of the computer program to the physical problem: Finite element analysis (FEA) method can be implemented with acceptable standards to South Africa			

Review and approval

Rev	Prepared by	Date	Verified by	Date	Approved by	Date
1	C Vorster	18/06/09	AR Gorman PrEng		K Georgala PrEng	

1. PURPOSE:

Determination of structure dimensions and required reinforcement under specified load.

2. REFERENCES:

<input type="checkbox"/>	1. Concrete layout drawing	K5452-035	Rev	P1
<input type="checkbox"/>	2.		Rev	

3. LOAD CASES AND COMBINATIONS

Load Cases:


1. Self Weight
2. Water Pressure
3. Soil Pressure

Load Combinations:

4. ULS
5. SLS

4. APPLICATIONS:

KEY PLAN:





**PANEL B
CONSULTANTS
JOINT
VENTURE**

Client:	ESKOM	Computed by:	CV
Project:	Kusile Power Station	Component:	Internal walls
Job no.:	5452/35	File no.:	5452
Title:	SDD SETTLING TANK	Date:	18/06/2009
	Structural design calculations and reports	Checked by:	KG & ARG
		Date:	29/06/2009
		Page:	3 of 24

REINFORCING:

RETAINING WALL ON GRIDLINE 3:

***NOTE: REFER TO APPENDIX A FOR DESIGN CALCULATION (PAGE 10-24)**



(cm²/m)

REINFORCEMENT AREA DIAGRAM

INTERPRETATION:

The diagram indicates required reinforcement in the retaining wall as follows:

wall from the left:

Required reinf. area	
144.4	cm2/m
Provided reinf. area	
Y16 every 250.00 mm =804mm ² – (Vertical)	

wall from the left (h/3):

Required reinf. area	
82.1	cm2/m
Provided reinf. area	
Y12 every 300.00 mm =377mm ² – (Horizontal)	

wall from the left (h/2):

Required reinf. area	
82.1	cm2/m
Provided reinf. area	
Y12 every 300.00 mm =377mm ² – (Horizontal)	

wall from the right:

Required reinf. area	
0.00 (Use minimum reinforcement)	cm2/m
Provided reinf. area	
Y16 every 250.00 mm =804mm ² – (Vertical)	

footing (+):



Required reinf. area	
82.1	cm2/m
Provided reinf. area	
Y12 every 250.00 mm =452mm ² – (Main bars Top & Bot)	

footing (-):

Required reinf. area	
82.1	cm2/m
Provided reinf. area	
Y12 every 250.00 mm =452mm ² - (Distribution bars Top & Bot)	

RETAINING WALL ON GRIDLINES C & D:

***NOTE: REFER TO APPENDIX A FOR DESIGN CALCULATION (PAGES 10-24)**



(cm²/m)

REINFORCEMENT AREA DIAGRAM

INTERPRETATION:

wall from the left:

Required reinf. area	
7.14	cm2/m
Provided reinf. area	
Y16 every 250.00 mm =804mm ² – (Vertical)	

wall from the left (h/3):

Required reinf. area	
7.14	cm2/m
Provided reinf. area	
Y12 every 250.00 mm =452mm ² – (Horizontal)	

wall from the left (h/2):

Required reinf. area	
7.14	cm2/m
Provided reinf. area	
Y12 every 250.00 mm =452mm ² – (Horizontal)	

wall from the right

Required reinf. area	
0.00 (Use minimum required reinforcement)	cm2/m
Provided reinf. area	
Y16 every 250.00 mm =804mm ² – (Vertical)	


footing (-):

Required reinf. area	
8.21	cm2/m
Provided reinf. area	
Y16 every 250.00 mm =804mm ² m - (Distribution bars Top & Bot)	

footing (+):

Required reinf. area	
8.21	cm2/m
Provided reinf. area	
Y16 every 250.00 mm =804mm ² – (Main bars Top & Bot)	

TYPICAL REINFORCEMENT LAYOUT OF WALL ON GRIDLINE 3:



JOINT LAYOUT:

Provide expansion joints through base of wall on gridline 3 at 40m c/c, and expansion joints at 20m c/c in wall.

PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	CV	
	Project:	Kusile Power Station	Component:	Internal walls	Date:	18/06/2009
	Job no.:	5452/35	File no.:	5452	Checked by:	KG & ARG
	Title:	SDD SETTLING TANK		Date:	29/06/2009	
		Structural design calculations and reports		Page:	8 of 24	

5. PROCEDURE/METHODOLOGY OF DESIGN:

- 4.1 The Robot Retaining wall module has been applied for this analysis
- 4.2 3 Load cases and 2 Load combinations have been analyzed, as indicated in "Annexure A"

6. ASSUMPTIONS:

- 5.1 Assumptions requiring verification will be listed on the cover sheet

7. DEFINITION OF UNITS AND CONSTANTS:

Refer to "Annexure A"

7. ANALYSIS/SOLUTION:(see body of calculation for analysis and solutions)

Note: Detailed calculations output data to be provided on request.

8. METHOD OF RESULTS GENERATION:

All loads and load combinations are defined as load cases within Robot Structural Analysis, combinations have the addition of factors applied as explained on pages 8-24 of this document, and are governed by ULS or SLS criteria.

The results displayed in this document, represents the worst cases of all possible cases, where each case has been analyzed individually as well as specified in combination cases.

9. APPENDICES TO CALCULATIONS:

- 9.1 Appendix A – Calculations
- 9.2 Appendix B – Autodesk Robot Structural Analysis 2010 verification report

PANEL B	Client:	ESKOM	Computed by:	CV
CONSULTANTS	Project:	Kusile Power Station	Date:	18/06/2009
JOINT	Job no.:	5452/35	Checked by:	KG & ARG
VENTURE	Title:	SDD SETTLING TANK	Date:	29/06/2009
		Structural design calculations and reports	Page:	9 of 24


APPENDIX A

CALCULATIONS

PANEL B	Client:	ESKOM	Computed by:	CV
CONSULTANTS	Project:	Kusile Power Station	Date:	18/06/2009
JOINT	Job no.:	5452/35	Component:	Internal walls
VENTURE	Title:	SDD SETTLING TANK	File no.:	5452
		Structural design calculations and reports	Checked by:	KG & ARG
			Date:	29/06/2009
			Page:	10 of 24

7.1.1 SDD SETTLING TANK WALL DESIGN

STRUCTURE VIEW



CALCULATION NOTE

Code preferences:

- **BS 8110** and **PN-B-03264(2002)** – Reinforced concrete design
- **PN-83/B-03010** – Soil Code

1. Calculation parameters for retaining wall on gridline 3:


MATERIAL:

- **CONCRETE:** class B 30, $f_{ck} = 30.00$ (MN/m²),
Unit weight = 24.00 (kN/m³)
- **STEEL:** class A - IIN, $f_{yk} = 450.00$ (MN/m²)

OPTIONS:

- Calculations according to: concrete code: **PN-B-03264(2002)**
soil code: **PN-83/B-03010**
- Cover: $c_1 = 50.0$ (mm), $c_2 = 50.0$ (mm)
- Exposure: X0
- Retaining wall design according to:
 - Capacity $m = 0.810$ $g = 2.000$
 - Sliding $m = 1.000$ $g = 2.000$
 - Overturning $m = 0.720$ $g = 2.000$
- Retaining wall verification according to:
 - Average settlement:
 $S_{dop} = 100.00$ (mm)
 - Settlement differences:
 $DS_{dop} = 50.00$ (mm)
 - Wall top displacements:
 $f_0 = 0.015$
 $f_1 = 0.010$
 $f_2 = 0.006$
 $f_3 = 0.004$
 - Wall/soil friction angle:
 - Passive pressure for cohesive soils $-1/3 \times \phi$
 - Cohesive soil pressure $1/2 \times \phi$
 - Passive pressure for non-cohesive soils $-1/3 \times \phi$
 - Pressure for non-cohesive soils $1/2 \times \phi$

2. Geometry:



3. Soil:


- **Soil parameter selection - method: A**
- **Backfill** Soil depth (behind the wall) Ho = 3000.00 (mm)
- **Original layers:**

Description:

No.	Soil name	Level [mm]	Thickness [mm]	Consolidation type	Moisture type	I _p /I _L
1.	silty fine sands	500.00	-	-	-	0.000

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1.	67.03	18.00	21.99	29.65	29.65



- **Soils (behind the wall):**

Description:

No.	Soil name	Level* [mm]	Thickness [mm]	Consolidation type	Moisture type	I _p /I _L
1	silty fine sands	500.00	500.00	-	-	0.000

* With respect to the lower right footing point

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1	67.03	18.00	21.99	29.65	29.65

- **Soils (before the wall):**


Description:

No.	Soil name	Level* [mm]	Thickness [mm]	Consolidation type	Moisture type	I _p /I _L
1	poorly graded sands	500.00	500.00	-	-	0.000


* With respect to the lower left footing point

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1	0.00	37.00	19.64	121.82	121.82



4. Loads



- **Load report**

.
 . 1 concentrated on wall
 . a1 live z = 250.00 (mm)
 . -1.00 (kN) M = 0.00 (kN*m)

V = 0.00 (kN) H =

- **5. Results (soils)**

.
 . PRESSURES
 .

Factors for pressures and passive pressures for soils:

Average backfill slope angle $\varepsilon = 0.00$ (Deg)

Wall inclination angle $\beta = 0.00$ (Deg)

$$K_a = \frac{\cos^2 \cdot (\beta - \phi)}{\cos^2 \beta \cdot \cos(\beta + \delta_2) \cdot \left(1 + \sqrt{\frac{\sin(\phi + \delta_2) \cdot \sin(\phi - \varepsilon)}{\cos(\beta + \delta_2) \cdot \cos(\beta - \varepsilon)}} \right)^2}$$

$$K_p = \frac{\cos^2 \cdot (\beta + \phi)}{\cos^2 \beta \cdot \cos(\beta + \delta_2) \cdot \left(1 - \sqrt{\frac{\sin(\phi - \delta_2) \cdot \sin(\phi + \varepsilon)}{\cos(\beta + \delta_2) \cdot \cos(\beta - \varepsilon)}} \right)^2}$$

$$K_o = \frac{\sigma_x}{\sigma_z} = \frac{\nu}{1 - \nu}$$

$$K_a \leq K_o \leq K_p$$

Soils (behind the wall):

No.	Soil name	Level [mm]	Friction angle [Deg]	Ka	Ko	Kp
1.	silty fine sands	500.00	18.00	0.483	0.691	2.190

- Generalized limit displacements

· passive pressure 0.134

· pressure 0.013

· Soils (before the wall):

No.	Soil name	Level [mm]	Friction angle [Deg]	Ka	Ko	Kp
1.	poorly graded sands	0.00	37.00	0.528	0.691	1.894
2.	poorly graded sands	500.00	37.00	0.249	0.398	4.023
3.	poorly graded sands	4400.00	37.00	1.000	1.000	1.000

- Generalized limit displacements

· passive pressure 0.131

· pressure 0.013

CAPACITY

- Soil type under footing: not layered
- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot C + 1.000 \cdot W + 1.300 \cdot a1$
- Reduced design load:
 $N = -88.33$ (kN/m) $My = -6.91$ (kN*m) $Fx = 178.20$ (kN/m)
- Equivalent footing dimension: $A = 2826.15$ (mm)
- Coefficient of load capacity and influence of load inclination:

$$N_B = 0.745 \quad i_B = 0.059$$

$$N_C = 11.768 \quad i_C = 0.266$$

$$N_D = 4.419 \quad i_D = 0.442$$

- Soil limit pressure: $Q_f = 615.99$ (kN/m)
- Safety factor: $Q_f \cdot m / N_r = 5.649 > 2.000$

SETTLEMENT

- Soil type under foundation: not layered
- Design combination: $1.000 \cdot PM + 1.000 \cdot P'a + 1.000 \cdot Pa + 1.000 \cdot C + 1.000 \cdot W + 1.000 \cdot a1$
- Reduced design load:
 $N = -88.33 \text{ (kN/m)}$ $My = -5.23 \text{ (kN*m)}$ $Fx = 178.50 \text{ (kN/m)}$
- Unit load of total loads: $q = 0.02 \text{ (MN/m}^2\text{)}$
- Thickness of the actively settling soil: $z = 1000.00 \text{ (mm)}$
- Stress on the level z :
 - additional: $szd = 0.01 \text{ (MN/m}^2\text{)}$
 - caused by soil weight: $szg = 0.03 \text{ (MN/m}^2\text{)}$
- Settlement: $S = 0.22 \text{ (mm)} < S_{dop} = 100.00 \text{ (mm)}$

OVERTURNING

- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot C + 1.000 \cdot W$
- Reduced design load:
 $N = -88.33 \text{ (kN/m)}$ $My = -1.51 \text{ (kN*m)}$ $Fx = 176.90 \text{ (kN/m)}$
- Overturning moment: $Mo = 200.39 \text{ (kN*m)}$
- Moment preventing foundation overturning: $M_{uf} = 511.16 \text{ (kN*m)}$
- Safety factor: $M_{uf} \cdot m / M_o = 1.837 < 2.000$

SLIDING

- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot C + 1.000 \cdot W$
- Reduced design load:
 $N = -88.33 \text{ (kN/m)}$ $My = -1.51 \text{ (kN*m)}$ $Fx = 176.90 \text{ (kN/m)}$
- Equivalent footing dimension: $A = 5000.00 \text{ (mm)}$
- Friction coefficient:
 - of soil (on the settlement level): $\mu = 0.039$
- Soil cohesion reduction factor = 100.000 %
- Cohesion: $C = 60.33 \text{ (kN/m}^2\text{)}$
- Sliding force value: $Q_{tr} = 176.90 \text{ (kN/m)}$
- Value of force preventing wall sliding:
 - $Q_{tf} = N \cdot \mu + C \cdot A$
 - - on the foundation level: $Q_{tf} = 305.06 \text{ (kN/m)}$
- Safety factor: $Q_{tf} \cdot m / Q_{tr} = 1.725 < 2.000$

SLIDING


- Soil type under foundation: not layered
- Design combination: $1.000 \cdot PM + 1.000 \cdot P'a + 1.000 \cdot Pa + 1.000 \cdot C + 1.000 \cdot W + 1.000 \cdot a1$
- Thickness of soil cooperating with foundation: $z = 2282.84 \text{ (mm)}$
- Wedge length: $la = 707.11 \text{ (mm)}$
- Sliding:
 - $f_0 = -21.04 \text{ (mm)}$
 - $f_1 = -5.59 \text{ (mm)}$
 - $f_2 = -1.57 \text{ (mm)}$
 - $f_3 = -13.88 \text{ (mm)}$
- Safety factor:
 - $3.493 > 1.000$

OVERTURNING ANGLES

- Soil type under foundation: not layered
- Design combination: $1.000*PM + 1.000*P'a + 1.000*Pa + 1.000*C + 1.000*W + 1.000*a1$
- Reduced design load:
 $N=-88.33$ (kN/m) $My=-5.23$ (kN*m) $Fx=178.50$ (kN/m)
- Maximum unit stresses from total loads:
 $q_{max} = 0.04$ (MN/m²)
- Minimum unit stresses from total loads:
 $q_{min} = 0.00$ (MN/m²)
- Overturning angle: $\theta = -0.02$ (Deg)
- Coordinates of wall rotation point:
 $X = 709.12$ (mm)
 $Z = 0.00$ (mm)
- Safety factor: $36.280 > 2.000$

6. Results of RC design

- Moments



(kN*m)

Element	Moments	Value [kN*m]	Position [mm]	Combination
Wall	maximum	0.00	4650.00	$1.100*PM + 1.100*P'a + 1.320*Pa + 1.100*C + 1.000*W + 1.300*a1$
Wall	minimum	-102.38	500.00	$1.100*PM + 1.100*P'a + 1.320*Pa + 1.100*C + 1.000*W + 1.300*a1$
Footing	maximum	78.43	2700.00	$1.100*PM + 0.765*P'a + 0.900*Pa + 0.900*C + 1.000*W + 1.300*a1$
Footing	minimum	-31.08	2300.00	$0.900*PM + 0.765*P'a + 0.900*Pa + 0.900*C + 1.000*W + 1.300*a1$

1. Calculation parameters for retaining walls on gridlines C & D:


MATERIAL:

- **CONCRETE:** class B 30, fck = 30.00 (MN/m²),
unit weight = 24.00 (kN/m³)
- **STEEL:** class A - III, fyk = 450.00 (MN/m²)

OPTIONS:

- Calculations according to: concrete code: **PN-B-03264(2002)**
soil code: **PN-83/B-03010**
- Cover: c1 = 50.0 (mm), c2 = 50.0 (mm)
- Exposure: X0
- Retainig wall design according to:
 - Capacity m = 0.810 g = 2.000
 - Sliding m = 0.720 g = 2.000
 - Overturning m = 0.720 g = 2.000
- Retainig wall verification according to:
 - Average settlement:
S_{dop} = 100.00 (mm)
 - Settlement differences:
DS_{dop} = 50.00 (mm)
- Reduction factors for:
 - - Soil cohesion 100.000 %
 - - Soil frictions 0.000 %
 - - Wall passive pressure 50.000 %
 - Key passive pressure 100.000 %
- Wall/soil friction angle:
 - - Passive pressure for cohesive soils -1/3×φ
 - - Cohesive soil pressure 1/2×φ
 - - Passive pressure for non-cohesive soils -1/3×φ
 - - Pressure for non-cohesive soils 1/2×φ

2. Geometry:



3. Soil:


- **Soil parameter selection - method: B**
- **Backfill** Soil depth (behind the wall) $H_o = 3000.00$ (mm)
- **Original layers:**

Description:

No.	Soil name	Level [mm]	Thickness [mm]	Consolidation type	Moisture type	I_p/I_L
1.	clayey fine sands	500.00	-	-	-	0.000

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1.	67.03	18.00	21.21	29.65	29.65



- **Soils (behind the wall):**

Description:

No.	Soil name	Level* [mm]	Thickness [mm]	Consolidation type	Moisture type	I _D /I _L
1	well graded gravels	500.00	500.00	-	-	0.000

* With respect to the lower right footing point

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1	0.00	42.00	21.99	199.50	199.50

- **Soils (before the wall):**


Description:

No.	Soil name	Level* [mm]	Thickness [mm]	Consolidation type	Moisture type	I _D /I _L
1	well graded gravels	500.00	500.00	-	-	0.000


* With respect to the lower left footing point

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1	0.00	42.00	21.99	199.50	199.50



4. Loads



- **Load report**

1 concentrated on wall

a1 live z = 0.00 (mm)
H = 1.00 (kN) M = 0.00 (kN*m)

V = 0.00 (kN)

5. Results (soils)

PRESSURES

Soil pressure and passive pressure : according to wall displacements
Factors for pressures and passive pressures for soils:

Average backfill slope angle $\epsilon = 0.00$ (Deg)

Wall inclination angle $\beta = 0.00$ (Deg)

$$K_a = \frac{\cos^2 \cdot (\beta - \phi)}{\cos^2 \beta \cdot \cos(\beta + \delta_2) \cdot \left(1 + \sqrt{\frac{\sin(\phi + \delta_2) \cdot \sin(\phi - \epsilon)}{\cos(\beta + \delta_2) \cdot \cos(\beta - \epsilon)}} \right)^2}$$

$$K_p = \frac{\cos^2 \cdot (\beta + \phi)}{\cos^2 \beta \cdot \cos(\beta + \delta_2) \cdot \left(1 - \sqrt{\frac{\sin(\phi - \delta_2) \cdot \sin(\phi + \epsilon)}{\cos(\beta + \delta_2) \cdot \cos(\beta - \epsilon)}} \right)^2}$$

$$K_o = \frac{\sigma_x}{\sigma_z} = \frac{\nu}{1 - \nu}$$

$$K_a \leq K_o \leq K_p$$

Soils (behind the wall):

No.	Soil name	Level [mm]	Friction angle [Deg]	Ka	Ko	Kp
1	wall graded gravel	500.00	12.00	0.189	0.221	0.560

- Generalized limit displacements
 - passive pressure 0.132
 - pressure 0.013

Soils (before the wall):

	Soil name	Level [mm]	Friction angle [Deg]	Ka	Ko	Kp
1.	well graded gravels	0.00	42.00	0.528	0.691	1.894
2.	well graded gravels	500.00	42.00	0.198	0.331	5.045
3.	well graded gravels	3150.00	42.00	1.000	1.000	1.000

- Generalized limit displacements
 - passive pressure 0.131
 - pressure 0.013

CAPACITY

- Soil type under footing: not layered
- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 - $N = -77.45$ (kN/m) $My = 5.05$ (kN*m) $Fx = 68.94$ (kN/m)
- Equivalent footing dimension: $A = 4240.24$ (mm)
- Coefficient of load capacity and influence of load inclination:

$$\begin{array}{ll}
 N_B = 0.745 & i_B = 0.059 \\
 N_C = 11.768 & i_C = 0.266 \\
 N_D = 4.419 & i_D = 0.442
 \end{array}$$

- Soil limit pressure: $Q_f = 953.64$ (kN/m)
- Safety factor: $Q_f \cdot m / N_r = 9.974 > 2.000$

SETTLEMENT

- Soil type under foundation: not layered
- Design combination: $1.000 \cdot PM + 1.000 \cdot P'a + 1.000 \cdot Pa + 1.000 \cdot W + 1.000 \cdot a1$
- Reduced design load:
 - $N = -77.06$ (kN/m) $My = 9.03$ (kN*m) $Fx = 69.00$ (kN/m)
- Unit load of total loads: $q = 0.02$ (MN/m²)
- Thickness of the actively settling soil: $z = 1000.00$ (mm)
- Stress on the level z:
 - additional: $szd = -0.00$ (MN/m²)
 - caused by soil weight: $szg = 0.04$ (MN/m²)
- Settlement: $S = 0.00$ (mm) $< S_{dop} = 100.00$ (mm)

OVERTURNING

- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 - $N = -77.45$ (kN/m) $My = 5.05$ (kN*m) $Fx = 68.94$ (kN/m)
- Overturning moment: $Mo = 139.81$ (kN*m)
- Moment preventing foundation overturning: $M_{uf} = 362.85$ (kN*m)
- Safety factor: $M_{uf} \cdot m / M_0 = 1.869 < 2.000$

PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	CV	
	Project:	Kusile Power Station	Component:	Internal walls	Date:	18/06/2009
	Job no.:	5452/35	File no.:	5452	Checked by:	KG & ARG
	Title:	SDD SETTLING TANK		Date:	29/06/2009	
	Structural design calculations and reports				Page:	22 of 24

SLIDING


- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -77.45 \text{ (kN/m)}$ $My = 5.05 \text{ (kN}\cdot\text{m)}$ $Fx = 68.94 \text{ (kN/m)}$
- Equivalent footing dimension: $A = 5000.00 \text{ (mm)}$
- Friction coefficient:
- of soil (on the settlement level): $\mu = 0.058$
- Soil cohesion reduction factor = 100.000 %
- Cohesion: $C = 12.05 \text{ (kN/m}^2\text{)}$
- Sliding force value: $Q_{tr} = 68.94 \text{ (kN/m)}$
- Value of force preventing wall sliding:
 $Q_{tf} = N \cdot \mu + C \cdot A$
- - on the foundation level: $Q_{tf} = 64.76 \text{ (kN/m)}$
- Safety factor: $Q_{tf} \cdot m / Q_{tr} = 0.676 < 2.000$

OVERTURNING ANGLES

- Soil type under foundation: not layered
- Design combination: $1.000 \cdot PM + 1.000 \cdot P'a + 1.000 \cdot Pa + 1.000 \cdot W$
- Reduced design load:
 $N = -77.07 \text{ (kN/m)}$ $My = 6.33 \text{ (kN}\cdot\text{m)}$ $Fx = 69.96 \text{ (kN/m)}$
- Maximum unit stresses from total loads:
 $q_{max} = 0.02 \text{ (MN/m}^2\text{)}$
- Minimum unit stresses from total loads:
 $q_{min} = 0.01 \text{ (MN/m}^2\text{)}$
- Overturning angle: $\theta = -0.01 \text{ (Deg)}$
- Coordinates of wall rotation point:
 $X = -3104.26 \text{ (mm)}$
 $Z = 0.00 \text{ (mm)}$
- Safety factor: $109.823 > 2.000$

6. Results of RC design


- Moments



(kN*m)

Element	Moments	Value [kN*m]	Position [mm]	Combination
Wall	maximum	0.45	2635.18	1.100*PM + 1.100*P'a + 1.320*Pa + 1.000*W + 1.300*a1
Wall	minimum	-30.43	500.00	1.100*PM + 1.100*P'a + 1.320*Pa + 1.000*W
Footing	maximum	36.77	2700.00	1.100*PM + 1.100*P'a + 1.320*Pa + 1.000*W
Footing	minimum	-5.09	2300.00	0.900*PM + 1.100*P'a + 1.320*Pa + 1.000*W

- Reinforcement



(cm2/m)

Position	Required reinf. area [cm2/m]	Bars		Spacing [mm]	Provided reinf. area [cm2/m]
wall from the left	7.14	12.0	every	150.00	7.54
wall from the left (h/3)	7.14	12.0	every	150.00	7.54
wall from the left (h/2)	7.14	12.0	every	150.00	7.54
wall from the right	7.14	12.0	every	150.00	7.54
left footing (+)	8.21	16.0	every	200.00	10.05
left footing (-)	8.21	16.0	every	200.00	10.05
right footing (-)	8.21	16.0	every	200.00	10.05
right footing (+)	0.00	16.0	every	200.00	10.05

PANEL B	Client:	ESKOM	Computed by:	CV
CONSULTANTS	Project:	Kusile Power Station	Component:	Internal walls
JOINT	Job no.:	5452/35	File no.:	5452
VENTURE	Title:	SDD SETTLING TANK	Checked by:	KG & ARG
		Structural design calculations and reports	Date:	29/06/2009
			Page:	24 of 24

APPENDIX B

AUTODESK ROBOT STRUCTURES 2010 VERIFICATION

CONCRETE


1. BS 9/1/96 – RC columns

VERIFICATION EXAMPLE 1 - Column subjected to axial load and biaxial bending

DESCRIPTION OF THE EXAMPLE:

Following example illustrates the procedure of dimensioning of biaxial bending of column, which is non-sway in one direction, whereas sway in the other. The results of the program are accompanied by the „manual” calculations.

1. SECTION DIMENSIONS



2. MATERIALS

Concrete	: C20	$f_{cu} = 20.00$ (MPa)
Longitudinal reinforcement	: T	$f_y = 460.00$ (MPa)
Transversal reinforcement	: R	$f_y = 250.00$ (MPa)

3. BUCKLING MODEL

Direction Y

Off

Structure

Non-sway

Sway

$L_{oy} =$ m

$\beta_y =$

Direction Z

Off

Structure

Non-sway

Sway

$L_{oz} =$ m

$\beta_z =$

As can be seen the sway column is assumed for Z direction, and the non-sway column for Y direction.


4. LOADS

No.	Case	Nature	Group	H (kH)	MyA (kH'm)	MyB (kH'm)	MyC (kH'm)	MzA (kH'm)	MzB (kH'm)	MzC (kH'm)	γ
1	DL1	dead load	1	400.00	150.00	30.00	102.00	20.00	30.00	50.00	1.40
2	LL1	Live	1	150.00	120.00	30.00	84.00	10.00	20.00	40.00	1.60
*											

NOTE: Let us assume, the moments in Y direction are linearly distributed along the height of the column. Thus, we define only the ends' moments for Y direction. In Z direction however, we assume the mid-height moment is not a result of the linear distribution. For such a case, Robot let the user define the moments in the mid-section explicitly.

5. CALCULATED REINFORCEMENT:

Program generates the reinforcement 14 ϕ 20.




6. RESULTS OF THE SECTION CALCULATIONS:

The dimensioning combination is 1.4DL1+1.6LL1

The dimensioning section (where the most unfavorable set of forces is found) is for that combination the section in the mid-height of the column (marked as (C)).

Intersection			
Load types <input checked="" type="radio"/> Basic <input type="radio"/> Accidental			
Description	H (kN)	My (kN*m)	Mz (kN*m)
1.40DL1+1.60LL1 (A)	800.00	423.33	71.04
1.40DL1+1.60LL1 (C)	800.00	319.87	161.04
1.40DL1+1.60LL1 (B)	800.00	111.33	101.04
1.40DL1 (A)	560.00	224.93	46.93
1.40DL1 (C)	560.00	172.67	88.93
1.40DL1 (B)	560.00	56.93	60.93
1.00DL1+1.60LL1 (A)	640.00	359.07	57.63
1.00DL1+1.60LL1 (C)	640.00	270.53	135.63
1.00DL1+1.60LL1 (B)	640.00	95.07	83.63

Rd / Sd	1.00	<	1.05
MRd / MSd	1.00	<	1.05
NRd / NSd	1.00	<	1.76



Since the column is found as slender, in both direction the second-order effects are taken into account.

In parallel the other sections (at the ends of the column) are checked for all combinations of loads. All the results of total forces for each combination and each section of the column may be seen in the table "Intersection" at the Column-results layout.

7. CALCULATIONS OF TOTAL MOMENT:

7.1. LOADS

For the dimensioning combination, the loads are:

	Case	N (kN)	MyA (kN*m)	MyB (kN*m)	MyC (kN*m)	MzA (kN*m)	MzB (kN*m)	MzC (kN*m)
1	DL1	400	150	30	102	20	30	50*
2	LL1	150	120	30	84	10	20	40*
Dimensioning combination	1.4DL1+1.6LL1	800	402	90	277.2	44	74	134

, where A, B and C denote upper, lower and mid-height sections of the column respectively.

* - the values are written "by hand" by the user (see point 4 – Loads)

7.2. THE INFLUENCE OF SLENDERNESS

Two independent calculations of the total moment for both directions are carried out.

Slenderness analysis acc. to 3.8.1.3:

$$l_{ey} / h = 13.33 < 15 \text{ (non-sway for Y direction)}$$

$$l_{ez} / b = 13.0 > 10 \text{ (sway for Z direction)}$$

Since the ratio l_{ez} / b exceeds the limit, the column is found as **slender**.

Y DIRECTION

Calculation of minimum eccentricity e_{min} and minimum moment M_{min} – 3.8.2.4

$$e_{min} = \min(0.05 \cdot h; 0.02m) = 0.02 \text{ (m)}$$

$$M_{min} = N \cdot e_{min} = 16.0 \text{ (kNm)}$$

Calculation of initial moment M_i – eq. 36

For the mid-height section, we have:

$$M_i = 0.4 \cdot M_1 + 0.6 \cdot M_2 = 277.2 \text{ (kNm)} > 0.4 \cdot M_2 = 160.8 \text{ (kNm)}$$

Calculation of second-order eccentricity a_u – eq. 32

$$a_u = \beta_a K h = 0.053 \text{ (m)}$$

$$\beta_a = \frac{1}{2000} \left(\frac{l_e}{h} \right) = 0.088$$

$$K = \min \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}}; 1 \right)$$

$$N_{uz} = \frac{2}{3} \frac{f_{cu}}{\gamma_c} A_c + \frac{f_y}{\gamma_s} A_{sc} = 4060.18 \text{ (kN)}$$

$$A_c = 0.24 \text{ (m}^2\text{)}$$

$$A_{sc} = 43.98 \text{ (cm}^2\text{)}$$

$N_{bal} = 1222.64 \text{ (kN)}$ – note that this value is calculated in detail for the state equilibrium in a section. Using the approximated code formula one would obtain

$$N_{bal} = 1173.33 \text{ (kN)}$$

$$K = \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}} \right) = \quad - \text{ thus, } K = 1 \text{ was assumed}$$

Calculation of second-order moment M_{add}

$$M_{add} = N \cdot a_u = 42.67 \text{ (kNm)}$$

NOTE: The second-order effects in Robot are taken into account dependent upon the section and upon the parameter sway/non sway in a following way:

- in non-sway structures, M_{add} is added for the mid-height section, while $0.5 M_{add}$ is added for the end sections. Such addition is carried out disregarding the distribution of the first-order moment.
- in sway structures, M_{add} is added to each of three sections of column. Such addition is carried out disregarding the distribution of the first-order moment.

The total moment M_y :

$$M_y = M_i + M_{add} = 319.87 \text{ (kNm)} > 16.00 \text{ (kNm)} = M_{min}$$

Z DIRECTION

Calculation of minimum eccentricity e_{min} and minimum moment M_{min} – 3.8.2.4

$$e_{min} = \min(0.05 \cdot b; 0.02m) = 0.02 \text{ (m)}$$

$$M_{min} = N \cdot e_{min} = 16.0 \text{ (kNm)}$$

Calculation of initial moment M_i – eq. 36

For the mid-height section, we have the moment fixed directly by the user:

$$M_i = 134 \text{ (kNm)}$$

Calculation of second-order eccentricity a_u – eq. 32

$$a_u = \beta_a K h = 0.034 \text{ (m)}$$

$$\beta_a = \frac{1}{2000} \left(\frac{l_e}{b} \right) = 0.0845$$

$$K = \min \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}}; 1 \right)$$

$$N_{uz} = \frac{2}{3} \frac{f_{cu}}{\gamma_c} A_c + \frac{f_y}{\gamma_s} A_{sc} = 4060.18 \text{ (kN)}$$

$$A_c = 0.24 \text{ (m}^2\text{)}$$

$$A_{sc} = 43.98 \text{ (cm}^2\text{)}$$

$N_{bal} = 1222.64 \text{ (kN)}$ – note that this value is calculated in detail for the state equilibrium in a section. Using the approximated code formula one would obtain

$$N_{bal} = 1173.33 \text{ (kN)}$$

$$K = \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}} \right) = \quad - \text{ thus, } K = 1 \text{ was assumed}$$

Calculation of second-order moment M_{add}

$$M_{add} = N \cdot a_u = 27.04 \text{ (kNm)}$$

NOTE: The second-order effects in Robot are taken into account dependent upon the section and upon the parameter sway/non sway in a following way:

- in non-sway structures, M_{add} is added for the mid-height section, while $0.5 M_{add}$ is added for the end sections. Such addition is carried out disregarding the distribution of the first-order moment.

- in sway structures, M_{add} is added to each of three sections of column. Such addition is carried out disregarding the distribution of the first-order moment.

The total moment M_z :

$$M_z = M_i + M_{add} = 161.04 \text{ (kNm)} > 16.00 \text{ (kNm)} = M_{\min}$$

7.3. FINAL RESULT

$$M_y = 320 \text{ (kNm)}$$

$$M_z = 161 \text{ (kNm)}$$

8. CONCLUSIONS

The algorithm of calculations of the total moments (i.e. slenderness effects) in non-sway/sway column has been presented. The results obtained with the program (see point 6 – Results of the Section Calculations) are in agreement with the manual calculations (see point 7.3 – Final Result)

LITERATURE

[1] British Standard BS 8110: 1985. Structural use of concrete. British Standard Institution, 1985.

PANEL B CONSULTANTS JOINT VENTURE Calculation Record

Client Name: ESKOM **Page:** 1 **of** 18
Project Name: Kusile Power Station **Job No:** K5452-038
Calculation Title: SDD Inlet Baffle Wall
Calculation No./File No.: K5452-038 R1b (REPORT 3 OF 3)
Calculation is: Preliminary Final
Objective: Determine required reinforcement areas for ULS & SLS

Unverified assumptions requiring subsequent verification			
No.	Assumption	Verified by	Date
1	Fluid density – 10kN/m ³	KG	16/07/2009
2	Soil pressure (see “Annexure A”)	KG	16/07/2009
3	Founding on non-yielding material	KG	16/07/2009

See page ____ of this calculation for additional assumptions.

This section applies to computer generated calculations	
Program Name/Number:	Autodesk Robot Structural Analysis 2010 Version: V23.0.1.3128
Program Name/Number:	Autodesk Revit Structure 2010 Version: V2010
Evidence of or reference to computer program verification, if applicable: See “Annexure B”	
Bases or reference thereto supporting application of the computer program to the physical problem: Autodesk Expert Retaining Wall 2010 – ver 23.0	

Review and approval						
Rev	Prepared by	Date	Verified by	Date	Approved by	Date
1	C Vorster	17/07/09	AR Gorman PrEng	20/07/09	K Georgala PrEng	20/07/2009

1. PURPOSE:

Determination of structure dimensions and required reinforcement under specified load.

2. REFERENCES:

	1. Concrete layout drawing	K5406-038	Rev	P1
	2.		Rev	


3. LOAD CASES AND COMBINATIONS

Load Cases:

1. Own Weight
2. Live load
3. Water load

4. APPLICATIONS:

STRUCTURE



Required reinforcement:


Position	Required reinf. area [cm ² /m]	Bars		Spacing [mm]	Provided reinf. area [cm ² /m]
wall from the left	7.14	10.0	every	100.00	7.85
wall from the left (h/3)	7.14	12.0	every	150.00	7.54
wall from the left (h/2)	7.14	12.0	every	150.00	7.54
wall from the right	7.14	10.0	every	100.00	7.85
shelf 1 (+)	7.14	10.0	every	100.00	7.85
left footing (-)	8.21	12.0	every	130.00	8.70
right footing (+)	8.21	12.0	every	130.00	8.70
left footing (+)	0.00	12.0	every	130.00	8.70

Note:

Due to openings in the wall, reinforcement is suggested as displayed in figures 1 to 5 as indicated below, with the addition of ground beams for stability of wall.

PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	CV	
	Project:	Kusile Power Station	Component:	SDD Settling Dam	Date:	16/07/2009
	Job no.:	5452/38	File no.:	5452	Checked by:	KG & ARG
	Title:	SDD Inlet baffle wall design		Date:	16/07/2009	
	Structural design calculations and reports				Page:	4 of 18

Figure 1 – Front elevation of baffle wall:



Note:
Y20 bars to lap 1200mm MIN

Figure 2 – Typical section of baffle wall:





Figure 3 – Positions of ground beams:

**PANEL B
CONSULTANTS
JOINT
VENTURE**

Client: ESKOM
Project: Kusile Power Station Component: SDD Settling
Job no.: 5452/38 File no.: 5452
Title: SDD Inlet baffle wall design
Structural design calculations and reports

Computed by: CV
Date: 16/07/2009
Checked by: KG & ARG
Date: 16/07/2009
Page: 6 of 18



PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	CV	
	Project:	Kusile Power Station	Component:	SDD Settling Dam	Date:	16/07/2009
	Job no.:	5452/38	File no.:	5452	Checked by:	KG & ARG
	Title:	SDD Inlet baffle wall design		Date:	16/07/2009	
	Structural design calculations and reports				Page:	7 of 18

Figure 4 – Typical sections of ground beams (sizes):





Figure 5 – Typical sections of ground beams (reinforcement layout):







Figure 8 – Sections on walkway slab:



PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	CV	
	Project:	Kusile Power Station	Component:	SDD Settling Dam	Date:	16/07/2009
	Job no.:	5452/38	File no.:	5452	Checked by:	KG & ARG
	Title:	SDD Inlet baffle wall design		Date:		16/07/2009
			Structural design calculations and reports		Page: 9 of 18	

5. PROCEDURE/METHODOLOGY OF DESIGN:

- 5.1 The finite element design method has been applied for this analysis
- 5.2 3 Load cases and 2 Load combinations have been analyzed, as indicated in "Annexure A"

6. ASSUMPTIONS:

- 6.1 Assumptions requiring verification will be listed on the cover sheet

7. DEFINITION OF UNITS AND CONSTANTS:

Refer to "Annexure A"

8. ANALYSIS/SOLUTION: (see body of calculation for analysis and solutions)

Note: Detailed calculations output data to be provided on request.

9. METHOD OF RESULTS GENERATION:

All loads and load combinations are defined as load cases within Robot Structural Analysis, combinations have the addition of factors applied as explained on page 9-16 of this document, and are governed by ULS or SLS criteria.

The results displayed in this document, represents the worst cases of all possible cases, where each case has been analyzed individually as well as specified in combination cases.

10. APPENDICES TO CALCULATIONS:

- 10.1 Appendix A – Calculations
- 10.2 Appendix B – Autodesk Robot Structural Analysis 2010 verification report


PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	CV	
	Project:	Kusile Power Station	Component:	SDD Settling Dam	Date:	16/07/2009
	Job no.:	5452/38	File no.:	5452	Checked by:	KG & ARG
	Title:	SDD Inlet baffle wall design		Date:	16/07/2009	
		Structural design calculations and reports		Page:	10 of 18	

APPENDIX A

CALCULATIONS

8.1.1 SDD Baffle Wall Design

STRUCTURE VIEW



1. Calculation parameters:


MATERIAL:

- **CONCRETE:** class B 30, $f_{ck} = 30.00$ (MN/m²),
unit weight = 24.00 (kN/m³)
- **STEEL:** class A - III, $f_{yk} = 450.00$ (MN/m²)

OPTIONS:

- Calculations according to: concrete code: **PN-B-03264(2002)**
soil code: **PN-83/B-03010**
- Cover: $c_1 = 50.0$ (mm), $c_2 = 50.0$ (mm)
- Exposure: X0
- Retainig wall design according to:
 - Capacity $m = 0.810$
 - Sliding $m = 0.720$
 - Overturning $m = 0.720$
- Retainig wall verification according to:
 - Average settlement:
 $S_{dop} = 100.00$ (mm)
 - Settlement differences:
 $DS_{dop} = 50.00$ (mm)
- Wall/soil friction angle:
 - Passive pressure for cohesive soils $-1/3 \times \phi$
 - Cohesive soil pressure $1/2 \times \phi$
 - Passive pressure for non-cohesive soils $-1/3 \times \phi$
 - Pressure for non-cohesive soils $1/2 \times \phi$

2. Geometry:



3. Soil:


- Soil parameter selection - method: B
- Backfill Soil depth (behind the wall) $H_o = 6200.00$ (mm)
- Original layers:

Description:

No.	Soil name	Level [mm]	Thickness [mm]	Consolidation type	Moisture type	I_p/I_L
1.	clayey fine sands	0.00	-	-	-	0.000

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1.	67.03	18.00	21.21	29.65	29.65



Soils (behind the wall):

Description:

No.	Soil name	Level* [mm]	Thickness [mm]	Consolidation type	Moisture type	I _D /I _L
1	well graded gravel - sand mixtures	500.00	500.00	-	-	0.000

* With respect to the lower right footing point

Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1	0.00	38.00	21.99	199.50	199.50

• **Soils (before the wall):**

Description:


No.	Soil name	Level* [mm]	Thickness [mm]	Consolidation type	Moisture type	I _D /I _L
1	well graded gravel - sand mixtures	500.00	500.00	-	-	0.000

* With respect to the lower left footing point


Parameters:

No.	Cohesion [kN/m ²]	Friction angle [Deg]	Unit weight [kN/m ³]	M [MN/m ²]	Mo [MN/m ²]
1	0.00	38.00	21.99	199.50	199.50

(mm)



4. Loads



- **Load report**

.
 . 1 distributed
 . a1 live x1 = 0.00 (m) x2 = 1.00 (m) P =
 . -3.00 (kN/m2)

- **5. Results (soils)**

• **PRESSURES**

•
 Soil pressure and passive pressure : static
 Factors for pressures and passive pressures for soils:

Average backfill slope angle $\epsilon = 0.00$ (Deg)
 Wall inclination angle $\beta = 0.00$ (Deg)

$$K_a = \frac{\cos^2 \cdot (\beta - \phi)}{\cos^2 \beta \cdot \cos(\beta + \delta_2) \cdot \left(1 + \sqrt{\frac{\sin(\phi + \delta_2) \cdot \sin(\phi - \epsilon)}{\cos(\beta + \delta_2) \cdot \cos(\beta - \epsilon)}} \right)^2}$$

$$K_p = \frac{\cos^2 \cdot (\beta + \phi)}{\cos^2 \beta \cdot \cos(\beta + \delta_2) \cdot \left(1 - \sqrt{\frac{\sin(\phi - \delta_2) \cdot \sin(\phi + \epsilon)}{\cos(\beta + \delta_2) \cdot \cos(\beta - \epsilon)}} \right)^2}$$

$$K_o = \frac{\sigma_x}{\sigma_z} = \frac{\nu}{1 - \nu}$$

$$K_a \leq K_o \leq K_p$$

Soils (behind the wall):

No.	Soil name	Level [mm]	Friction angle [Deg]	Ka	Ko	Kp
1.	well graded gravel - sand mixtures	500.00	38.00	0.238	0.384	4.204
2.		3000.00		1.000	1.000	1.000

- Generalized limit displacements
- passive pressure 0.132
- pressure 0.013
- Soils (before the wall):

No.	Soil name	Level [mm]	Friction angle [Deg]	Ka	Ko	Kp
1.	well graded gravel - sand mixtures	500.00	38.00	0.217	0.384	7.007

- Generalized limit displacements
- passive pressure 0.132
- pressure 0.013

Simple cases

No.	Case	x (m)	y (m)	Px (kN/m)	Py (kN/m)	Description
1.	PM	0.75	1.66	0.00	-78.48	Self-weight of a retaining wall
2.	P'a	0.00	0.17	1.03	0.23	Soil pressure (before the wall)
3.	Pa	0.46	0.17	-0.67	0.00	Soil pressure (behind the wall)
4.	W	0.60	1.00	-44.15	7.36	Hydrostatic pressure
5.	a1	0.46	1.61	0.00	0.00	Live load

CAPACITY

- Soil type under footing: not layered
- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W + 1.200 \cdot a1$
- Reduced design load:
 $N = -70.93 \text{ (kN/m)}$ $My = 17.44 \text{ (kN}\cdot\text{m)}$ $Fx = -44.07 \text{ (kN/m)}$
- Equivalent footing dimension: $A = 286.76 \text{ (mm)}$
- Coefficient of load capacity and influence of load inclination:

$$N_B = 0.745 \quad i_B = 0.059$$

$$N_C = 11.768 \quad i_C = 0.266$$

$$N_D = 4.419 \quad i_D = 0.442$$

- Soil limit pressure: $Q_f = 59.67 \text{ (kN/m)}$
- Safety factor: $Q_f \cdot m / N_r = Q_f \cdot m / N_r = 0.682 < 1.000$

SETTLEMENT

- Soil type under foundation: not layered
- Design combination: $1.000 \cdot PM + 1.000 \cdot P'a + 1.000 \cdot Pa + 1.000 \cdot W + 1.000 \cdot a1$
- Reduced design load:
 $N = -70.89 \text{ (kN/m)}$ $My = 17.52 \text{ (kN}\cdot\text{m)}$ $Fx = -43.78 \text{ (kN/m)}$
- Unit load of total loads: $q = 0.16 \text{ (MN/m}^2\text{)}$
- Thickness of the actively settling soil: $z = 3000.00 \text{ (mm)}$
- Stress on the level z:
 - additional: $szd = 0.01 \text{ (MN/m}^2\text{)}$
 - caused by soil weight: $szg = 0.06 \text{ (MN/m}^2\text{)}$

PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	CV	
	Project:	Kusile Power Station	Component:	SDD Settling Dam	Date:	16/07/2009
	Job no.:	5452/38	File no.:	5452	Checked by:	KG & ARG
	Title:	SDD Inlet baffle wall design			Date:	16/07/2009
	Structural design calculations and reports			Page:	16 of 18	

- Settlement: $S = 5.04 \text{ (mm)} < S_{dop} = 100.00 \text{ (mm)}$

OVERTURNING

- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W + 1.200 \cdot a1$
- Reduced design load:
 $N = -70.93 \text{ (kN/m)} \quad M_y = 17.44 \text{ (kN} \cdot \text{m)} \quad F_x = -44.07 \text{ (kN/m)}$
- Overturning moment: $M_o = 66.35 \text{ (kN} \cdot \text{m)}$
- Moment preventing foundation overturning: $M_{uf} = 76.52 \text{ (kN} \cdot \text{m)}$
- Safety factor: $M_{uf} \cdot m / M_o = 0.830 < 1.000$

SLIDING


- Design combination: $1.000 \cdot PM + 0.850 \cdot P'a + 1.200 \cdot Pa + 1.000 \cdot W + 1.200 \cdot a1$
- Reduced design load:
 $N = -70.93 \text{ (kN/m)} \quad M_y = 17.44 \text{ (kN} \cdot \text{m)} \quad F_x = -44.07 \text{ (kN/m)}$
- Equivalent footing dimension: $A = 1500.00 \text{ (mm)}$
- Friction coefficient:
- of soil (on the settlement level): $\mu = 0.000$
- Soil cohesion reduction factor = 100.000 %
- Cohesion: $C = 60.33 \text{ (kN/m}^2\text{)}$
- Sliding force value: $Q_{tr} = 44.07 \text{ (kN/m)}$
- Value of force preventing wall sliding:
• $Q_{ff} = N \cdot \mu + C \cdot A$
- - on the foundation level: $Q_{ff} = 90.49 \text{ (kN/m)}$
- Safety factor: $Q_{ff} \cdot m / Q_{tr} = 1.479 > 1.000$

OVERTURNING ANGLES

- Soil type under foundation: not layered
- Design combination: $1.000 \cdot PM + 1.000 \cdot P'a + 1.000 \cdot Pa + 1.000 \cdot W + 1.000 \cdot a1$
- Reduced design load:
 $N = -70.89 \text{ (kN/m)} \quad M_y = 17.52 \text{ (kN} \cdot \text{m)} \quad F_x = -43.78 \text{ (kN/m)}$
- Maximum unit stresses from total loads:
 $q_{max} = 0.33 \text{ (MN/m}^2\text{)}$
- Minimum unit stresses from total loads:
 $q_{min} = 0.00 \text{ (MN/m}^2\text{)}$
- Overturning angle: $\theta_o = 1.44 \text{ (Deg)}$
- Coordinates of wall rotation point:
 $X = 432.39 \text{ (mm)}$
 $Z = 0.00 \text{ (mm)}$
- Safety factor: $4.600 > 1.000$

6. Results of RC design

- Moments



(kN*m)

Element	Moments	Value [kN*m]	Position [mm]	Combination
Wall	maximum	22.95	500.00	$0.900*PM + 0.765*P'a + 0.900*Pa + 1.000*W + 1.320*a1$
Wall	minimum	-3.17	3000.00	$1.100*PM + 1.100*P'a + 1.320*Pa + 1.000*W + 1.320*a1$
Footing	maximum	26.34	500.00	$0.900*PM + 0.765*P'a + 1.320*Pa + 1.000*W + 1.320*a1$
Footing	minimum	-2.20	900.00	$1.100*PM + 1.100*P'a + 1.320*Pa + 1.000*W + 1.320*a1$

PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	CV	
	Project:	Kusile Power Station	Component:	SDD Settling Dam	Date:	16/07/2009
	Job no.:	5452/38	File no.:	5452	Checked by:	KG & ARG
	Title:	SDD Inlet baffle wall design		Date:	16/07/2009	
	Structural design calculations and reports			Page:	18 of 18	

APPENDIX B

AUTODESK ROBOT STRUCTURES 2010 VERIFICATION

CONCRETE


1. BS 9/1/96 – RC columns

VERIFICATION EXAMPLE 1 - Column subjected to axial load and biaxial bending

DESCRIPTION OF THE EXAMPLE:

Following example illustrates the procedure of dimensioning of biaxial bending of column, which is non-sway in one direction, whereas sway in the other. The results of the program are accompanied by the „manual” calculations.

1. SECTION DIMENSIONS



2. MATERIALS

Concrete	: C20	$f_{cu} = 20.00$ (MPa)
Longitudinal reinforcement	: T	$f_y = 460.00$ (MPa)
Transversal reinforcement	: R	$f_y = 250.00$ (MPa)

3. BUCKLING MODEL

Direction Y

Off

Structure

Non-sway

Sway

$L_{oy} =$ m

$\beta_y =$

Direction Z

Off

Structure

Non-sway

Sway

$L_{oz} =$ m

$\beta_z =$

As can be seen the sway column is assumed for Z direction, and the non-sway column for Y direction.


4. LOADS

No.	Case	Nature	Group	H (kH)	MyA (kH'm)	MyB (kH'm)	MyC (kH'm)	MzA (kH'm)	MzB (kH'm)	MzC (kH'm)	γ
1	DL1	dead load	1	400.00	150.00	30.00	102.00	20.00	30.00	50.00	1.40
2	LL1	Live	1	150.00	120.00	30.00	84.00	10.00	20.00	40.00	1.60
*											

NOTE: Let us assume, the moments in Y direction are linearly distributed along the height of the column. Thus, we define only the ends' moments for Y direction. In Z direction however, we assume the mid-height moment is not a result of the linear distribution. For such a case, Robot let the user define the moments in the mid-section explicitly.

5. CALCULATED REINFORCEMENT:

Program generates the reinforcement 14 ϕ 20.




6. RESULTS OF THE SECTION CALCULATIONS:

The dimensioning combination is 1.4DL1+1.6LL1

The dimensioning section (where the most unfavorable set of forces is found) is for that combination the section in the mid-height of the column (marked as (C)).

Intersection			
Load types <input checked="" type="radio"/> Basic <input type="radio"/> Accidental			
Description	H (kN)	My (kN*m)	Mz (kN*m)
1.40DL1+1.60LL1 (A)	800.00	423.33	71.04
1.40DL1+1.60LL1 (C)	800.00	319.87	161.04
1.40DL1+1.60LL1 (B)	800.00	111.33	101.04
1.40DL1 (A)	560.00	224.93	46.93
1.40DL1 (C)	560.00	172.67	88.93
1.40DL1 (B)	560.00	56.93	60.93
1.00DL1+1.60LL1 (A)	640.00	359.07	57.63
1.00DL1+1.60LL1 (C)	640.00	270.53	135.63
1.00DL1+1.60LL1 (B)	640.00	95.07	83.63

Rd / Sd	1.00	<	1.05
MRd / MSd	1.00	<	1.05
NRd / NSd	1.00	<	1.76



Since the column is found as slender, in both direction the second-order effects are taken into account.

In parallel the other sections (at the ends of the column) are checked for all combinations of loads. All the results of total forces for each combination and each section of the column may be seen in the table "Intersection" at the Column-results layout.

7. CALCULATIONS OF TOTAL MOMENT:

7.1. LOADS

For the dimensioning combination, the loads are:

	Case	N (kN)	MyA (kN*m)	MyB (kN*m)	MyC (kN*m)	MzA (kN*m)	MzB (kN*m)	MzC (kN*m)
1	DL1	400	150	30	102	20	30	50*
2	LL1	150	120	30	84	10	20	40*
Dimensioning combination	1.4DL1+1.6LL1	800	402	90	277.2	44	74	134

,where A, B and C denote upper, lower and mid-height sections of the column respectively.

* - the values are written "by hand" by the user (see point 4 – Loads)

7.2. THE INFLUENCE OF SLENDERNESS

Two independent calculations of the total moment for both directions are carried out.

Slenderness analysis acc. to 3.8.1.3:

$$l_{ey} / h = 13.33 < 15 \text{ (non-sway for Y direction)}$$

$$l_{ez} / b = 13.0 > 10 \text{ (sway for Z direction)}$$

Since the ratio l_{ez} / b exceeds the limit, the column is found as **slender**.

Y DIRECTION

Calculation of minimum eccentricity e_{min} and minimum moment M_{min} – 3.8.2.4

$$e_{min} = \min(0.05 \cdot h; 0.02m) = 0.02 \text{ (m)}$$

$$M_{min} = N \cdot e_{min} = 16.0 \text{ (kNm)}$$

Calculation of initial moment M_i – eq. 36

For the mid-height section, we have:

$$M_i = 0.4 \cdot M_1 + 0.6 \cdot M_2 = 277.2 \text{ (kNm)} > 0.4 \cdot M_2 = 160.8 \text{ (kNm)}$$

Calculation of second-order eccentricity a_u – eq. 32

$$a_u = \beta_a K h = 0.053 \text{ (m)}$$

$$\beta_a = \frac{1}{2000} \left(\frac{l_e}{h} \right) = 0.088$$

$$K = \min \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}}; 1 \right)$$

$$N_{uz} = \frac{2}{3} \frac{f_{cu}}{\gamma_c} A_c + \frac{f_y}{\gamma_s} A_{sc} = 4060.18 \text{ (kN)}$$

$$A_c = 0.24 \text{ (m}^2\text{)}$$

$$A_{sc} = 43.98 \text{ (cm}^2\text{)}$$

$N_{bal} = 1222.64 \text{ (kN)}$ – note that this value is calculated in detail for the state equilibrium in a section. Using the approximated code formula one would obtain

$$N_{bal} = 1173.33 \text{ (kN)}$$

$$K = \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}} \right) = \quad \text{- thus, } K = 1 \text{ was assumed}$$

Calculation of second-order moment M_{add}

$$M_{add} = N \cdot a_u = 42.67 \text{ (kNm)}$$

NOTE: The second-order effects in Robot are taken into account dependent upon the section and upon the parameter sway/non sway in a following way:

- in non-sway structures, M_{add} is added for the mid-height section, while $0.5 M_{add}$ is added for the end sections. Such addition is carried out disregarding the distribution of the first-order moment.
- in sway structures, M_{add} is added to each of three sections of column. Such addition is carried out disregarding the distribution of the first-order moment.

The total moment M_y :

$$M_y = M_i + M_{add} = 319.87 \text{ (kNm)} > 16.00 \text{ (kNm)} = M_{min}$$

Z DIRECTION

Calculation of minimum eccentricity e_{min} and minimum moment M_{min} – 3.8.2.4

$$e_{min} = \min(0.05 \cdot b; 0.02m) = 0.02 \text{ (m)}$$

$$M_{min} = N \cdot e_{min} = 16.0 \text{ (kNm)}$$

Calculation of initial moment M_i – eq. 36

For the mid-height section, we have the moment fixed directly by the user:

$$M_i = 134 \text{ (kNm)}$$

Calculation of second-order eccentricity a_u – eq. 32

$$a_u = \beta_a K h = 0.034 \text{ (m)}$$

$$\beta_a = \frac{1}{2000} \left(\frac{l_e}{b} \right) = 0.0845$$

$$K = \min \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}}; 1 \right)$$

$$N_{uz} = \frac{2}{3} \frac{f_{cu}}{\gamma_c} A_c + \frac{f_y}{\gamma_s} A_{sc} = 4060.18 \text{ (kN)}$$

$$A_c = 0.24 \text{ (m}^2\text{)}$$

$$A_{sc} = 43.98 \text{ (cm}^2\text{)}$$

$N_{bal} = 1222.64 \text{ (kN)}$ – note that this value is calculated in detail for the state equilibrium in a section. Using the approximated code formula one would obtain

$$N_{bal} = 1173.33 \text{ (kN)}$$

$$K = \left(\frac{N_{uz} - N}{N_{uz} - N_{bal}} \right) = \quad \text{- thus, } K = 1 \text{ was assumed}$$

Calculation of second-order moment M_{add}

$$M_{add} = N \cdot a_u = 27.04 \text{ (kNm)}$$

NOTE: The second-order effects in Robot are taken into account dependent upon the section and upon the parameter sway/non sway in a following way:

- in non-sway structures, M_{add} is added for the mid-height section, while $0.5 M_{add}$ is added for the end sections. Such addition is carried out disregarding the distribution of the first-order moment.

- in sway structures, M_{add} is added to each of three sections of column. Such addition is carried out disregarding the distribution of the first-order moment.

The total moment M_z :

$$M_z = M_i + M_{add} = 161.04 \text{ (kNm)} > 16.00 \text{ (kNm)} = M_{\min}$$

7.3. FINAL RESULT

$$M_y = 320 \text{ (kNm)}$$

$$M_z = 161 \text{ (kNm)}$$

8. CONCLUSIONS

The algorithm of calculations of the total moments (i.e. slenderness effects) in non-sway/sway column has been presented. The results obtained with the program (see point 6 – Results of the Section Calculations) are in agreement with the manual calculations (see point 7.3 – Final Result)

LITERATURE

[1] British Standard BS 8110: 1985. Structural use of concrete. British Standard Institution, 1985.

PANEL B CONSULTANTS JOINT VENTURE Calculation Record

Client Name: ESKOM **Page:** 1 **of** 31
Project Name: SDD SETTLING TANKS **Job No:** K5452-80-071
Calculation Title: Junction Boxes - Typical
Calculation No./File No.: K5452-80-071 R1
Calculation is: Preliminary Final
Objective: Determine required reinforcement areas for ULS & SLS

Unverified assumptions requiring subsequent verification

No.	Assumption	Verified by	Date
1	Fluid density – 10kN/m ³	K. Georgala	05/04/2010
2	Soil pressure (see “Annexure A”)	K. Georgala	05/04/2010
3	Founding on non-yielding material	K. Georgala	05/04/2010

This section applies to computer generated calculations

Program Name/Number:	Autodesk Robot Structural Analysis 2010	Version:	V23.0.1.3128
Program Name/Number:	Autodesk Revit Structure 2010	Version:	V2010
Evidence of or reference to computer program verification, if applicable: See “Annexure B”			
Bases or reference thereto supporting application of the computer program to the physical problem: Finite element analysis (FEA) method can be implemented with acceptable standards to South Africa			

Review and approval

Rev	Prepared by	Date	Verified by	Date	Approved by	Date
1	S. Wilding	03/05/2010	T. Tjia	03/05/2010	K Georgala PrEng	04/05/2010

1. PURPOSE:

Determination of structure dimensions and required reinforcement under specified load

2. REFERENCES:

<input type="checkbox"/>	1. Concrete layout drawing	<u>K5452-80-103 to 109 & 111 to 117</u>
<input type="checkbox"/>	2. Reinforcement detail	<u>K5452-80-103 to 109 & 111 to 117</u>

3. LOAD CASES AND COMBINATIONS:

Load Cases:


1. Self Weight
2. Soil Pressure
3. Soil Water Pressure
4. Water Pressure

Load Combinations:


10. Own Weight + Soil Pressure + Soil Water Pressure (ULS)
20. Own Weight + Soil Pressure + Soil Water Pressure (SLS)

4. APPLICATIONS:

STRUCTURE VIEW (SQUARE & RECTANGULAR SHAPED JUNCTION BOXES)




STRUCTURE VIEW (PENTAGON SHAPED JUNCTION BOXES)




REINFORCING (SQUARE AND RECTANGULAR SHAPED JUNCTION BOXES):


(Horizontal inside face required reinforcement & minimum reinforcement)




(Horizontal outside face required reinforcement & minimum reinforcement)



(Vertical inside face required reinforcement & minimum reinforcement)



(Vertical outside face required reinforcement & minimum reinforcement)



INTERPRETATION:

A reinforcement area of 1340mm²/m will be sufficient to withstand the worst load combination scenario, Self Weight + Soil Pressure in the side walls.



Y16@150mm centre-to-centre = 1340mm²/m.

A reinforcement area of 754mm²/m will be sufficient to withstand the worst load combination scenario, Self Weight + Soil pressure in the top slab. The vertical reinforcement, Y15 @150mm, must act as starter bars of the top face slab reinforcement.



Y12@150mm centre-to-centre = 754mm²/m.

REINFORCING (PENTAGON SHAPED JUNCTION BOXES):



(Horizontal inside face required reinforcement & minimum reinforcement)





(Horizontal outside face required reinforcement & minimum reinforcement)



(Vertical inside face required reinforcement & minimum reinforcement)



(Vertical outside face required reinforcement & minimum reinforcement)



INTERPRETATION:

A reinforcement area of 1340mm²/m will be sufficient to withstand the worst load combination scenario, Self Weight + Soil Pressure, in the side walls

Y16@150mm centre-to-centre = 1340mm²/m.

A reinforcement area of 2094mm²/m will be sufficient to withstand the worst load combination scenario, Self Weight + Soil Pressure as the vertical reinforcement on the outside face of the longer wall.

Y20@150mm centre-to-centre = 2094mm²/m.

PANEL B	Client:	ESKOM	Computed by:	SW
CONSULTANTS	Project:	Kusile Power Station	Component:	Junction Boxes
JOINT	Job no.:	K5452-80	File no.:	5452-80-071 R1
VENTURE	Title:	SDD Settling Tanks Junction Boxes	Checked by:	KG
		Structural design calculations and reports	Date:	04/05/2010
			Page:	8 of 31

5. PROCEDURE/METHODOLOGY OF DESIGN:

5.1. The finite element design method has been applied for this analysis, as well as mathematical design procedures to SABS 0100, BS 8110 and ACI 318

5.2. Four load cases and two load combinations have been analyzed, as indicated in "Annexure A"

6. ASSUMPTIONS:

Assumptions requiring verification will be listed on the cover sheet

7. DEFINITION OF UNITS AND CONSTANTS:

Refer to "Annexure A"

8. ANALYSIS/SOLUTION: (see body of calculation for analysis and solutions)

Note: Detailed calculations output data to be provided on request.

9. METHOD OF RESULTS GENERATION:

All loads and load combinations are defined as load cases within Robot Structural Analysis, combinations have the addition of factors applied as explained on page 11 to 21 of this document, and are governed by ULS or SLS criteria.

The results displayed in this document, represents the worst cases of all possible cases, where each case has been analyzed individually as well as specified in combination cases.

10. APPENDICES TO CALCULATIONS:

10.1 Appendix A – Calculations.

10.2 Appendix B – Prokon Structural Analysis verification report – Side walls

10.3 Appendix C – Prokon Structural Analysis verification report – Top slab

**PANEL B
CONSULTANTS
JOINT
VENTURE**

Client: ESKOM
Project: Kusile Power Station Component: Junction Boxes
Job no.: K5452-80 File no.: 5452-80-071 R1
Title: SDD Settling Tanks Junction Boxes
Structural design calculations and reports

Computed by: SW
Date: 03/05/2010
Checked by: KG
Date: 04/05/2010
Page: 9 of 31


APPENDIX A

CALCULATIONS

SDD Junction Box Design

SQUARE & RECTANGULAR SHAPED JUNCTION BOXES

STRUCTURE VIEW



CALCULATION NOTE

Code preferences:

- BS 8004 – Soil Code
- SABS 1060 – Code Combinations
- BS 8110 – Concrete Design

Structure centre of gravity coordinates:

X = 2.425 (m)

Y = 2.425 (m)

Z = 3.808 (m)

Structure central moments of inertia:

Lx = 1244524.873 (kg.m²)

Ly = 1226735.499 (kg.m²)

Lz = 660942.734 (kg.m²)


Mass = 120248.968 (kg)

LOADS & LOAD COMBINATIONS:


Table of load cases / analysis types

Case 1 : OWN WEIGHT
Analysis type: Static – Linear


Case 2 : SOIL PRESSURE
Analysis type: Static – Linear



Case 3 : WATER PRESSURE
Analysis type: Static - Linear



Case 4 : LIVE LOAD
Analysis type: Static - Linear



Case 10 : SELF WEIGHT + SOIL PRESSURE (ULS)
Analysis type: Linear combination

Case 20 : SELF WEIGHT + SOIL PRESSURE (SLS)
Analysis type: Linear combination

SOIL PRESSURE

Geometrical data

Soil level (Z) = 7.1 (m)
Soil inclination (alpha) = 0.0 (Deg)
Wall inclination (beta) = 0.0 (Deg)

Soil

Underground water level = 7.10 (m)

Soil layers:

No.	Soil name	Level (m)	Unit weight (kg/m ³)	Unit weight of solid (kg/m ³)
1	Well graded gravel - sand mixtures	7.10	2242.58	2702.31

Limit and static pressure factors for soil layers taken into account during calculations:

No.	Soil name	Level	Friction angle (m)	Ka (Deg)	Ko	Kp
1	well graded gravel - sand mixtures	6.20	38.0	0.238	0.384	4.204

Soil pressure and passive pressure:

Limit displacement factor: = 0.00

LOADS


Case	Load type	List	Load values
1:DL1	self-weight	1to6	' PZ Negative Factor=1.00
2:Soil load	(FE) planar		' PX2=0.00(kN/m2) PX3=118.00(kN/m2) N1X=0.300(m) N1Y=4.550(m) N1Z=7.300(m) N2X=0.300(m) N2Y=0.300(m) N2Z=7.300(m) N3X=0.300(m) N3Y=0.300(m) N3Z=0.0(m)
2:Soil load	(FE) planar		' PY2=118.00(kN/m2) PY3=118.00(kN/m2) N1X=0.300(m) N1Y=0.300(m) N1Z=7.300(m) N2X=0.300(m) N2Y=0.300(m) N2Z=0.0(m) N3X=4.550(m) N3Y=0.300(m) N3Z=0.0(m)
2:Soil load	(FE) planar		' PX2=0.00(kN/m2) PX3=-118.00(kN/m2) N1X=0.300(m) N1Y=4.550(m) N1Z=7.300(m) N2X=0.300(m) N2Y=0.300(m) N2Z=7.300(m) N3X=0.300(m) N3Y=0.300(m) N3Z=0.0(m)
2:Soil load	(FE) planar		' PX2=0.00(kN/m2) PY3=-118.00(kN/m2) N1X=0.300(m) N1Y=4.550(m) N1Z=7.300(m) N2X=0.300(m) N2Y=0.300(m) N2Z=7.300(m) N3X=0.300(m) N3Y=0.300(m) N3Z=0.0(m)
3:Live Load	(FE) uniform		' PZ=-1.50(kN/m2)
3:Live Load	(FE) uniform	6	' PZ=-1.50(kN/m2)
2:Soil load	(FE) planar	5	' PX1=-128.00(kN/m2) PX2=-128.00(kN/m2) N1X=4.550(m) N1Y=0.300(m) N1Z=0.0(m) N2X=4.550(m) N2Y=4.550(m) N2Z=0.0(m) N3X=4.550(m) N3Y=2.425(m) N3Z=7.865(m)
2:Soil load	(FE) planar	4	' PY1=128.00(kN/m2) PY2=128.00(kN/m2) N1X=0.300(m) N1Y=0.300(m) N1Z=0.0(m) N2X=4.550(m) N2Y=0.300(m) N2Z=0.0(m) N3X=2.425(m) N3Y=0.300(m) N3Z=7.865(m)
2:Soil load	(FE) planar	3	' PX1=128.00(kN/m2) PX2=128.00(kN/m2) N1X=0.300(m) N1Y=4.550(m) N1Z=0.0(m) N2X=0.300(m) N2Y=0.300(m) N2Z=0.0(m) N3X=0.300(m) N3Y=2.425(m) N3Z=7.865(m)
2:Soil load	(FE) planar	2	' PY1=-128.00(kN/m2) PY2=-128.00(kN/m2) N1X=4.550(m) N1Y=4.550(m) N1Z=0.0(m) N2X=0.300(m) N2Y=4.550(m) N2Z=0.0(m) N3X=2.425(m) N3Y=4.550(m) N3Z=7.865(m)
4:Water Pressure	(FE) hydrostatic pressure	2 5	' GAMMA=10.00(kN/m3) H=7.050(m) NDIR=-Z
4:Water Pressure	(FE) hydrostatic pressure	3 4	' GAMMA=-10.00(kN/m3) H=7.050(m) NDIR=-Z

COMBINATIONS


Combinations	Name	Analysis type	Combination nature	Case nature	Definition
10 (C)	COMB1	Linear Combination	ULS	dead	1*1.20+(2+3)*1.60
20 (C)	COMB2	Linear Combination	SLS	dead	1*1.10+(2+3)*1.00

STRUCTURAL DIAGRAMS (SQAURE & RECTANGULAR SHAPED JUNCTION BOXES):


Structure deformation diagram




Stresses diagram



Forces diagram



Moments diagram



PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	SW	
	Project:	Kusile Power Station	Component:	Junction Boxes	Date:	03/05/2010
	Job no.:	K5452-80	File no.:	5452-80-071 R1	Checked by:	KG
	Title:	SDD Settling Tanks Junction Boxes		Date:	04/05/2010	
	Structural design calculations and reports			Page:	16 of 31	

REINFORCEMENT PARAMETERS

GENERAL

Concrete as in the structure model
 Lightweight concrete:

NO

ADDITIONAL INFO

Reinforcement check (cracking):
 Maximum cracking value:
 Exposure:

YES
 0.3 mm
 mild

LONGITUDINAL REINFORCEMENT

Steel characteristic strength:
 The same bar diameter in both directions:
 Diameters of reinforcing bars
 - Top/along b:
 - Bottom/along h:
 Cover
 - Clear cover:
 - To axis:

450.00 MPa
 YES
 12 mm to 20 mm
 12 mm to 32 mm
 50 mm to 70 mm
 58 mm

TRANSVERSAL REINFORCEMENT


Steel characteristic strength:
 Stirrups
 - Bar diameter:
 - Number of legs:
 - Number of reinforced. sections:
 Modularity of spacing:

450.00 MPa
 12 mm to 20 mm
 2
 3
 20 mm

For final reinforcement refer to reinforcement detail drawings.

PENTAGON SHAPED JUNCTION BOXES

STRUCTURE VIEW



CALCULATION NOTE

Code preferences:

- BS 8004 – Soil Code
- SABS 1060 – Code Combinations
- BS 8110 – Concrete Design

Structure centre of gravity coordinates:

X = 3.372 (m)

Y = 3.981 (m)

Z = 2.967 (m)

Structure central moments of inertia:

Lx = 1964416.926 (kg.m²)

Ly = 1877775.884 (kg.m²)

Lz = 1923736.791 (kg.m²)


Mass = 166093.661 (kg)

LOADS & LOAD COMBINATIONS:


Table of load cases / analysis types

Case 1 : OWN WEIGHT
 Analysis type: Static – Linear


Case 2 : SOIL PRESSURE
 Analysis type: Static – Linear



Case 3 : WATER PRESSURE
 Analysis type: Static - Linear



Case 4 : LIVE LOAD
 Analysis type: Static – Linear



Case 10 : SELF WEIGHT + SOIL PRESSURE (ULS)
 Analysis type: Linear combination

Case 20 : SELF WEIGHT + SOIL PRESSURE (SLS)
 Analysis type: Linear combination

SOIL PRESSURE

Geometrical data

Soil level (Z) = 7.1 (m)
 Soil inclination (alpha) = 0.0 (Deg)
 Wall inclination (beta) = 0.0 (Deg)

Soil

Underground water level = 7.10 (m)

Soil layers:

No.	Soil name	Level (m)	Unit weight (kg/m ³)	Unit weight of solid (kg/m ³)
1	Well graded gravel - sand mixtures	7.10	2242.58	2702.31

**PANEL B
CONSULTANTS
JOINT
VENTURE**

Client:	ESKOM	Computed by:	SW
Project:	Kusile Power Station	Component:	Junction Boxes
Job no.:	K5452-80	File no.:	5452-80-071 R1
Title:	SDD Settling Tanks Junction Boxes	Date:	03/05/2010
	Structural design calculations and reports	Checked by:	KG
		Date:	04/05/2010
		Page:	20 of 31

Limit and static pressure factors for soil layers taken into account during calculations:

No.	Soil name	Level	Friction angle (m)	Ka (Deg)	Ko	Kp
1	well graded gravel - sand mixtures	6.20	38.0	0.238	0.384	4.204

Soil pressure and passive pressure:

Limit displacement factor: = 0.00

LOADS


Case	Load type	List	Load values
1:DL1	self-weight	2 4to9	' PZ Negative Factor=1.00
2:Soil load	(FE) planar		' PX2=0.00(kN/m2) PX3=-118.00(kN/m2) N1X=0.300(m) N1Y=4.550(m) N1Z=7.300(m) N2X=0.300(m) N2Y=0.300(m) N2Z=7.300(m) N3X=0.300(m) N3Y=0.300(m) N3Z=0.0(m)
3:Live Load	(FE) uniform		' PZ=-1.50(kN/m2)
3:Live Load	(FE) uniform	9	' PZ=-1.50(kN/m2)
2:Soil load	(FE) planar	5	' PX2=0.00(kN/m2) PZ2=101.00(kN/m2) PZ3=101.00(kN/m2) local N1X=0.425(m) N1Y=3.920(m) N1Z=6.275(m) N2X=0.425(m) N2Y=7.414(m) N2Z=0.0(m) N3X=0.425(m) N3Y=0.425(m) N3Z=0.0(m)
2:Soil load	(FE) planar	2	' PZ2=101.00(kN/m2) PZ3=101.00(kN/m2) local N1X=2.582(m) N1Y=0.425(m) N1Z=6.275(m) N2X=0.425(m) N2Y=0.425(m) N2Z=0.0(m) N3X=4.738(m) N3Y=0.425(m) N3Z=0.0(m)
2:Soil load	(FE) planar	7	' PX2=0.00(kN/m2) PZ2=-101.00(kN/m2) PZ3=- 101.00(kN/m2) local N1X=6.224(m) N1Y=6.159(m) N1Z=6.275(m) N2X=7.869(m) N2Y=4.903(m) N2Z=0.0(m) N3X=4.579(m) N3Y=7.414(m) N3Z=0.0(m)
2:Soil load	(FE) planar	4	' PX2=0.00(kN/m2) PZ2=-101.00(kN/m2) PZ3=- 101.00(kN/m2) local N1X=2.502(m) N1Y=7.414(m) N1Z=6.275(m) N2X=4.579(m) N2Y=7.414(m) N2Z=0.0(m) N3X=0.425(m) N3Y=7.414(m) N3Z=0.0(m)
2:Soil load	(FE) planar	6	' PZ2=-101.00(kN/m2) PZ3=-101.00(kN/m2) local N1X=6.303(m) N1Y=2.664(m) N1Z=6.275(m) N2X=4.738(m) N2Y=0.425(m) N2Z=0.0(m) N3X=7.869(m) N3Y=4.903(m) N3Z=0.0(m)
4:Water Pressure	(FE) hydrostatic pressure	9	' GAMMA=10.00(kN/m3) H=6.000(m) NDIR=-Z
4:Water Pressure	(FE) hydrostatic pressure	5	' GAMMA=-10.00(kN/m3) H=6.000(m) NDIR=-Z
4:Water Pressure	(FE) hydrostatic pressure	2	' GAMMA=-10.00(kN/m3) H=6.000(m) NDIR=-Z
4:Water Pressure	(FE) hydrostatic pressure	4 6 7	' GAMMA=10.00(kN/m3) H=6.000(m) NDIR=-Z
4:Water Pressure	(FE) uniform	8	' PZ=-60.00(kN/m2)

COMBINATIONS


Combinations	Name	Analysis type	Combination nature	Case nature	Definition
10 (C)	COMB1	Linear Combination	ULS	dead	1*1.20+(2+3)*1.60
20 (C)	COMB2	Linear Combination	SLS	dead	1*1.10+(2+3)*1.00

STRUCTURAL DIAGRAMS (SQAURE & RECTANGULAR SHAPED JUNCTION BOXES):


Structure deformation diagram




Stresses diagram



Forces diagram



Moments diagram



PANEL B CONSULTANTS JOINT VENTURE	Client:	ESKOM		Computed by:	SW	
	Project:	Kusile Power Station	Component:	Junction Boxes	Date:	03/05/2010
	Job no.:	K5452-80	File no.:	5452-80-071 R1	Checked by:	KG
	Title:	SDD Settling Tanks Junction Boxes		Date:	04/05/2010	
	Structural design calculations and reports			Page:	23 of 31	

REINFORCEMENT PARAMETERS

GENERAL

Concrete as in the structure model
 Lightweight concrete:

NO

ADDITIONAL INFO

Reinforcement check (cracking):
 Maximum cracking value:
 Exposure:

YES
 0.3 mm
 mild

LONGITUDINAL REINFORCEMENT

Steel characteristic strength:
 The same bar diameter in both directions:
 Diameters of reinforcing bars
 - Top/along b:
 - Bottom/along h:
 Cover
 - Clear cover:
 - To axis:

450.00 MPa
 YES
 12 mm to 20 mm
 12 mm to 32 mm
 50 mm to 70 mm
 58 mm

TRANSVERSAL REINFORCEMENT

Steel characteristic strength:
 Stirrups
 - Bar diameter:
 - Number of legs:
 - Number of reinforced. sections:
 Modularity of spacing:

450.00 MPa
 12 mm to 20 mm
 2
 3
 20 mm

For final reinforcement refer to reinforcement detail drawings.

**PANEL B
CONSULTANTS
JOINT
VENTURE**

Client:	ESKOM	Computed by:	SW
Project:	Kusile Power Station	Component:	Junction Boxes
Job no.:	K5452-80	File no.:	5452-80-071 R1
Title:	SDD Settling Tanks Junction Boxes	Checked by:	KG
	Structural design calculations and reports	Date:	04/05/2010
		Page:	24 of 31

APPENDIX B

PROKON STRUCTURAL ANALYSIS VERIFICATION REPORT – SIDE WALLS

1000x300 Wall (Code of Practice : SABS 0100 - 2000)
2010/05/10 11:22:37 AM



Input Tables

Fcu (MPa)	30
Fy (MPa)	450
Fyv (MPa)	250
% Redistribution	0
Downward/Optimized redistrib.	D
Cover to centre top steel(mm)	70
Cover to centre bot.steel(mm)	70
Dead Load Factor	1.2
Live Load Factor	1.6
Density of concrete (kN/m3)	24
% Live load permanent	25
Ø (Creep coefficient)	2
Ecs (Free shrinkage strain)	300E-6

Sec No.	Bw (mm)	D (mm)	Bf-top (mm)	Hf-top (mm)	Bf-bot (mm)	Hf-bot (mm)	Y-offset (mm)	Web offset	Flange offset
1	1000	300							






Span No	Section Length(m)	Sec No Left	Sec No Right
1	6.55	1	1



Sup No.	Code C,F	Column Below			Code F,P	Column above			Code F,P
		D(mm)	B(mm)	H(m)		D(mm)	B(mm)	H(m)	
1	F								
2	F								

Case D,L	Span	Wleft (kN/m)	Wright (kN/m)	a (m)	b (m)	P (kN)	a (m)	M (kNm)	a (m)
D	1	16.9	0		4				
L	1	3	0		4				

Span	M left (kNm)	M right (kNm)

Deflection, Shear, Moment and Steel diagrams. Span 1





SECTION A-A

**PANEL B
CONSULTANTS
JOINT
VENTURE**

Client:	ESKOM	Computed by:	SW
Project:	Kusile Power Station	Component:	Junction Boxes
Job no.:	K5452-80	File no.:	5452-80-071 R1
Title:	SDD Settling Tanks Junction Boxes	Checked by:	KG
	Structural design calculations and reports	Date:	04/05/2010
		Page:	28 of 31

APPENDIX C

PROKON STRUCTURAL ANALYSIS VERIFICATION REPORT – TOP SLAB

1000x250 Slab (Code of Practice : SABS 0100 - 2000)
2010/05/10 11:18:06 AM



Input Tables

Fcu (MPa)	30
Fy (MPa)	450
Fyv (MPa)	250
% Redistribution	0
Downward/Optimized redistrib.	D
Cover to centre top steel(mm)	50
Cover to centre bot.steel(mm)	50
Dead Load Factor	1.2
Live Load Factor	1.6
Density of concrete (kN/m3)	24
% Live load permanent	25
Ø (Creep coefficient)	2
Ecs (Free shrinkage strain)	300E-6

Sec No.	Bw (mm)	D (mm)	Bf-top (mm)	Hf-top (mm)	Bf-bot (mm)	Hf-bot (mm)	Y-offset (mm)	Web offset	Flange offset
1	1000	250							







Span No	Section Length(m)	Sec No Left	Sec No Right
1	8.72	1	1



Sup No.	Code C,F	Column Below			Code F,P	Column above			Code F,P
		D(mm)	B(mm)	H(m)		D(mm)	B(mm)	H(m)	
1	F								
2	F								

Case D,L	Span	Wleft (kN/m)	Wright (kN/m)	a (m)	b (m)	P (kN)	a (m)	M (kNm)	a (m)
D	1								
L	1	3							

Span	M left (kNm)	M right (kNm)

Deflection, Shear, Moment and Steel diagrams. Span 1





SECTION A-A

PANEL B CONSULTANTS JOINT VENTURE Calculation Record

Client Name: ESKOM **Page:** 1 **of** 6

Project Name: Kusile Power Station **Job No:** 303-00098/06

Calculation Title: Pipe Hydraulic Calculations : SDD Settling Tanks

Calculation No./File No.: _____

Calculation is: Preliminary Final

Objective: Hydraulic design of the SDD and SDD Settling Tanks inlet and outlet pipes.

Unverified assumptions requiring subsequent verification			
No.	Assumption	Verified by	Date
	None		

This section applies to computer generated calculations	
Program Name/Number: <u>N/A</u>	Version: _____
Program Name/Number: <u>N/A</u>	Version: _____
Evidence of or reference to computer program verification, if applicable:	
Bases or reference thereto supporting application of the computer program to the physical problem:	

Review and approval						
Rev	Prepared by	Date	Verified by	Date	Approved by	Date
0	Scott Rees	Oct 09				

1. PURPOSE:

To calculate the size/capacity of the SDD and SDD ST inlet and outlet pipes.

2. REFERENCES:

1.	SDD SETTLING TANKS INLET & OUTLET PIPEWORKS GENERAL ARRANGEMENT	5452/80/071	Rev	
2.	SDD SETTLING TANKS INLET & OUTLET PIPEWORKS SECTIONS & DETAILS	5452/50/072	Rev	
3.	SDD SETTLING TANKS INLET & OUTLET PIPEWORKS SECTIONS	5452/80/100	Rev	

3. ASSUMPTIONS

Density of water = 1000kg/m³
 Acceleration due to gravity = 9.81m/s²

Additional assumptions are listed in the detailed hydraulic calculations, where applicable.

4. HYDRAULIC CALCULATIONS

APPENDICES


None

Calculations

Knight Piésold CONSULTING PHALABORWA OFFICE First Floor, Park Building Tambolie Street, P.O. Box 830, Phalaborwa 1390 Tel: (015) 781-0839/0882 Fax: (015) 781-3788 Email: kppha@mweb.co.za	JOB KUSILE POWER STATION	SHEET No.
	REF.DRGS	JOB No. 303-00098/06
DESIGNED Scott Rees	DATE Oct. 20/09	
CHECKED	DATE	

HYDRAULIC DESIGN - SDD & SDD ST PIPES

* assume SDD is operated empty, check JBK13 to SDD compartment 2 first.



- length = 250m
- headwater level = 1454m
- tailwater level = 1445.2m (assume pipe \varnothing @ outlet)

$$\frac{P_1}{\rho} + \frac{V_1^2}{2g} + Z_1 = \frac{P_2}{\rho} + \frac{V_2^2}{2g} + Z_2 + \sum h_L$$

$$\Delta Z - \sum h_L = V_2^2 / 2g$$

$$\sum h_L = \sum K \cdot \frac{V^2}{2g} + f \cdot \frac{L}{D} \cdot \frac{V^2}{2g}, \quad \sum K = 3 \times 1.0 + 2 \times 0.5 = 4$$


• substitute in $V = Q/A$, and solve Swamee-Jain formula with excel program

$$Q = 24.8 \text{ m}^3/\text{s}$$

* this is sufficient to handle all of the dirty water flow to the SDD

Knight Piésold CONSULTING	JOB <u>KUSILE POWER STATION</u>	SHEET No.
	REF.DRGS	JOB No.
PHALABORWA OFFICE First Floor, Park Building Tamboke Street, P O Box 830, Phalaborwa 1390 Tel: (015) 781-0839/0862 Fax: (015) 781-3788 Email: kppha@rweb.co.za	DESIGNED <u>Scott Rees</u>	DATE <u>Oct 20/09</u>
	CHECKED	DATE

JBK13 → Compartment 1



• applying Bernoulli's,

$$\Delta Z - \sum h_L = V^2/2g$$

$$\sum h_L = \sum K \cdot V^2/2g + f \cdot \frac{L}{D} \cdot \frac{V^2}{2g}, \quad \sum K = 1 + 0.5 = 1.5$$

$$L = 60m$$

• substitute in $V = Q/A$, and solve using the Swamee-Jain approximation.

$$Q = 46.3 m^3/s$$

Knight Piésold CONSULTING PHALABORWA OFFICE First Floor, Park Building Tamboke Street, P O Box 830, Phalaborwa 1390 Tel: (015) 781-0838/0882 Fax: (015) 781-3788 Email: kppha@mweb.co.za	JOB KUSILE POWER STATION	SHEET No.
	REFDRGS	JOB No. 303-00098/06
	DESIGNED Scott Rees	DATE Oct 30/09
	CHECKED	DATE

JB504-JBK12

- 1950 ND class 100D concrete Pipe - 1.8m Inside Diameter
- length = 410m
- minor losses, $k = 4.5$
- headwater $\sim 1463m$, Tailwater $\sim 1455m$

$Q = 12.24 \text{ m}^3/\text{s}$

JBK12 \rightarrow JBK13

- 2x 1950 ND class 100D concrete Pipe
- length = 245m
- headwater = 1455m, tailwater = 1454m

$Q = 7.4 \text{ m}^3/\text{s}$

$2Q = 14.8 \text{ m}^3/\text{s}$

\rightarrow this is under-capacity, however in the event that the SDD is full, the water will be backed up through the entire pipeline

- try with JBK13 at 1452m TWL (more realistic)

$Q = 12.8 \text{ m}^3/\text{s}$

$2Q = 25.6 \text{ m}^3/\text{s}$

* this is sufficient to pass the total flow (1:50yr) of $23.9 \text{ m}^3/\text{s}$

Knight Piésold CONSULTING PHALABORWA OFFICE First Floor, Park Building Tambolie Street, P O Box 830, Phalaborwa 1390 Tel: (015) 781-0838/0882 Fax: (015) 781-3788 Email: kppha@mweb.co.za	JOB KUSILE POWER STATION	SHEET No.
		JOB No. 303-00098/06
	REF: DRGS	
	DESIGNED Scott Rees	DATE Oct 30/09
	CHECKED	DATE

SDD ST → JBK12

- 1950 ND Class 100D Concrete Pipe
- length = 130m
- $\Sigma K = 2(1.0) + 2(0.5) = 3$
- Top water Level = 1459m, Tail water Level = 1455m

$Q = 13.1 \text{ m}^3/\text{s}$

JB509 → SDDST

- 1950 ND Class 100D Concrete Pipe
- length = 185m
- $\Sigma K = 2(1.0) + 2(0.5) = 3.0$
- Top water Level = 1467m, Tail water Level = 1460.4m

$Q = 15.8 \text{ m}^3/\text{s}$

→ more conservatively, try Headwater Level = 1466m

$Q = 14.5 \text{ m}^3/\text{s}$