

Dan Hlanyane  
Senior Manager Municipal Health & Environmental Services  
Gert Sibande District Municipality  
C/O Joubert and Oosthuise streets  
Ermelo  
2350

Date:  
01 June 2020

Enquiries: F Kagoda  
Tel +27 17 799 3241

Dear Mr Hlanyane

## REVISION OF MAJUBA POWER STATION'S MARCH AND JUNE 2019 MONTHLY EMISSIONS REPORTS

Majuba Power Station (hereafter referred to as 'the Station') is required to report on its point source emissions on a monthly basis as per its Atmospheric Emissions Licence (AEL reference Dr PKI Seme/Eskom H SOC Ltd/MPS/0014/2019/F03).

A review was undertaken on the Station's reports submitted to the Licencing Authority to ensure exceedances were reported accurately. It was noted that there were two instances where exceedances were falsely reported as a result of emissions monitor faults. As a result, the reports were revised and hereby submitted to the Licencing Authority, the changes are noted in the table below:

**Table 1: Monitor issues experienced**

Month	Unit	Monitor	Date of issue
March 2019	4	SO <sub>x</sub>	7 March 2019
		NO <sub>x</sub>	7 March 2019
June 2019	4	SO <sub>x</sub>	5 June 2019

The Station hereby submits the revised monthly emissions reports. Please do not hesitate to contact us should you have any further queries on this matter.

Yours sincerely



Tebogo Lekalakala  
**GENERAL MANAGER: MAJUBA POWER STATION**