

Ian Gildenhuys
Air Quality Management
246 Voortrekker Road
Vasco
7460

Date:
6 May 2020

Enquiries: Hilton Westman
(021) 9415856

Ref: ACP/2020/04

Dear Mr Gildenhuys

ACACIA POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL 2020

This serves as the monthly report required in terms of Section 5.4.1 and Sections 8.1.1 of Acacia Power Station's Atmospheric Emission License **WCCT023**. The information is applicable for the month of April 2020.

1. Raw Materials and Products (Licence 5.4.1)

Quantity of Raw Materials and Products used/produced for the month

Element	Performance	Reporting Unit
Fuel type : Kerosene		
Total Fuel Consumption	1.874	Tons
Electricity Produced	0	MWh
Average Fuel Consumption	0	Tons / MWh
Maximum fuel consumption rate	0	Kg per hour

2. Operating times of units (Licence 5.4.1)

a. Total Hours

	Hours operated	Total Fuel Consumption	Energy Production
	Hours	Litres	MWh
Unit One	0	2186	0
Unit Two	0		0
Unit Three	0		0

Peaking

Acacia Power Station
Off Montague Road Monte Vista 7460
PO Box 193 Edgemoed 7407
Tel +27 21 558 7266 Fax +27 21 558 2997 www.eskom.co.za

Eskom Holdings SOC Ltd Reg No 2002/015527/30

b. Detailed operating times

Not applicable

3. Complaints Register (Licence reference 8.1.1)

One complaint was received for the month of April 2020. On Investigation this was determined not to be related to Eskom Acacia Power Station. The complaint by an Edgemean resident related to a loud noise from an alarm coming from the direction of the station. The station manager verified the next day that no alarms were recorded on site on the day / evening in question, and the sound must have originated from another source.

4. General

A VT (Voltage transformer) failure was recorded on Unit 1 that required a test run in order to requalify the unit. A unit test run was done on 21st April and again on the 23rd which resulted in the fuel usage.

The monthly Ambient Air Quality Report compiled by Argos Scientific for air quality monitoring at the Acacia AQM station, will be sent to your office as soon as it is received.

Load Factor –April 2020
0 % *per Unit*

We trust that the above information complies with your requirements.

Yours sincerely



Pamela Mrubata
Plant Manager
ACACIA POWER STATION

