

Ian Gildenhuys
 Air Quality Management
 246 Voortrekker Road
 Vasco
 7460

Date:
 2 December 2020

Enquiries: Hilton Westman
 (021) 9415856

Ref: ACP/2020/11

Dear Mr Gildenhuys

ACACIA POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF NOVEMBER 2020

This serves as the monthly report required in terms of Section 5.4.1 and Sections 8.1.1 of Acacia Power Station's Atmospheric Emission License **WCCT023**. The information is applicable for the month of November 2020.

1. Raw Materials and Products (Licence 5.4.1)

Quantity of Raw Materials and Products used/produced for the month

Element	Performance	Reporting Unit
Fuel type : Kerosene		
Total Fuel Consumption	0	Tons
Electricity Produced	0	MWh
Average Fuel Consumption	0	Tons / MWh
Maximum fuel consumption rate	0	Kg per hour

2. Operating times of units (Licence 5.4.1)

a. Total Hours

	Hours operated	Total Fuel Consumption	Energy Production
	Hours and minutes	Litres	MWh
Unit One	0	0	0
Unit Two	0		0
Unit Three	0		0

b. Detailed operating times

Not applicable

3. Complaints Register (Licence reference 8.1.1)

No complaints were registered for the month of November 2020, however 1 communication public enquiry was received questioning Eskom Acacia design to withstand tremor (after recent seismic activity), and expected date of decommission. A reply was sent by Peaking Stakeholder Management indicating that there would be no impact on the station in the event of a tremor.

4. General

Acacia was not requested to generate for the grid to supplement power availability and minimise national load shedding.

New 5 year Acacia AQM contract with Argos Scientific started on the 1st November for monthly ambient air quality monitoring at the Acacia AQM station.

The Eskom owned NOx analyser major component repair has recently been completed and is expected back within next week.

We trust that the above information complies with your requirements.

Yours sincerely



Pamela Mrubata
Plant Manager
ACACIA POWER STATION