



Mr. Vusi Mahlangu
Air Quality Officer
DEDET
Private bag X11215
NELSPRUIT
1200

Date:
19 October 2020

Enquiries:
Mariam Joseph
Tel +27 13 297 9828
Fax + 27 86 661 7663

Dear Mr. Mahlangu

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF SEPTEMBER 2020

This serves as the monthly report required in terms of Section 6 in Arnot Power Station's Atmospheric Emission License. The emissions are for the month of September 2020, Verified emissions of particulates; SO₂ and NO_x (as NO₂) are also included.

Raw Materials and Products

Table1: Quantity of Raw Materials and Products used/produced for the Month of September 2020

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption/ Rate in Month of September
	Coal	Tons/month	1 050 330	437948.52
Fuel Oil	Tons/month	10 000	1278.44	

Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of September 2020
	Energy	GWh	1 785 600	771 188
Ash	Tons/month	421 000	101 472	

Abatement Technology

Generation Division
Arnot Power Station
N4 Nelspruit Road
Private Bag X2 Rietkuil 1097 SA
Tel +27 13 297 9111 Fax +27 13 297 9142 www.eskom.co.za

Eskom Holdings SOC Ltd Reg No 2002/015527/30

MMR

**ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF
SEPTEMBER 2020**

Table 2: Abatement Equipment Control Technology for month of September 2020

Associated Unit/Stack	Technology Type	Actual Utilisation (%) for the month of June 2020
North Stack	Fabric Filter Bags	99.9%
South Stack	Fabric Filter Bags	99.8%

Energy Source Characteristics

Table 3: Energy Source Material Characteristics for the month of September 2020

Characteristic	Stipulated Range (Unit)	Monthly Average Content
Sulphur Content	0.5 to < 1 (%)	0.62%
Ash Content	17 to < 40 (%)	23.17%

Table 4 Operating days in compliance to PM AEL Limit –September 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
North	31	0	0	0	0	23.4
South	28	0	0	0	0	32.5
SUM	59	0	0	0	0	

Table 5 Operating days in compliance to NOx AEL Limit – September 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm ³)
North	31	0	0	0	0	671.1
South	28	0	0	0	0	789.2
SUM	59	0	0	0	0	

Table 6: Operating days in compliance to SOx AEL Limit –September 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm ³)
North	31	0	0	0	0	1297.9
South	28	0	0	0	0	1573.7
SUM	59	0	0	0	0	

MMR

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF SEPTEMBER 2020

Emissions Reporting




Figure 1: PM emissions (daily averages) for the month of September 2020 against emission limit for the North Stack




Figure 2: PM emissions (daily averages) for the month of September 2020 against emission limit for the South Stack

MMR

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF SEPTEMBER 2020




Figure 3: SO₂ emissions (daily averages) for the month of September 2020 against emission limit for the North Stack




Figure 4. SO₂ emissions (daily averages) for the month of September-2020 against emission limit for the South Stack.

MMR

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF SEPTEMBER 2020




Figure 5: NO₂ emissions (daily averages) for the month of September -2020 against emission limit for the North Stack




Figure 6: NO₂ emissions (daily averages) for the month of September -2020 against emission limit for the South Stack

MMR

**ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF
SEPTEMBER 2020**

Table 4: Monthly tonnages for the month of September 2020

Unit	PM (tons)	SO ₂ (tons)	NO ₂ (tons)	CO ₂ (tons)
Total Tons (North & South Stack)	108.0	5647.1	2875.8	790683

Table 5: Monitor Availability

Unit	PM (%)	SO ₂ (%)	NO ₂ (%)
North Stack	100.0	99.6	99.6
South Stack	100.0	91.8	91.8

Table 6: Each unit and respective days operating under normal operation, days in grace period, and section 30 days respectively

Unit	Days operating under normal operation	Days operating in grace period	Days operating under S 30
1	31	0	0
2	31	0	0
3	31	0	0
4	31	0	0
5	31	0	0
6	31	0	0

Light up information

Continuous reporting is being done even during start-ups, emissions were not affected.

Complaints Register

Table 7. Complaints for the month of September 2020

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

General

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission reports sent to your office.

MMR

**ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF
SEPTEMBER 2020**

Hoping the above will meet your satisfaction.

Compiled by



Lawrence Machebe

ENVIRONMENTAL OFFICER: ARNOT


Verified by



Nomathemba Mpulo

SENIOR TECHNOLOGIST: ARNOT

Supported by



Rofhiwa Tshikovha

SENIOR ENVIRONMENTAL ADVISOR: ARNOT

MMR

**ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF
SEPTEMBER 2020**

Approved by



Mariam Joseph

SENIOR ENVIRONMENTAL ADVISOR: ARNOT

Yours sincerely



Aswin Rampersad

GENERAL MANAGER: ARNOT