

Mrs Mpho Nembilwi
Nkangala District
P.O Box 437
MIDDLEBERG
1050
By email: nembilwim@nkangaladm.gov.za'

Date:
16 July 2020

Enquiries: E Madike
Tel +27 13 647 9199

Dear Mrs. Mpho Nembilwi

Ref: Kendal Power Station AEL (17/4/AEL/MP312/11/15)

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF APRIL 2020

This is a monthly report required in terms of Section 7.4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Note: This report was reviewed by Ebrahim Patel from Eskom Generation Division | Asset Management | Mechanical Engineering Center of Excellence | Air Pollution Control

Compiled by:



Tshilidzi Vilane
ENVIRONMENTAL OFFICER- KENDAL

Date: 16-07-2020

Verified by:



Hlono Malatsi
SENIOR TECHNICIAN BOILER ENGINEERING- KENDAL

16/07/2020
Date:

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF APRIL 2020


Validated by:



Malibongwe Mabizela
BOILER ENGINEERING MANAGER-KENDAL

Date: 16/07/2020

Supported by:



Bonga Mashazi
ENGINEERING MANAGER-KENDAL

Date: 2020/07/16

Approved by:



Solly Ngcashi
ACTING GENERAL MANAGER-KENDAL

Date: 2020.07.20

KENDAL POWER STATION MONTHLY EMISSIONS REPORT
 Atmospheric Emission License 17/4/AEL/MP312/11/15



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Consumption Rate Apr-2020
	Coal	Tons	582 177
	Fuel Oil	Tons	1059.44

Production Rates	Product / By-Product Name	Units	Production Rate Apr-2020
	Energy	GWh	962.62
	Ash	Tons	179 485.2
	RE Ash	kg/MWh	1.131

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.7 TO >1 (%)	1.100
Ash Content	%	30 TO >40 (%)	30.830

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SOx	NOx
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMET TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Apr-2020	Technology Type	Utilization Apr-2020
Unit 1	ESP + SO ₃	99.8%	SO ₃	95.1%
Unit 2	ESP + SO ₃	99.7%	SO ₃	99.0%
Unit 3	ESP + SO ₃	99.3%	SO ₃	100.0%
Unit 4	ESP + SO ₃	99.4%	SO ₃	99.8%
Unit 5	ESP + SO ₃	Unit off	SO ₃	Unit off
Unit 6	ESP + SO ₃	97.3%	SO ₃	Data not available(Piserver frozen)

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	99.6	99.8	99.8	83.8
Unit 2	0.0	0.0	0.0	0.0
Unit 3	75.0	100.0	96.9	0.0
Unit 4	99.2	98.5	98.4	0.0
Unit 5	Unit off	Unit off	Unit off	Unit off
Unit 6	83.5	99.9	99.9	0.0

Note: Low monitor reliability is due to defective analysers as a result of unavailability of spares, Maintenance working on this issue .

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of April 2020

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	72.9	2 962	1 358
Unit 2	140.0	4 118	1 820
Unit 3	65.8	654	240
Unit 4	227.4	3 264	1 099
Unit 5	Unit off	Unit off	Unit off
Unit 6	582.6	1 938	789
SUM	1 088.71	12 937	5 305

Table 6.2: Operating days as per PM AEL Conditions - April 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	20	3	0	0	3	60.5
Unit 2	0	2	0	23	25	115.5
Unit 3	1	2	0	2	4	198.7
Unit 4	3	4	0	18	22	179.0
Unit 5	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 6	0	1	0	12	13	769.0
SUM	24	12	0	55	67	

Table 6.3: Operating days as per SOx AEL Conditions - April 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm ³)
Unit 1	25	0	0	0	0	2 025.8
Unit 2	26	0	0	0	0	2 458.1
Unit 3	6	0	0	0	0	1 844.9
Unit 4	26	0	0	0	0	2 088.5
Unit 5	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 6	13	0	0	0	0	1 779.6
SUM	96	0	0	0	0	

Table 6.4: Operating days as per NOx AEL Conditions - April 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm³)
Unit 1	25	0	0	0	0	928.8
Unit 2	26	0	0	0	0	1 086.3
Unit 3	6	0	0	0	0	668.5
Unit 4	26	0	0	0	0	702.1
Unit 5	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 6	13	0	0	0	0	723.4
SUM	96	0	0	0	0	

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Dark Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contra-vention	Red	Emissions above ELV but outside grace or S30 incident conditions





Figure 2: Kendal Unit 2 PM Emissions - April 2020



Unit 2 PM used an average PM of 115.5 mg/Nm3 (average load of 454 MW) for Unit 2 from 07 to 30 April due to the PI server fault. This is based on the average emissions for March and 6th of 31st of May 2020.

Figure 3: Kendal Unit 3 PM Emissions - April 2020




Figure 4: Kendal Unit 4 PM Emissions - April 2020




Figure 5: Kendal Unit 5 PM Emissions - April 2020




Figure 6: Kendal Unit 6 PM Emissions - April 2020






Figure 7: Kendal Unit 1 SOx Emissions - April 2020




Note that gaseous emissions (H₂O, O₂ & CO₂) for unit 1 were manually entered using independent third party QAL2 parallel test reports due to defective CEMS monitors.

Figure 8: Kendal Unit 2 SOx Emissions - April 2020




Note that gaseous emissions (H₂O, O₂ & CO₂) including SO_x and NO for unit 2 were manually entered using independent third party QAL2 parallel test reports due to defective CEMS monitors.

Figure 9: Kendal Unit 3 SOx Emissions - April 2020



Note that gaseous emissions (H₂O, O₂ & CO₂) for unit 3 were manually entered using independent third party QAL2 parallel test reports due to defective CEMS monitors.

Figure 10: Kendal Unit 4 SOx Emissions - April 2020



Note that gaseous emissions (H₂O, O₂ & CO₂) for unit 4 were manually entered using independent third party QAL2 parallel test reports due to defective CEMS monitors.

Figure 11: Kendal Unit 5 SOx Emissions - April 2020






Figure 12: Kendal Unit 6 SOx Emissions - April 2020




Note that gaseous emissions (H₂O, O₂ & CO₂) for unit 6 were manually entered using Independent third party QAL2 parallel test reports due to defective CEMS monitors.

Figure 13: Kendal Unit 1 NOx Emissions - April 2020




Note that gaseous emissions (H₂O, O₂ & CO₂) for unit 1 were manually entered using Independent third party QAL2 parallel test reports due to defective CEMS monitors.

Figure 14: Kendal Unit 2 NOx Emissions - April 2020




Note that gaseous emissions (H₂O, O₂ & CO₂) including SO_x and NO_x for unit 2 were manually entered using independent third party QAL2 parallel test reports due to defective CEMS monitors.

Figure 15: Kendal Unit 3 NOx Emissions - April 2020



Note that gaseous emissions (H₂O, O₂ & CO₂) for unit 3 were manually entered using independent third party QAL2 parallel test reports due to defective CEMS monitors.

Figure 16: Kendal Unit 4 NOx Emissions - April 2020



Note that gaseous emissions (H₂O, O₂ & CO₂) for unit 4 were manually entered using independent third party QAL2 parallel test reports due to defective CEMS monitors.

Figure 17: Kendal Unit 5 NOx Emissions - April 2020





Figure 18: Kendal Unit 6 NOx Emissions - April 2020



Note that gaseous emissions (H₂O, O₂ & CO₂) for unit 6 were manually entered using Independent third party QAL2 parallel test reports due to defective CEMS monitors.

7 COMMENTS

Note that gaseous emissions for units 1,2,3,4 & 6 were manually entered using Independent third party QAL2 parallel test reports due to defective CEMS monitors

Unit 2 PM used an average PM of 115.5 mg/Nm³ (average load of 454 MW) for Unit 2 from 07 to 30 April due to the PI server fault. This is based on the average emissions for March and 6th to 31st of May 2020.

Units 3,4 & 6 high PM emissions can be attributed to poor availability of Dust Handling Plant resulting to ash backlogs causing poor performance of the electrostatic precipitators fields.

Unit 5 was still offload during the whole months of April 2020

average SRM velocity values were used for gaseous emissions on unit 1,3 & 4 and velocity factors were set at M=1 and C=0

8 COMPLAINTS

There were no complaints for the months of April 2020