

Department of Agriculture, Rural Development, Land and Environmental Affairs

The Director: Pollution and Waste Management  
Private Bag X11219  
Nelspruit 1200

Date:  
15<sup>th</sup> June 2018  
Enquiries:

Attention:  
Mr. M Mahlalela

**Nkangala District Municipality**  
PO Box 437  
Middelburg 1050

Attention:  
Mr. V Mahlangu

## MATLA POWER STATION AIR QUALITY REPORT FOR MAY 2018

The figures reported in this report are preliminary, and are to be considered for information purposes only. Final annual figures are those reported within 60 days of the independent audit conducted at the end of the financial year (March).

### 1. PARTICULATE EMISSIONS: MONTHLY TONNAGES.

	BLR	JUN 2017	JUL 2017	AUG 2017	SEP 2017	OCT 2017	NOV 2017	DEC 2017	JAN 2018	FEB 2018	MAR 2018	APR 2018	MAY 2018
Monthly Tonnage	1	70.23	34.95	61.36	65.19	71.68	108.77	90.10	46.69	Off	Off	Off	Off
	2	36.73	31.62	47.40	56.79	51.66	99.27	84.35	165.43	57.98	60.80	28.57	44.25
	3	39.75	30.24	48.85	61.23	47.64	97.34	82.94	172.35	55.05	62.50	29.56	35.97
	4	31.23	22.41	165.94	148.80	183.23	165.67	173.61	188.43	166.34	132.22	87.07	123.63
	5	25.52	17.14	30.95	45.36	147.51	74.42	49.59	82.97	68.06	97.63	61.14	83.25
	6	44.15	39.51	Off	Off	Off	5.37	22.74	53.43	62.15	50.91	52.66	44.17
	Station	247.61	175.85	354.51	377.37	501.73	550.84	503.33	709.30	409.57	404.02	258.99	331.28
GWhSO		1357.6	1977.7	1557.1	1703.4	1580.5	1802.7	1998.5	1783.6	1562.9	1733.7	1594.2	1627.7

Generation Division (Operating Unit Coal 2)  
Matla Power Station SA  
Delmas Road  
Private Bag X 5012, Kriel, 2271 SA  
Tel +27 17 612 9111 Fax +27 17 612 6651 www.eskom.co.za

## 2. COAL AND LOAD FACTOR:

STATION		JUN 2017	JUL 2017	AUG 2017	SEP 2017	OCT 2017	NOV 2017	DEC 2017	JAN 2018	FEB 2018	MAR 2018	APR 2018	MAY 2018
Load Factor		77.44	73.03	75.25	78.05	80.55	83.88	85.33	82.96	88.34	86.45	78.39	89.58
Ash Content	%	26.01	26.24	28.42	28.70	24.34	24.11	29.57	27.15	23.3	26.41	25.3	27.70
Sulphur Content	%	0.79	0.94	1.00	1.00	1.00	1.0	1.0	1.0	0.95	0.90	1.00	1.2
Total Moisture	%	9.46	9.33	9.54	7.10	8.11	10.69	9.64	9.43	9.60	9.57	9.21	9.7

## 3. GASEOUS EMISSIONS:

**CO<sub>2</sub> emissions: kilotons emitted per month, calculated from coal analysis and emission factors.**

	JUN 2017	JUL 2017	AUG 2017	SEP 2017	OCT 2017	NOV 2017	DEC 2017	JAN 2018	FEB 2018	MAR 2018	APR 2018	MAY 2018
Units 1-3												
Unit 4												
Unit 5												
Unit 6												
All Units												

**SO<sub>2</sub> emissions: kilotons emitted per month, calculated from coal analysis and emission factors.**

	JUN 2017	JUL 2017	AUG 2017	SEP 2017	OCT 2017	NOV 2017	DEC 2017	JAN 2018	FEB 2018	MAR 2018	APR 2018	MAY 2018
Units 1-3	9.97	6.53	9.64	8.66	9.40	10.46	10.31	8.25	6.95	7.84	6.62	7.68
Unit 4	2.74	2.16	3.52	3.15	3.62	3.38	3.71	2.89	2.85	3.16	3.29	3.94
Unit 5	3.57	2.32	2.99	3.02	3.25	3.15	3.50	3.31	3.02	3.51	3.07	3.95
Unit 6	3.34	2.36	Off	Off	Off	0.44	2.80	3.70	2.46	3.13	3.15	3.93
All Units	19.63	13.37	16.15	14.83	16.27	17.43	20.32	18.15	15.28	17.64	16.12	19.50

**NO<sub>x</sub> emissions: kilotons emitted per month, calculated from coal analysis and emission factors.**

	JUN 2017	JUL 2017	AUG 2017	SEP 2017	OCT 2017	NOV 2017	DEC 2017	JAN 2018	FEB 2018	MAR 2018	APR 2018	MAY 2018
Units 1-3	3.12	2.96	3.02	2.71	2.95	3.28	3.23	2.59	2.18	2.46	2.07	2.01
Unit 4	0.86	0.98	1.10	0.99	1.13	1.06	1.16	0.91	0.89	0.99	1.03	1.03
Unit 5	1.12	1.05	0.94	0.95	1.02	0.99	1.10	1.04	0.95	1.10	0.96	1.03
Unit 6	1.05	1.07	Off	Off	Off	0.14	0.88	1.16	0.77	0.98	0.99	10.3
All Units	6.15	6.07	5.06	4.65	5.10	5.46	6.37	5.69	4.79	5.53	5.05	5.09

**CO<sub>2</sub> emissions: kilotons emitted per month, measured with the continuous emission monitoring system. NOTE: These are unverified values for information purposes only.**

	JUN 2017	JUL 2017	AUG 2017	SEP 2017	OCT 2017	NOV 2017	DEC 2017	JAN 2018	FEB 2018	MAR 2018	APR 2018	MAY 2018
Units 1-3												
Unit 4												
Unit 5												
Unit 6												
All Units												

**SO<sub>2</sub> emissions: kilotons emitted per month, measured with the continuous emission monitoring system. NOTE: These are unverified values for information purposes only.**

	JUN 2017	JUL 2017	AUG 2017	SEP 2017	OCT 2017	NOV 2017	DEC 2017	JAN 2018	FEB 2018	MAR 2018	APR 2018	MAY 2018
Units 1-3	8.91	6.29	7.60	7.82	7.59	12.65	9.94	7.15	5.55	8.31	6.73	6.64
Unit 4	1.49	1.27	2.89	1.54	2.91	2.51	2.43	1.61	1.81	2.28	2.18	1.96
Unit 5	2.34	2.25	4.66	1.55	2.84	3.05	2.89	2.54	2.57	2.74	2.61	2.58
Unit 6	2.81	2.05	Off	Off	Off	0.14	1.06	1.44	1.03	1.22	2.73	2.65
All Units	15.55	11.85	15.15	10.91	13.35	18.36	16.33	12.74	10.96	14.55	14.26	13.83

**NO<sub>x</sub> emissions: kilotons emitted per month, measured with the continuous emission monitoring system. NOTE: These are unverified values for information purposes only.**

	JUN 2017	JUL 2017	AUG 2017	SEP 2017	OCT 2017	NOV 2017	DEC 2017	JAN 2018	FEB 2018	MAR 2018	APR 2018	MAY 2018
Units 1-3	2.65	3.04	3.78	3.57	3.48	5.98	5.03	3.26	2.98	3.78	2.82	2.47
Unit 4	1.03	0.85	1.81	0.87	1.84	1.53	1.52	0.98	1.30	1.26	1.01	0.84
Unit 5	1.30	1.16	2.41	0.68	1.35	1.41	1.35	1.43	1.32	1.28	1.06	1.02
Unit 6	1.38	0.99	Off	Off	Off	0.07	0.54	0.79	0.55	0.63	1.25	1.10
All Units	6.35	6.04	8.01	5.12	6.66	8.99	8.44	6.46	6.15	6.95	6.15	5.43

**CO<sub>2</sub> emissions (mg/Nm<sup>3</sup>): Average concentration per month (at 273 K, 101.3 kPa and 10% O<sub>2</sub>), measured with the continuous emission monitoring system. NOTE: These are unverified values for information purposes only**

	JUN 2017	JUL 2017	AUG 2017	SEP 2017	OCT 2017	NOV 2017	DEC 2017	JAN 2018	FEB 2018	MAR 2018	APR 2018	MAY 2018
Units 1-3												
Unit 4												
Unit 5												
Unit 6												

**SO<sub>2</sub> emissions (mg/Nm<sup>3</sup>): Average concentration per month (at 273 K, 101.3 kPa and 10% O<sub>2</sub>), measured with the continuous emission monitoring system. NOTE: These are unverified values for information purposes only**

Limit	JUN 2017	JUL 2017	AUG 2017	SEP 2017	OCT 2017	NOV 2017	DEC 2017	JAN 2018	FEB 2018	MAR 2018	APR 2018	MAY 2018
4000												
Units 1-3	1671	1582	1875	2094	1831	2390	2127	1883	1587	2246	2036	2153
Unit 4	1938	1589	2112	1627	2023	1513	1447	1476	1350	1626	1628	1685
Unit 5	2003	1749	2562	1731	1966	2046	1906	1751	1827	1856	1850	1797
Unit 6	1508	1395	Off	Off	Off	1421	1385	1353	1406	1425	1540	1620

**SO<sub>2</sub> daily average emissions: AEL limit exceedances**

Limit	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY
3500	2017	2017	2017	2017	2017	2017	2017	2018	2018	2018	2018	2018
Units 1-3	0	0	0	0	0	0	0	0	0	0	0	0
Unit 4	0	0	0	0	0	0	0	0	0	0	0	0
Unit 5	0	0	0	0	0	0	0	0	0	0	0	0
Unit 6	0	0	0	0	0	0	0	0	0	0	0	0

**NO<sub>x</sub> emissions (mg/Nm<sup>3</sup>): Average concentration per month (at 273 K, 101.3 kPa and 10% O<sub>2</sub>), measured with the continuous emission monitoring system. NOTE: These are unverified values for information purposes only**

Limit	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY
1700	2017	2017	2017	2017	2017	2017	2017	2018	2018	2018	2018	2018
Units 1-3	763	760	932	956	838	1128	1074	858	851	1017	852	797
Unit 4	1326	1042	1313	914	1269	914	894	896	970	872	752	713
Unit 5	1109	915	1291	759	938	949	892	982	936	859	753	708
Unit 6	741	657	Off	Off	Off	682	705	751	751	740	711	674

**NO<sub>x</sub> daily average emissions: AEL limit exceedances**

Limit	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY
1200	2017	2017	2017	2017	2017	2017	2017	2018	2018	2018	2018	2018
Units 1-3	1	0	0	0	0	2	0	0	0	0	0	0
Unit 4	15	0	17	0	20	0	0	0	0	0	0	0
Unit 5	1	0	21	0	0	0	0	0	0	0	0	0
Unit 6	0	0	0	0	0	0	0	0	0	0	0	0

**4. PARTICULATE EMISSION PERFORMANCE**

	MONTH AVERAGE EMISSIONS	AEL LIMIT(DAILY AVERAGE)	HIGHEST DAILY AVERAGE
UNIT	mg/Nm <sup>3</sup>	mg/Nm <sup>3</sup>	mg/Nm <sup>3</sup>
1, 2 & 3	25.54	200	86.68
4	99.45	200	399.06
5	55.72	100	109.1
6	25.79	100	82.0
Station	51.63		
YTD	44.49		

**ABATEMENT APPARATUS AVAILABILITY**

Unit		1	2	3	4	5	6	Station
Precipitator efficiency	%	Off	99.84	99.84	99.70	99.80	99.89	99.82
Precipitator availability	%	Off	100.00	99.70	96.77	98.67	98.17	98.78
SO <sub>3</sub> plant utilisation	%	Off	99.09	99.46	100.00	99.78	100.00	99.19

## ATMOSPHERIC EMISSION LICENSE LIMIT EXCEEDED

	AEL LIMIT EXCEEDED (TOTAL)	AEL LIMIT EXCEEDED (LIGHT-UP/SHUT DOWN)	AEL LIMIT EXCEEDED (UPSET CONDITIONS)	AEL LIMIT EXCEEDED (MAINTENANCE)	AEL LIMIT EXCEEDED (SECTION 30 / CONTRAVENTION)
UNIT	Days	Days	Days	Days	Days
1, 2 & 3	0	0	0	0	0
4	4	0	3	1	0
5	1	0	1	0	0
6	0	0	0	0	0
Station	5	0	4	1	0
YTD	5	0	4	1	0

### 5. DISCUSSION

#### Unit 1:

Unit was taken off load on the 10<sup>th</sup> January 2018 for a major refurbishment outage.

#### Unit 2:

The flue gas conditioning plant performed well during the month and emissions well below the AEL limit was recorded for the month.

The SO<sub>3</sub> flue gas conditioning plant tripped several times during the month but most of the trips were of a short duration and the impact on the particulate emissions was limited.

#### Unit 3:

The flue gas conditioning plant performed well during the month and emissions well below the AEL limit was recorded for the month.

The unit experienced a few precipitator field failures during the month. The impact on the particulate emissions was minimal.

The unit tripped on the 15<sup>th</sup> May 2018 at 03:25 when the power supply to the right hand draught group tripped due to a control module failure. The unit returned to service on the 15<sup>th</sup> May 2018 at 13:38.

The unit tripped on the 18<sup>th</sup> May 2018 at 03:51 when the right hand ID fan motor failed. The unit returned to service on the 18<sup>th</sup> May 2018 at 08:41. The right hand draught group remained off load for replacement of the ID fan motor. The RH ID fan motor was replaced and returned to service on the 20<sup>th</sup> May 2018 at 04:41 and the unit loaded to full load.

Higher than normal particulate emissions were recorded for this period because the low load prohibited the SO<sub>3</sub> from being placed in service, but the emissions remained within the AEL limit.

The SO<sub>3</sub> flue gas conditioning plant tripped on the 26<sup>th</sup> May 2018 at 02:16 when the blower V-belts failed. The belts were replaced and the plant returned to service at 13:30 on the 26<sup>th</sup> May 2018.

#### **Unit 4:**

The unit experienced a few precipitator field failures during the month which resulted in an increase in particulate emissions. The coal quality deteriorated during this period resulting in hopper levels.

The SO<sub>3</sub> flue gas conditioning plant was taken off line on the 4<sup>th</sup> May 2018 at 09:50 for gas leak repairs. The plant returned to service at 16:45 on the same day. The daily average particulate emissions exceeded the AEL limit for the day.

The left hand precipitator fields tripped intermittently as from 16:30 on the 17<sup>th</sup> May 2018 due to field controller malfunctioning. Maintenance managed to place some fields in service but the emissions still remained above the AEL limit. The problem was eventually resolved by re-programming most of the controller e-proms, replacement of thyristors. The emissions reduced to levels below the AEL limit at 21:00 on the 19<sup>th</sup> May 2019. The AEL limit was exceeded for a period of 48hours.

The unit experienced precipitator field failures due to full hoppers as from the 26<sup>th</sup> May 2018. The emissions, however was managed well below the AEL limit.

#### **Unit 5:**

The unit experienced a few precipitator field failures during the month which resulted in an increase in particulate emissions. The coal quality deteriorated during this period resulting in hopper levels. With an already stressed plant the dust handling plant experienced trips due to low air pressure and blocked dust conveying lines and as a result the daily average emissions exceeded the AEL limit on the 23<sup>rd</sup> May 2018.

The unit also experienced a few SO<sub>3</sub> flue gas conditioning plant failures but these were of a short duration and the impact on the particulate emissions was limited.

The unit experienced several precipitator field failure due to full dust hoppers towards the end of the month. A gradual increase in emissions was noted.

#### **Unit 6:**

The unit was taken off load on the 30<sup>th</sup> April 2017 at 22:30 for maintenance to repair a leaking Spraywater valve. The unit returned to service on the 2<sup>nd</sup> May 2018 at 12:18. The opportunity was utilised to carry out minor precipitator repair.

The unit experienced a few precipitator field failures during the month which resulted in an increase in particulate emissions. The coal quality deteriorated during this period resulting in hopper levels.

#### **SO<sub>3</sub> common Plant:**

The SO<sub>3</sub> flue gas conditioning plant tripped on the 1<sup>st</sup> April 2018 at 12:55. All of the SO<sub>3</sub> plants were back in service by 15:00 on the same day.

#### **Gas Emissions:**

The south stack O<sub>2</sub> analyser reading remained high. The OEM established that the sensor is faulty. The procurement process to replace the sensor has commenced. The O<sub>2</sub> reading is thus calculated based on the O<sub>2</sub>/CO<sub>2</sub> balance.

The availability of the CEMS was good for the month of April 2018.

The gas emissions measured by the CEMS was well below the AEL limit for the duration of the month.

## General:

The coal quality supplied to boilers 5 and 6 remained poor during the month, impacting negatively on the particulate emissions.

The south smoke stack dust monitor correlation test was carried out from the 3<sup>rd</sup> to 12<sup>th</sup> April 2018. The correlation factors have been implemented as from the 1<sup>st</sup> April 2018.

## 6. LIGHT UP:

Unit:	6	
Fires in:	07:15	2 May 2018
Synchronisation:	12:18	2 May 2018
Emissions below Limit:	16:10	2 May 2018
Fires in to synchronisation:	5:03	Hours
Synchronisation to < Limit:	3:52	Hours

Unit:	3	
Fires in:	07:15	15 May 2018
Synchronisation:	13:38	15 May 2018
Emissions below Limit:	11:00	16 May 2018
Fires in to synchronisation:	6:23	Hours
Synchronisation to < Limit:	21:22	Hours

Unit:	3	
Fires in:	06:00	18 May 2018
Synchronisation:	08:41	18 May 2018
Emissions below Limit:	13:15	May 2018
Fires in to synchronisation:	2:41	Hours
Synchronisation to < Limit:	4:34	Hours

## 7. GRAPHS:

See attached graphs

## 8. COMPLAINTS

Name of complainant	Date	Description of complaint	Action taken
No Complaints			

9. NOTIFICATION OF CONTRAVENTION OF EMISSION LICENCE CONDITIONS


<i>Date</i>	
<i>Power Station Unit(s)</i>	Matla Power Station –
<i>Date of incident</i> <i>Time of incident</i>	Start date and time: End date:
<i>Nature of incident</i>	Extended start-up <input type="checkbox"/> On-line maintenance <input type="checkbox"/> Extended shut-down <input type="checkbox"/>
<i>Emission limit exceedance</i>	
<i>Details of incident</i>	
<i>Risks posed by the incident to public health, safety and property</i>	
<i>Toxicity of substance or by-products released by the incident</i>	
<i>Mitigation to avoid or minimize the incident effects on public health and the environment</i>	
<i>Compiler and contact details</i>	Name: Tel no: Email:
<i>Responsible manager and contact details</i>	Name: Tel no: Email:




## **BOILER PLANT ENGINEERING**

Copies to:     Licensing Authority  
                  Power Station Manager  
                  Environmental Practitioner  
                  Engineering Manager  
                  Boiler Plant Engineering Manager  
                  Maintenance Manager (Acting)  
                  Unit Electrical Maintenance Manager  
                  Operating Manager  
                  Production Manager  
                  Outside Plant Maintenance Manager  
                  Coal Manager  
                  Megawatt Park, Corporate Consultant Air Pollution  
                  Plant Performance Units 1 to 6


**MATLA POWER STATION**  
**UNIT 1 DUST EMISSION REPORT**  
**MAY 2018**




**MATLA POWER STATION**  
**UNIT 2 DUST EMISSION REPORT**  
**MAY 2018**




**MATLA POWER STATION  
UNIT 3 DUST EMISSION REPORT  
MAY 2018**




**MATLA POWER STATION  
UNIT 4 DUST EMISSION REPORT  
MAY 2018**




**MATLA POWER STATION  
UNIT 5 DUST EMISSION REPORT  
MAY 2018**



**MATLA POWER STATION  
UNIT 6 DUST EMISSION REPORT  
MAY 2018**




# MATLA POWER STATION PRECIPITATOR RELIABILITY MAY 2018






**MATLA POWER STATION  
SO<sub>3</sub> PLANT AVAILABILITY  
MAY 2018**



**MATLA POWER STATION**  
**SMOKE STACK SO<sub>2</sub> EMISSION REPORT**  
**MAY 2018**



**MATLA POWER STATION  
SMOKE STACK NO<sub>2</sub> EMISSION REPORT  
MAY 2018**

