



Generation

Nkangala District Municipality
P O Box 437
Middleburg
1050

Date: 2019/04/23

Attention:
Mr V Mahlangu

AND

Directorate: Air Quality Management Services
The Director:
Mr Vumile Senene
Department of Environmental Affairs
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

Total number of pages:
15

Total number of annexes:

MATLA POWER STATION

Atmospheric Emission License 17/4/AEL/MP312/11/14

BOILER ENGINEERING MANAGER

24/04/2019
Date

ENGINEERING MANAGER

24/04/2019
Date

ENVIRONMENTAL MANAGER

2019-04-24
Date

MONTHLY EMISSIONS REPORT FOR MATLA POWER STATION
 Atmospheric Emission License 17/4/AEL/MP312/1/1/14
 REPORTING MONTH March-2019

1 PARTICULATE EMISSIONS

EMISSION LIMIT: North U5 & U6: 100 mg/Nm³ South Stack: 200 mg/Nm³
 North U4: 200 mg/Nm³

2 GASEOUS EMISSIONS

EMISSION LIMIT: North Stack: South Stack
 NOx 1200 mg/Nm³ 1200 mg/Nm³
 SO₂ 3500 mg/Nm³ 3500 mg/Nm³

1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products used	Raw Material Type	Units	Maximum Permitted Consumption/ Rate (Quantity)	Consumption/ Rate March 2019
Fuel Oil	Tons/month	2 500	2069.01	
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of March-2019
	Energy	GWh	2566.8	1399
	Ash	Tons/month	471000	217697
	RE PM	kg/MWh	not specified	1.038


2 ABATEMET TECHNOLOGY

Associated Unit/Stack	Technology Type	Efficiency (%) for Mar-2019	Reliability (%) March-2019			
			PM	SO ₂	NO	CO ₂
South Stack	ESP	99.2%	56.4	68.7	99.7	
Unit 4	ESP	98.7%	76.0	92.3	92.6	
Unit 5	ESP	OFF	OFF	OFF	OFF	
Unit 6	ESP	99.8%	100.0	80.4	80.7	

3 ENERGY SOURCE CHARACTERISTICS

Characteristic	Stipulated Range (Unit)	Monthly Average Content
CV Content	16-24 (MJ/kg)	
Sulphur Content	0.8-1.1 (%)	1.00
Ash Content	21-40 (%)	28.32

4 EMISSION PERFORMANCE






Figure 2. PM emissions (daily averages) for the month of March-2019 against emission limit for Unit 4




Figure 3. PM emissions (daily averages) for the month of March-2019 against emission limit for Unit 5




Figure 4. PM emissions (daily averages) for the month of March-2019 against emission limit for Unit 6




Figure 5. SO_x emissions (daily averages) for the month of March-2019 against emission limit for the South Stack




Figure 6. SO₂ emissions (daily averages) for the month of March-2019 against emission limit for Unit 4




Figure 7. SO₂ emissions (daily averages) for the month of March-2019 against emission limit for Unit 5




Figure 8. SO₂ emissions (daily averages) for the month of March-2019 against emission limit for Unit 6




Figure 9. NOx emissions (daily averages) for the month of March-2019 against emission limit for the South Stack




Figure 10. NOx emissions (daily averages) for the month of March-2019 against emission limit for Unit 4




Figure 11. NOx emissions (daily averages) for the month of March-2019 against emission limit for Unit 5




Figure 12. NOx emissions (daily averages) for the month of March-2019 against emission limit for Unit 6

Table 4: Monthly tonnages for the month of March-2019

Unit	PM (tons)	SO ₂ (tons)	NO ₂ (tons)	CO ₂ (tons)
1	285.1	2 092.4	842.3	
2	403.1	3 824.3	1 551.6	
3	313.6	3 031.6	1 230.7	
4	350.1	1 305.5	931.3	
5	0.0	0.0	0.0	
6	100.1	2 898.0	1 078.5	
SUM	1 452.0	13 151.8	5 634.4	

Table 5: Each unit and respective days operating under normal operation, days in grace period, and section 30 days respectively

Unit	Normal operation	Operating Days (DD:HH:MM)			Unit off load
		In grace period	Under S 30		
1	14:13:10	02:00:00	04:09:00	10:01:50	
2	31:00:00	00:00:00	00:00:00	00:00:00	
3	26:12:05	00:00:00	00:00:00	04:11:55	
4	00:12:40	06:00:00	10:12:00	13:23:20	
5	00:00:00	00:00:00	00:00:00	31:00:00	
6	25:11:05	00:00:00	00:00:00	05:12:55	

5 LIGHT UP INFORMATION

Table 6. PM Start-up information for the month of March-2019

South Stack Unit No.	Event 1	Event 2	Event 3	Event 4	Event 5
Fires in Synch. to Grid	no event	no event			
Emissions > limit from Synch. (Date and Time)					
Fires in to Synch. Emissions < limit from Synch. (Duration)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)
	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)
	no event	no event	no event	no event	no event

South Stack ...cont.	Event 6	Event 7	Event 8	Event 9	Event
Unit No.	no event	no event	no event	no event	no e
Fires in					
Synch. to Grid					
Emissions > limit from Synch. (Date and Time)					
Fires in to Synch.	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	
Emissions < limit from Synch. (Duration)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	

Event No.	Event 1	Event 2	Event 3	Event 4	Event 5
Unit No.4	no event	no event	no event	no event	no event
Fires in					
Synch. to Grid					
Emissions > limit from Synch. (Date and Time)					
Fires in to Synch.	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	
Emissions < limit from Synch. (Duration)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	

Event No.	Event 1	Event 2	Event 3	Event 4	Event 5
Unit No.5	no event	no event	no event	no event	no event
Fires in					
Synch. to Grid					
Emissions > limit from Synch. (Date and Time)					
Fires in to Synch.	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	
Emissions < limit from Synch. (Duration)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	

Event No.	Event 1	Event 2	Event 3	Event 4	Event 5
Unit No.6	no event	no event	no event	no event	no event
Fires in					
Synch. to Grid					
Emissions > limit from Synch. (Date and Time)					
Fires in to Synch.	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	
Emissions < limit from Synch. (Duration)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	Hrs (dd:hh:mm)	

Table 7. Point Source emissions released during start-up (fires-in) for the month of March-2019 in mg/Nm³

Unit	South Stack Emission Average from Fires-in to Synchronisation (Date and Time)			
	Fires-in	Synchronisation	PM	NO _x
Unit 1	2019/03/22	2019/03/23	09:15 AM	289.0
Unit 3	2019/03/21	2019/03/21	03:05 PM	300.6
Unit 3	2019/03/28	2019/03/28	11:35 PM	298.6
no event				
no event				
no event				
no event				
no event				
no event				
no event				

North Stack Emission Average from Fires-in to Synchronisation (Date and Time).

Unit	North Stack Emission Average from Fires-in to Synchronisation (Date and Time)			
	Fires-in	Synchronisation	PM	NO _x
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				
no event				

Table 8. Point Source emissions released during Shut-down (SD) for the month of March-2019 in mg/Nm³

Unit	South Stack Emission Average Breaker Open (BO) to Draught Group Shut Down (SD) (Date & Time)			
	Breaker Open	DG SD	PM	NO _x
Unit 1	2019/03/13	2019/03/14	10:15 PM	289.0
Unit 3	2019/03/21	2019/03/21	09:25 AM	300.6

6 EMERGENCY GENERATION

Emergency Generation *[This is only required for stations that are requested to report on this information]*

Table 8. Emergency Generation per unit for the month of March-2019

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control						
Emergency Hours declared including hours after stand down						
Hours over the Limit during Emergency Generation						

7 COMPLAINTS REGISTER

Table 9. Complaints for the month of March-2019

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with	Dispersion modeling of pollutants where	Measures implemented to prevent reoccurrence	Date by which will be implemented
<i>(Insert name of affected person/source)</i>	<i>(Insert root cause for incident)</i>	<i>(Insert emissions associated with incident)</i>	<i>(Insert dispersion model information where applicable)</i>	<i>(Insert mitigation measures taken)</i>	<i>(Insert implementer mitigation)</i>

8 General

CO2 and O2 values needs to be verified and this investigation is in progress. If there are deviations after completion of the investigation corrections will be effected and re-report. There are two section 30, one for South Stack caused by underperforming Unit 1 and Unit 4. These section 30s are already reported.

Boiler Plant Engineering _____ Date _____ Environmental Practitioner _____ Date _____

General Manager _____ Date _____

Compiled by: Boiler Engineering Department

For: Department of Environmental Affairs and Tourism

Copies: Eskom Environmental Management

Group Technology Engineering

Matla Power Station:

ESP & SO₃ System Engineer
Chief Air Pollution Control Officer

Engineering Manager
Operating Manager
Maintenance Manager
Boiler Engineering Manager
System Engineer
Environmental Manager
Performance and Test Manager
Production Managers