

MATLA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/14



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Mar-2020
	Coal	Tons	1 475 000	891 587
	Fuel Oil	Tons	2 500	1 103

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Mar-2020
	Energy	GWh	2 567	1 777
	Ash	Tons	471 000	233 061
	RE PM	kg/MWh	not specified	0,571

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	16-24	20,49
Sulphur Content	%	0.8-1.1	1,00
Ash Content	%	21-40	26,14

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO
South	200	3500	1200
Unit 4	200	3500	1200
Unit 5	100	3500	1200
Unit 6	100	3500	1200

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Mar-2020
South	<i>Electro Static Precipators (ESP)</i>	<i>99,609%</i>
Unit 4	<i>Electro Static Precipators (ESP)</i>	<i>99,253%</i>
Unit 5	<i>Electro Static Precipators (ESP)</i>	<i>99,646%</i>
Unit 6	<i>Electro Static Precipators (ESP)</i>	<i>99,301%</i>

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	PM	SO ₂	NO	CO ₂	O ₂
South	<i>95,2</i>	<i>57,4</i>	<i>57,7</i>	<i>53,9</i>	<i>38,7</i>
Unit 4	<i>87,6</i>	<i>99,9</i>	<i>99,9</i>	<i>86,7</i>	<i>99,9</i>
Unit 5	<i>78,8</i>	<i>85,1</i>	<i>85,1</i>	<i>85,1</i>	<i>85,1</i>
Unit 6	<i>92,6</i>	<i>80,8</i>	<i>80,8</i>	<i>80,8</i>	<i>48,9</i>

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of March-2020

Associated Unit/Stack	PM	SO _x	NO _x	
Unit 1	158,8	3 679,0	1 001,7	
Unit 2	139,0	3 341,6	910,2	
Unit 3	140,3	2 750,2	733,6	
Unit 4	288,4	2 619,7	1 863,5	
Unit 5	127,7	2 863,6	840,3	
Unit 6	160,1	2 892,7	1 021,5	
SUM	1 014,3	18 146,8	6 371,0	

Table 6.2: Operating days in compliance to PM AEL Limit - March 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contra- vention	Total Exceedance	Average PM (mg/Nm ³)
South	30	1	0	0	1	89,4
Unit 4	19	7	0	0	7	174,9
Unit 5	22	6	1	0	7	102,4
Unit 6	24	6	1	0	7	106,5
SUM	95	20	2	0	22	

Table 6.3: Operating days in compliance to SOx AEL Limit - March 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contra- vention	Total Exceedance	Average SOx (mg/Nm ³)
South	31	0	0	0	0	2 121,0
Unit 4	27	0	0	0	0	1 598,7
Unit 5	29	0	0	0	0	1 913,5
Unit 6	31	0	0	0	0	1 815,0
SUM	118	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - March 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contra- vention	Total Exceedance	Average NOx (mg/Nm ³)
South	31	0	0	0	0	577,4
Unit 4	19	0	0	8	8	1 136,5
Unit 5	29	0	0	0	0	562,8
Unit 6	31	0	0	0	0	648,6
SUM	110	0	0	8	8	

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contra- vention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Matla South Stack PM Emissions - March 2020




Figure 2: Matla Unit 4 PM Emissions - March 2020




Figure 3: Matla Unit 5 PM Emissions - March 2020




Figure 4: Matla Unit 6 PM Emissions - March 2020




Figure 5: Matla South Stack SOx Emissions - March 2020




Figure 6: Matla Unit 4 SOx Emissions - March 2020




Figure 7: Matla Unit 5 SOx Emissions - March 2020




Figure 8: Matla Unit 6 SOx Emissions - March 2020




Figure 9: Matla South Stack NOx Emissions - March 2020




Figure 10: Matla Unit 4 NOx Emissions - March 2020




Figure 11: Matla Unit 5 NOx Emissions - March 2020





Figure 12: Matla Unit 6 NOx Emissions - March 2020



7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1. PM Start-up information for the month of March-2020

South Stack	<i>Event 1</i>		<i>Event 2</i>		<i>Event 3</i>		<i>Event 4</i>	
Unit No.	<i>no event</i>		<i>no event</i>		<i>Unit 3</i>		<i>no event</i>	
Breaker Open (BO)					<i>5:20 AM</i>	<i>2020/03/23</i>		
Draught Group (DG) Shut Down (SD)					<i>3:10 AM</i>	<i>2020/03/24</i>		
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM	<i>00:21:50</i>	DD:HH:MM		DD:HH:MM
Fires in time					<i>8:30 PM</i>	<i>2020/03/29</i>		
Synch. to Grid (or BC)					<i>9:10 AM</i>	<i>2020/03/30</i>		
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM	<i>00:12:40</i>	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)					<i>not > limit</i>	<i>not > limit</i>		
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM	<i>n/a</i>	DD:HH:MM		DD:HH:MM

South Stack ...cont.	<i>Event 5</i>		<i>Event 6</i>		<i>Event 7</i>		<i>Event 8</i>	
Unit No.	<i>no event</i>		<i>no event</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 4	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	5:40 AM	2020/03/03						
Synch. to Grid (or BC)	11:40 AM	2020/03/05						
Fires in to BC (duration)	02:06:00	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit						
Emissions below limit from BC (duration)	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 5	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	3:40 PM	2020/03/11	9:00 AM	2020/03/29				
Draught Group (DG) Shut Down (SD)	3:40 PM	2020/03/11	9:00 AM	2020/03/29				
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	3:40 PM	2020/03/11						
Synch. to Grid (or BC)	8:40 PM	2020/03/11						
Fires in to BC (duration)	00:05:00	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit						
Emissions below limit from BC (duration)	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 6	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM


7.2: Point Source emissions released during start-up (fires-in) and Shut-down (SD) for the month of March-2020 in mg/Nm³


[Include reference to once off test showing typical emissions rates during fires in and SD]


Remember to add attachments here; see ReportAddendum Tab

Reserved for Addendum XXXX

11 General


Boiler Engineering 05-05-2020
Date


Environmental Department 2020-05-05
Date


General Manager 05/05/2020
Date

Compiled by Boiler Engineering Department

ESP & SO₃ System Engineer

For: Department of Environmental Affairs and Tourism

Chief Air Pollution Control Officer

Copies: Eskom Environmental Management

D Herbst
B Mccourt

Group Technology Engineering

R Rampiar
E. Patel

Matla Power Station:

Engineering Manager
Operating Manager
Maintenance Manager
Unit Production Manager
Boiler Engineering Manager
System Engineer
Environmental Officer
Performance and Test
Production Manager