

**MATLA POWER STATION MONTHLY EMISSIONS REPORT**

Atmospheric Emission License 17/4/AEL/MP312/11/14


**1 RAW MATERIALS AND PRODUCTS**

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate May-2020
	Coal	Tons	1 475 000	804 488
	Fuel Oil	Tons	2 500	622
Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate May-2020
	Energy	GWh	2 567	1 456
	Ash	Tons	471 000	220 993
	RE PM	kg/MWh	not specified	0,625

**2 ENERGY SOURCE CHARACTERISTICS**

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.8-1.1	1,00
Ash Content	%	21-40	27,47

### 3 EMISSION LIMITS (mg/Nm<sup>3</sup>)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO
South	200	3500	1200
Unit 4	200	3500	1200
Unit 5	100	3500	1200
Unit 6	100	3500	1200

### 4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency May-2020
South	Electro Static Precipators (ESP)	99,531%
Unit 4	Electro Static Precipators (ESP)	99,297%
Unit 5	Electro Static Precipators (ESP)	99,573%
Unit 6	Electro Static Precipators (ESP)	99,760%

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

### 4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	O <sub>2</sub>
South	99,7	19,4	19,4	19,4
Unit 4	89,7	99,6	99,6	97,4
Unit 5	78,8	99,3	99,5	98,4
Unit 6	99,5	86,6	86,0	86,3

### 6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of May-2020

Associated Unit/Stack	PM	SO <sub>x</sub>	NO <sub>x</sub>
Unit 1	190,5	2 943,9	1 011,3
Unit 2	0,0	0,0	0,0
Unit 3	201,4	2 996,4	1 035,1
Unit 4	275,5	4 419,5	1 259,7
Unit 5	136,8	2 374,9	906,2
Unit 6	105,6	3 112,2	1 251,1
<b>SUM</b>	<b>909,9</b>	<b>15 846,9</b>	<b>5 463,3</b>

Table 6.2: Operating days in compliance to PM AEL Limit - May 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm³)
South	26	4	1	0	5	117,8
Unit 4	21	7	2	0	9	160,7
Unit 5	21	4	2	0	6	87,7
Unit 6	25	6	0	0	6	65,7
SUM	93	21	5	0	26	

Table 6.3: Operating days in compliance to SOx AEL Limit - May 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm³)
South	31	0	0	0	0	1 829,7
Unit 4	30	0	0	0	0	2 603,9
Unit 5	27	0	0	0	0	1 607,3
Unit 6	31	0	0	0	0	1 927,4
SUM	119	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - May 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
South	31	0	0	0	0	630,5
Unit 4	30	0	0	0	0	733,4
Unit 5	27	0	0	0	0	613,5
Unit 6	31	0	0	0	0	772,6
SUM	119	0	0	0	0	

Table 6.5: Legend Description





Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Matla South Stack PM Emissions - May 2020




Figure 2: Matla Unit 4 PM Emissions - May 2020






Figure 3: Matla Unit 5 PM Emissions - May 2020




Figure 4: Matla Unit 6 PM Emissions - May 2020




Figure 5: Matla South Stack SO<sub>x</sub> Emissions - May 2020




Figure 6: Matla Unit 4 SO<sub>x</sub> Emissions - May 2020




Figure 7: Matla Unit 5 SOx Emissions - May 2020




Figure 8: Matla Unit 6 SOx Emissions - May 2020




Figure 9: Matla South Stack NOx Emissions - May 2020




Figure 10: Matla Unit 4 NOx Emissions - May 2020






Figure 11: Matla Unit 5 NOx Emissions - May 2020





Figure 12: Matla Unit 6 NOx Emissions - May 2020



## 7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1. PM Start-up information for the month of May-2020

South Stack	Event 1		Event 2		Event 3		Event 4	
Unit No.	Unit 3		no event		no event		no event	
Breaker Open (BO)	5:40 PM	2020/05/13						
Draught Group (DG) Shut Down (SD)	8:40 PM	2020/05/13						
BO to DG SD (duration)	00:03:00	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	9:50 PM	2020/05/13						
Synch. to Grid (or BC)	6:10 AM	2020/05/14						
Fires in to BC (duration)	00:08:20	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	12:00 AM	2020/05/19						
Emissions below limit from BC (duration)	04:17:50	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

South Stack ...cont.	Event 5		Event 6		Event 7		Event 8	
Unit No.	no event		no event		no event		no event	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 4	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	9:55 PM	2020/05/16						
Draught Group (DG) Shut Down (SD)	9:55 PM	2020/05/16						
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	9:55 PM	2020/05/16						
Synch. to Grid (or BC)	1:05 AM	2020/05/18						
Fires in to BC (duration)	01:03:10	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit						
Emissions below limit from BC (duration)	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 5	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	10:45 PM	2020/05/04						
Synch. to Grid (or BC)	8:45 AM	2020/05/05						
Fires in to BC (duration)	00:10:00	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit						
Emissions below limit from BC (duration)	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 6	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

7.2: Point Source emissions released during start-up (fires-in) and Shut-down (SD) for the month of May-2020 in mg/Nm<sup>3</sup>

[Include reference to once off test showing typical emissions rates during fires in and SD]


Remember to add attachments here; see ReportAddendum Tab


Reserved for Addendum XXXX




# 11 General

Gases emission monitors were defective and the station is engaging original equipment manufacturer

  
Boiler Engineering 13-07-2020  
Date

  
General Manager  
Date

  
Environmental Department 2020-07-13  
Date

Compiled by: Boiler Engineering Department

For: Department of Environmental Affairs and Tourism

Copies: Eskom Environmental Management

Group Technology Engineering

Matla Power Station:

ESP & SO<sub>3</sub> System Engineer

Chief Air Pollution Control Officer

D Herbst  
B Mccourt

R Rampiar  
E. Patel

Engineering Manager  
Operating Manager  
Maintenance Manager  
Unit Production Manager  
Boiler Engineering Manager  
System Engineer  
Environmental Officer  
Performance and Test  
Production Manager

