

Ian Geldenhuys
 Air Quality Management
 246 Voortrekker Road
 Vasco
 7460

Date:
 04 Mar 2021

Enquiries:
 021 941 5856

Ref: ANK/2021/02

Dear Ian

ANKERLIG POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF February 2021

This serves as the monthly report required in terms of Section 9 in Ankerlig Power Station's Atmospheric Emission License (WCCT036). The emissions are for the month of February, these being SO₂, CO₂, PM and NO_x (as NO₂).

1 Raw Materials and Products

Table 1. Quantity of Raw Materials and Products used/produced for the month of February 2021.

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Total consumption in Month of February
	Fuel Diesel	Tons/hour/unit	40	39 752 874.56 L
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted per unit (MW)	Total production/Power sent out in Month of February
	Energy	MWh	170 MW per hour per unit	124 788.48
	Fuel use per hour per unit (L)		Fuel efficiency Litres per MWH	
	<i>Unit 11: 38 001.67</i> <i>Unit 12: 38 036.16</i> <i>Unit 21: 35 960.59</i> <i>Unit 22: 36 530.21</i> <i>Unit 31: 38 268.51</i> <i>Unit 32: 36 193.66</i> <i>Unit 41: 35 322.63</i> <i>Unit 42: 36 151.95</i> <i>Unit 43: 37 902.95</i>		<i>Unit 11: 316.12</i> <i>Unit 12: 323.27</i> <i>Unit 21: 312.72</i> <i>Unit 22: 321.87</i> <i>Unit 31: 321.22</i> <i>Unit 32: 322.19</i> <i>Unit 41: 311.71</i> <i>Unit 42: 316.88</i> <i>Unit 43: 315.93</i>	

2 Abatement Technology

Table 2. Abatement Equipment Control Technology availability for the month of February 2021

Associated Unit	Technology Type	Actual Utilisation (%) for the month of February
Unit 11	Low NOx burners	100%
Unit 12	Low NOx burners	100%
Unit 21	Low NOx burners	100%
Unit 22	Low NOx burners	100%
Unit 31	Low NOx burners	100%
Unit 32	Low NOx burners	100%
Unit 41	Low NOx burners	100%
Unit 42	Low NOx burners	100%
Unit 43	Low NOx burners	100%

Table 3: Tonnages and mg/Nm³ for the month of February 2021

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
Unit 11					
	2021/02/24 20:00	9	154	0	0.2
	2021/02/24 19:00	9	156	0	0.1
	2021/02/24 18:00	7.1	158	0	0.1
	2021/02/22 20:00	24.7	119	0	79.6
	2021/02/22 19:00	25.1	120	0	79.5
	2021/02/22 18:00	24.6	119	0	79.6
	2021/02/22 17:00	23.8	119	0	79.5
	2021/02/22 16:00	23.4	121	0	79.6
	2021/02/22 15:00	22.8	121	0	79.4
	2021/02/22 14:00	21.1	121	0	78.8
	2021/02/22 13:00	19.4	120	0	78.6
	2021/02/22 12:00	17.6	118	0	78.4
	2021/02/22 11:00	16.1	116	0	78.1
	2021/02/21 23:00	19.9	116	0	78.4
	2021/02/21 22:00	20.9	118	0	79.5
	2021/02/21 21:00	22.6	120	0	80.4
	2021/02/21 20:00	24.9	124	0	82.6
	2021/02/21 19:00	25.2	126	0	83.3
	2021/02/21 18:00	24.4	126	0	83.4
	2021/02/21 17:00	22.7	121	0	81.4
	2021/02/21 16:00	22.7	100	0	85.5
	2021/02/21 15:00	21.5	108	0	83.7
	2021/02/21 14:00	20.1	119	0	80.5
	2021/02/21 13:00	19.3	118	0	80.6
	2021/02/21 12:00	17.8	116	0	80

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/09 22:00	25.7	116	0	69
	2021/02/09 21:00	28.4	120	0	71.2
	2021/02/09 20:00	31	125	0	73
	2021/02/09 19:00	31.2	127	0	73.4
	2021/02/09 18:00	30.3	126	0	73.3
	2021/02/09 17:00	29.3	125	0	73.2
	2021/02/09 16:00	28	126	0	72.9
	2021/02/09 15:00	27.2	124	0	72.6
	2021/02/09 14:00	26	124	0	72.4
	2021/02/09 13:00	24.3	123	0	71.5
	2021/02/09 12:00	22.9	119	0	71.1
	2021/02/09 11:00	20.9	116	0	69.9
	2021/02/09 10:00	19.2	112	0	69.3
	2021/02/09 09:00	18.5	99	0	71
	2021/02/09 08:00	17.7	100	0	70.3
	2021/02/09 07:00	17.4	110	0	68.5
	2021/02/08 23:00	22.5	115	0	72.7
	2021/02/08 22:00	24.1	120	0	73.6
	2021/02/08 21:00	26.2	123	0	74.8
	2021/02/08 20:00	28	127	0	76
	2021/02/08 19:00	27.1	127	0	75.6
	2021/02/08 18:00	25.4	125	0	75.1
	2021/02/08 17:00	23.8	124	0	75.3
	2021/02/08 16:00	22.5	124	0	75.4
	2021/02/08 15:00	21.2	123	0	75.1
	2021/02/08 14:00	20.1	124	0	75.3
	2021/02/08 13:00	19.5	123	0	75.1
	2021/02/05 12:00	23.2	128	0	73.8
	2021/02/05 11:00	22.2	127	0	73.4
	2021/02/05 10:00	20.3	123	0	72.1
	2021/02/05 09:00	19.4	121	0	72.3
	2021/02/05 08:00	18.9	121	0	72.3
	2021/02/05 07:00	18.4	122	0	72.5
	2021/02/05 06:00	17.4	120	0	71.5
	2021/02/05 05:00	16.7	119	0	71.2
	2021/02/02 22:00	27.4	139	0	76.3
	2021/02/02 21:00	30.7	147	0	78.9
	2021/02/02 20:00	34	152	0	80.8
	2021/02/02 19:00	33.6	156	0	80.7
	2021/02/02 18:00	32.4	156	0	80.6
	2021/02/02 17:00	31	157	0	80.3
	2021/02/02 16:00	28.8	155	0	79.9

	Date/Time	CO (mg/Nm3)	NOx (mg/Nm3)	PM (mg/Nm3)	SO ₂ (mg/Nm3)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/02 15:00	26.2	152	0	78.6
	2021/02/02 14:00	23.3	149	0	77.8
	2021/02/02 13:00	21	146	0	77.5
Unit 12					
	2021/02/24 21:00	1.6	161	0	0.1
	2021/02/24 20:00	1	162	0	0.1
	2021/02/24 19:00	0.7	164	0	0.1
	2021/02/24 18:00	0.8	165	0	0.1
	2021/02/24 17:00	1.1	162	0	0.1
	2021/02/23 20:00	1.6	149	0	0.1
	2021/02/23 19:00	1.2	154	0	0.1
	2021/02/23 18:00	1.5	153	0	0.1
	2021/02/22 21:00	1.4	162	0	0.1
	2021/02/22 20:00	2.1	162	0	1.8
	2021/02/22 19:00	2.4	161	0	3.6
	2021/02/22 18:00	2.3	160	0	1.8
	2021/02/22 17:00	2.1	162	0	1.2
	2021/02/22 16:00	2	167	0	0.2
	2021/02/22 15:00	2.1	169	0	0.4
	2021/02/22 14:00	1.8	172	0	0.5
	2021/02/22 13:00	1.7	170	0	0.1
	2021/02/22 12:00	1	174	0	0.1
	2021/02/22 11:00	1.4	175	0	0.1
	2021/02/21 23:00	1.3	160	0	1.1
	2021/02/21 22:00	1.2	162	0	0.5
	2021/02/21 21:00	1.4	162	0	0.3
	2021/02/21 20:00	2.1	165	0	1.4
	2021/02/21 19:00	2	166	0	0.7
	2021/02/21 18:00	1.8	166	0	0.3
	2021/02/21 17:00	1.7	163	0	0.1
	2021/02/21 16:00	1.7	164	0	0.1
	2021/02/21 15:00	1.6	165	0	0.1
	2021/02/21 14:00	1.7	164	0	0.1
	2021/02/21 13:00	1.8	160	0	0.1
	2021/02/21 12:00	1.3	165	0	0.1
	2021/02/21 11:00	1.3	172	0	0.1
	2021/02/21 10:00	2.2	169	0	0.1
	2021/02/20 12:00	0.7	167	0	0.1
	2021/02/20 11:00	0.1	172	0	0.1
	2021/02/20 10:00	0.3	170	0	0.1
	2021/02/13 22:00	1.2	128	0	0.1

	Date/Time	CO (mg/Nm3)	NOx (mg/Nm3)	PM (mg/Nm3)	SO ₂ (mg/Nm3)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/13 21:00	1.4	129	0	0.1
	2021/02/13 20:00	1.7	130	0	0.6
	2021/02/13 19:00	1.9	133	0	1
	2021/02/13 18:00	1.8	133	0	0.9
	2021/02/13 17:00	1.7	132	0	0.4
	2021/02/13 16:00	1.6	125	0	0.1
	2021/02/13 15:00	2.1	120	0	0.1
	2021/02/13 14:00	0.9	133	0	0.1
	2021/02/13 13:00	1.1	130	0	0.1
	2021/02/12 23:00	1.9	128	0	0.5
	2021/02/12 22:00	1.7	133	0	0.2
	2021/02/12 21:00	1.7	136	0	0.2
	2021/02/12 20:00	1.1	142	0	0.2
	2021/02/12 19:00	1	145	0	0.1
	2021/02/12 18:00	1.4	142	0	0.1
	2021/02/11 23:00	0.5	128	0	0.1
	2021/02/11 22:00	0.8	129	0	0.1
	2021/02/11 21:00	1.4	132	0	0.1
	2021/02/11 20:00	2.2	136	0	0.1
	2021/02/11 19:00	2.4	137	0	0.1
	2021/02/11 18:00	2.2	138	0	0.3
	2021/02/11 17:00	1.9	138	0	0.9
	2021/02/11 16:00	1.6	142	0	0.1
	2021/02/11 15:00	1.7	144	0	0.1
	2021/02/11 14:00	1.4	145	0	0.1
	2021/02/11 13:00	1.4	146	0	0.1
	2021/02/11 12:00	1.3	149	0	0.4
	2021/02/11 11:00	1.2	149	0	0.5
	2021/02/11 10:00	1.5	148	0	0.4
	2021/02/10 21:00	1.2	127	0	0.1
	2021/02/10 20:00	2.4	127	0	1
	2021/02/10 19:00	4.2	92	0	2.1
	2021/02/10 18:00	2.5	137	0	2.7
	2021/02/10 17:00	2.1	137	0	0.2
	2021/02/10 16:00	1.8	124	0	0.4
	2021/02/10 15:00	1.8	107	0	0.2
	2021/02/10 14:00	1.1	137	0	0.1
	2021/02/10 13:00	1	137	0	0.1
	2021/02/10 12:00	1.4	141	0	0.1
	2021/02/10 11:00	1.4	142	0	0.1
	2021/02/10 10:00	1.4	138	0	0.1
	2021/02/10 09:00	1.4	136	0	0.1

	Date/Time	CO (mg/Nm3)	NOx (mg/Nm3)	PM (mg/Nm3)	SO ₂ (mg/Nm3)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/10 08:00	1.6	137	0	0.1
	2021/02/10 07:00	1.6	139	0	0.1
	2021/02/10 06:00	3.1	141	0	0.3
	2021/02/09 22:00	0.8	126	0	0.1
	2021/02/09 21:00	1.1	127	0	0.1
	2021/02/09 20:00	1.3	129	0	0.1
	2021/02/09 19:00	1.5	130	0	0.1
	2021/02/09 18:00	1.3	130	0	0.3
	2021/02/09 17:00	1.1	127	0	0.1
	2021/02/09 16:00	1.8	132	0	3
	2021/02/09 15:00	2	132	0	4.3
	2021/02/09 14:00	1.7	134	0	1.4
	2021/02/09 13:00	1.8	135	0	1.7
	2021/02/09 12:00	1.8	139	0	1
	2021/02/09 11:00	1.8	139	0	1.8
	2021/02/09 10:00	1.6	136	0	1.3
	2021/02/09 09:00	1.4	133	0	0.5
	2021/02/09 08:00	0.8	129	0	0.3
	2021/02/09 07:00	0.6	129	0	0.1
	2021/02/09 06:00	0.7	129	0	0.1
	2021/02/08 23:00	0.9	127	0	0.1
	2021/02/08 22:00	1.1	129	0	0.1
	2021/02/08 21:00	1.4	131	0	0.2
	2021/02/08 20:00	1.6	133	0	3.5
	2021/02/08 19:00	1.5	135	0	2.2
	2021/02/08 18:00	1.3	134	0	0.9
	2021/02/08 17:00	1.3	134	0	1.5
	2021/02/08 16:00	1.6	134	0	0.6
	2021/02/08 15:00	1.6	137	0	0.2
	2021/02/08 14:00	1.4	138	0	0.1
	2021/02/08 13:00	1.5	141	0	0.1
	2021/02/08 12:00	1.2	146	0	0.1
	2021/02/08 11:00	1.4	147	0	0.1
	2021/02/07 22:00	1	141	0	0.1
	2021/02/07 21:00	1.3	143	0	0.1
	2021/02/07 20:00	1.1	149	0	0.1
	2021/02/07 19:00	1.5	152	0	0.1
	2021/02/06 12:00	0.6	88	0	0.1
	2021/02/06 11:00	0.3	96	0	0.1
	2021/02/06 10:00	1	138	0	0.1
	2021/02/05 16:00	1.2	118	0	0.1
	2021/02/05 15:00	1.1	106	0	0.1

	Date/Time	CO (mg/Nm ³)	NOx(mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/05 14:00	1.1	85	0	0.1
	2021/02/05 13:00	1.3	132	0	0.1
	2021/02/05 12:00	1.2	132	0	0.1
	2021/02/05 11:00	1.1	133	0	0.1
	2021/02/05 10:00	1.1	130	0	0.1
	2021/02/05 09:00	1.2	127	0	0.1
	2021/02/05 08:00	1.1	128	0	0.1
	2021/02/05 07:00	1.1	130	0	0.1
	2021/02/05 06:00	1.2	130	0	0.1
	2021/02/05 05:00	1.5	130	0	0.1
	2021/02/03 20:00	1	124	0	0.5
	2021/02/03 19:00	1	130	0	0.1
	2021/02/03 18:00	1.1	132	0	0.1
	2021/02/03 17:00	1.2	132	0	0.1
	2021/02/03 16:00	1.2	133	0	0.1
	2021/02/03 15:00	1.2	136	0	0.1
	2021/02/03 14:00	1.3	137	0	0.1
	2021/02/03 13:00	1.4	133	0	0.1
	2021/02/03 12:00	1.7	136	0	0.2
	2021/02/02 22:00	1	134	0	0.1
	2021/02/02 21:00	1.4	139	0	0.1
	2021/02/02 20:00	1.5	136	0	0.1
	2021/02/02 19:00	1.6	141	0	0.7
	2021/02/02 18:00	1.5	142	0	0.2
	2021/02/02 17:00	1.4	143	0	0.3
	2021/02/02 16:00	1.2	147	0	0.4
	2021/02/02 15:00	1	145	0	0.2
	2021/02/02 14:00	1	146	0	0.1
	2021/02/02 13:00	0.9	146	0	0.1
	2021/02/02 12:00	2	156	0	0.4
	2021/02/01 21:00	1.6	142	0	0.1
	2021/02/01 20:00	1.8	152	0	0.1
	2021/02/01 19:00	1.8	156	0	0.1
	2021/02/01 18:00	2.1	162	0	0.1
Unit 21					
	2021/02/24 20:00	2.1	144	0	0.3
	2021/02/24 19:00	1	144	0	0.4
	2021/02/24 18:00	1	147	0	0.3
	2021/02/24 17:00	1.6	149	0	0.3
	2021/02/22 20:00	2.5	152	0	0.3
	2021/02/22 19:00	1.3	151	0	0.4

	Date/Time	CO (mg/Nm ³)	NOx(mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/22 18:00	1	151	0	0.8
	2021/02/22 17:00	1.3	151	0	0.3
	2021/02/22 16:00	0.4	152	0	1
	2021/02/22 15:00	0.4	154	0	1.4
	2021/02/22 14:00	0.8	156	0	1
	2021/02/22 13:00	1.4	157	0	0.6
	2021/02/22 12:00	1	158	0	0.1
	2021/02/22 11:00	1.5	158	0	0.1
	2021/02/21 14:00	1.5	149	0	0.2
	2021/02/21 13:00	1.4	147	0	0.3
	2021/02/21 12:00	1.2	149	0	0.1
	2021/02/21 11:00	1.5	158	0	0.1
	2021/02/09 22:00	2.3	132	0	0.1
	2021/02/09 21:00	2	132	0	0.1
	2021/02/09 20:00	3	133	0	0.1
	2021/02/09 19:00	2.7	144	0	0.1
	2021/02/09 11:00	2.2	139	0	3.5
	2021/02/09 10:00	2.2	137	0	3
	2021/02/09 09:00	2.3	136	0	1.6
	2021/02/09 08:00	2.9	134	0	0.1
	2021/02/09 07:00	3	138	0	0.1
	2021/02/08 23:00	2.4	129	0	1.7
	2021/02/08 22:00	1.9	133	0	0.3
	2021/02/08 21:00	1.6	134	0	0.2
	2021/02/08 20:00	1.9	138	0	4
	2021/02/08 19:00	1.7	139	0	3.8
	2021/02/08 18:00	1.6	139	0	2.6
	2021/02/08 17:00	1.6	138	0	1.5
	2021/02/08 16:00	3.3	141	0	0.1
	2021/02/08 15:00	3	142	0	0.1
	2021/02/05 13:00	2	142	0	2.3
	2021/02/05 12:00	1.8	144	0	3.2
	2021/02/05 11:00	1.7	143	0	3.1
	2021/02/05 10:00	1.5	142	0	1.7
	2021/02/05 09:00	1.4	140	0	0.5
	2021/02/05 08:00	1.6	140	0	0.1
	2021/02/05 07:00	1.6	141	0	0.1
	2021/02/05 06:00	1.5	141	0	0.1
	2021/02/05 05:00	1.6	144	0	0.3
	2021/02/02 22:00	2.3	145	0	0.4
	2021/02/02 21:00	1.7	147	0	0.2
	2021/02/02 20:00	4	151	0	6.6

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/24 19:00	3.4	109	0.1	1.2
	2021/02/02 19:00	3.1	156	0	4.8
	2021/02/02 18:00	2.7	158	0	2.4
	2021/02/02 17:00	2.4	160	0	0.8
	2021/02/02 16:00	14.7	174	0	0.1
	2021/02/02 15:00	11.6	175	0	2
	2021/02/02 14:00	3.8	167	0	13.4
	2021/02/02 13:00	0.2	148	0	3.4
Unit 22					
	2021/02/24 21:00	3.5	111	0.1	0.6
	2021/02/24 20:00	4.1	112	0.1	0.7
	2021/02/24 18:00	3.3	111	0.1	0.7
	2021/02/24 17:00	3.6	113	0.1	1
	2021/02/22 21:00	3.3	104	0.1	2.2
	2021/02/22 20:00	4	105	0.1	2.8
	2021/02/22 19:00	5.1	117	0.1	1.1
	2021/02/22 18:00	5.1	117	0.1	0.8
	2021/02/22 17:00	4.9	118	0.1	0.7
	2021/02/22 16:00	4.7	121	0.1	0.6
	2021/02/22 15:00	5.4	117	0.1	0.9
	2021/02/22 14:00	5.2	118	0.1	1.1
	2021/02/22 13:00	4.8	119	0.1	0.6
	2021/02/22 12:00	4.4	118	0.1	0.6
	2021/02/22 11:00	3.7	125	0.1	3.3
	2021/02/21 23:00	1.9	85	0.1	0.2
	2021/02/21 22:00	2.2	85	0.1	0.2
	2021/02/21 21:00	2.7	86	0.1	0.3
	2021/02/21 20:00	3.5	87	0.1	0.9
	2021/02/21 19:00	4.7	85	0.1	2.1
	2021/02/21 18:00	4.5	89	0.1	1.1
	2021/02/21 17:00	4	115	0.1	0.6
	2021/02/21 16:00	3.9	114	0.1	0.8
	2021/02/21 15:00	4.4	117	0.1	2.1
	2021/02/21 14:00	4.3	116	0.1	2
	2021/02/21 13:00	4.3	115	0.1	2.1
	2021/02/21 12:00	4.1	116	0.1	1.8
	2021/02/21 11:00	2.6	118	0.1	1.6
	2021/02/21 10:00	3.3	121	0.1	2.7
	2021/02/20 12:00	3.8	114	0.1	1.1
	2021/02/20 11:00	2.3	118	0.1	0.7
	2021/02/20 10:00	2.2	120	0.1	0.8

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/13 22:00	3.7	101	0.1	0.1
	2021/02/13 21:00	4.2	103	0.1	0.1
	2021/02/13 20:00	4.8	104	0.1	0.1
	2021/02/13 19:00	4.6	103	0.1	1.4
	2021/02/13 18:00	4.6	104	0.1	1.1
	2021/02/13 17:00	4.9	106	0.1	1.4
	2021/02/12 23:00	3.1	95	0.1	1
	2021/02/12 22:00	3.4	96	0.1	0.7
	2021/02/12 21:00	3.8	98	0.1	0.8
	2021/02/12 20:00	4.6	100	0.1	1.5
	2021/02/12 19:00	4.2	107	0.1	1.4
	2021/02/12 18:00	4.8	111	0.1	1.8
	2021/02/11 22:00	0.3	100	0.1	0.1
	2021/02/11 21:00	1.7	102	0.1	0.1
	2021/02/11 20:00	3.8	105	0.1	0.1
	2021/02/11 19:00	6.8	103	0.1	3.5
	2021/02/11 18:00	6.2	104	0.1	2.7
	2021/02/11 17:00	5.2	107	0.1	1.6
	2021/02/09 22:00	2.1	96	0.1	1
	2021/02/09 21:00	2.8	96	0.1	1.2
	2021/02/09 20:00	3.8	99	0.1	2.1
	2021/02/09 19:00	5.4	112	0.1	2.5
	2021/02/09 12:00	5	106	0.1	1.6
	2021/02/09 11:00	5	107	0.1	1.7
	2021/02/09 10:00	4.5	106	0.1	1.6
	2021/02/09 09:00	4.3	105	0.1	1.6
	2021/02/09 08:00	4.2	105	0.1	1.2
	2021/02/09 07:00	2	102	0.1	0.1
	2021/02/09 06:00	2.2	102	0.1	0.1
	2021/02/09 05:00	3.2	106	0.1	0.5
	2021/02/08 23:00	2.1	105	0.1	0.1
	2021/02/08 22:00	2.2	106	0.1	0.1
	2021/02/08 21:00	2.8	107	0.1	0.1
	2021/02/08 20:00	3.7	110	0.1	0.2
	2021/02/08 19:00	5.4	105	0.1	3.8
	2021/02/08 18:00	5.1	104	0.1	3.5
	2021/02/08 17:00	4.9	103	0.1	3
	2021/02/08 16:00	4.3	104	0.1	2.4
	2021/02/08 15:00	2.7	104	0.1	0.1
	2021/02/08 14:00	2.3	106	0.1	0.1
	2021/02/08 13:00	3	111	0.1	0.3
	2021/02/05 13:00	4.9	109	0.1	0.5

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/05 12:00	4.8	111	0.1	0.5
	2021/02/05 11:00	5.8	110	0.1	1.6
	2021/02/05 10:00	5.6	108	0.1	1.5
	2021/02/05 09:00	5.3	108	0.1	1.1
	2021/02/05 08:00	5	109	0.1	1
	2021/02/05 07:00	2.6	104	0.1	0.1
	2021/02/05 06:00	2.7	105	0.1	0.1
	2021/02/05 05:00	3	107	0.1	0.2
	2021/02/03 17:00	5.9	114	0.1	1.4
	2021/02/03 16:00	5.3	114	0.1	0.8
	2021/02/03 15:00	3.7	111	0.1	0.5
	2021/02/03 14:00	3.9	115	0.1	0.8
	2021/02/02 22:00	0.2	103	0.1	0.1
	2021/02/02 21:00	1.4	107	0.1	0.2
	2021/02/02 20:00	3.3	109	0.1	1
	2021/02/02 19:00	8.1	121	0.1	4.6
	2021/02/02 18:00	7.4	122	0.1	3.7
	2021/02/02 17:00	6.3	123	0.1	2.6
	2021/02/02 16:00	5.1	123	0.1	1.6
	2021/02/02 15:00	4.4	117	0.1	1.8
	2021/02/02 14:00	3.9	118	0.1	1.3
	2021/02/02 13:00	3.7	120	0.1	1
	2021/02/01 21:00	1.4	112	0.1	0.1
	2021/02/01 20:00	2.6	115	0.1	0.2
	2021/02/01 19:00	5.6	120	0.1	4.5
Unit 31					
	2021/02/24 21:00	7.8	138	0	1
	2021/02/24 20:00	8	137	0	1.1
	2021/02/24 19:00	7.5	135	0	1
	2021/02/24 18:00	7.2	136	0	0.5
	2021/02/24 17:00	6.9	133	0	0.5
	2021/02/22 21:00	7.9	140	0	1.2
	2021/02/22 20:00	8	141	0	1.1
	2021/02/22 19:00	8.3	146	0	0.7
	2021/02/22 18:00	8.1	145	0	0.5
	2021/02/22 17:00	7.9	145	0	0.3
	2021/02/22 16:00	7.9	149	0	0.4
	2021/02/22 15:00	7.2	151	0.1	0.3
	2021/02/22 14:00	7.5	150	0.1	0.3
	2021/02/22 13:00	7.8	149	0	0.4
	2021/02/22 12:00	8.2	150	0	0.7

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/21 23:00	6.9	145	0	1.8
	2021/02/21 22:00	7	145	0	1.7
	2021/02/21 21:00	7	146	0	1.5
	2021/02/21 20:00	7.2	145	0	1.5
	2021/02/21 19:00	7.8	146	0	0.9
	2021/02/21 18:00	7.5	143	0	0.7
	2021/02/21 17:00	7.2	141	0	0.6
	2021/02/21 16:00	7	140	0	0.6
	2021/02/21 15:00	6.3	139	0.1	0.5
	2021/02/21 14:00	6.3	139	0.1	0.3
	2021/02/21 13:00	6.4	136	0	0.3
	2021/02/21 10:00	7	138	0	1.7
	2021/02/20 13:00	6.1	136	0	0.3
	2021/02/20 12:00	6	137	0	0.3
	2021/02/20 11:00	4.1	134	0	0.2
	2021/02/20 10:00	4.7	135	0	0.2
	2021/02/13 22:00	9.3	125	0	0.5
	2021/02/13 21:00	9.4	125	0	0.8
	2021/02/13 20:00	9.5	125	0	1
	2021/02/13 19:00	9.6	127	0	0.7
	2021/02/13 18:00	9.6	127	0	0.7
	2021/02/13 17:00	9.5	127	0	0.5
	2021/02/13 16:00	9.7	115	0	0.4
	2021/02/13 15:00	8.7	122	0.1	0.6
	2021/02/13 14:00	8.7	121	0.4	0.4
	2021/02/13 13:00	9	120	0.1	0.4
	2021/02/13 12:00	9.8	127	0	1.2
	2021/02/12 23:00	9.9	126	0	0.2
	2021/02/12 22:00	10.1	127	0	0.2
	2021/02/12 21:00	10.4	129	0	0.3
	2021/02/12 20:00	10.7	131	0	0.4
	2021/02/12 19:00	11	131	0	1.5
	2021/02/12 18:00	10.7	131	0	1.4
	2021/02/12 17:00	10.6	130	0	0.8
	2021/02/12 16:00	10.6	129	0	0.6
	2021/02/12 15:00	8.8	123	0.2	0.2
	2021/02/12 14:00	9.1	122	0.4	0.2
	2021/02/12 13:00	9.7	121	0.1	0.2
	2021/02/11 23:00	10.5	118	0	0.2
	2021/02/11 22:00	10.7	119	0	0.4
	2021/02/11 21:00	11.3	121	0	0.7
	2021/02/11 20:00	11.6	122	0	1.1

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/11 19:00	12.7	126	0	1.7
	2021/02/11 18:00	12.5	125	0	1.9
	2021/02/11 17:00	12	127	0	1.1
	2021/02/11 16:00	11.6	129	0	0.7
	2021/02/11 15:00	11.7	128	0.1	2.2
	2021/02/11 14:00	11.2	128	0.4	1.4
	2021/02/11 13:00	11.3	130	0.1	1.6
	2021/02/11 12:00	11.2	131	0	1.5
	2021/02/11 11:00	9.4	126	0	0.2
	2021/02/11 10:00	9.8	127	0.1	0.2
	2021/02/10 14:00	11.3	91	0.5	1.6
	2021/02/10 13:00	10.5	129	0.1	1
	2021/02/10 12:00	10.2	129	0	0.8
	2021/02/10 11:00	10	130	0	0.5
	2021/02/10 10:00	10.3	100	0.1	0.4
	2021/02/10 09:00	9.4	130	0	0.4
	2021/02/10 08:00	9.3	131	0	0.3
	2021/02/10 07:00	8.6	132	0	0.3
	2021/02/10 06:00	9.1	134	0	0.7
	2021/02/09 23:00	7.9	125	0.1	0.2
	2021/02/09 22:00	8.1	127	0.1	0.2
	2021/02/09 21:00	8.7	128	0.1	0.4
	2021/02/09 20:00	8.9	128	0.1	0.4
	2021/02/09 19:00	10.2	133	0.1	2
	2021/02/09 18:00	10.1	131	0	2
	2021/02/09 17:00	9.7	130	0.1	1.1
	2021/02/09 16:00	9.3	130	0	0.8
	2021/02/09 15:00	9	130	0.1	1.4
	2021/02/09 14:00	9.2	130	0.5	1.1
	2021/02/09 13:00	9.2	131	0.3	0.7
	2021/02/09 12:00	8.8	132	0	0.5
	2021/02/09 11:00	8.3	133	0	0.2
	2021/02/09 10:00	8.1	132	0	0.2
	2021/02/09 09:00	8.1	131	0	0.2
	2021/02/09 08:00	8	130	0	0.3
	2021/02/09 07:00	8	127	0	1.7
	2021/02/08 23:00	8.1	126	0	0.5
	2021/02/08 22:00	8.5	129	0.1	0.3
	2021/02/08 21:00	8.5	130	0	0.5
	2021/02/08 20:00	8.7	133	0	0.8
	2021/02/08 19:00	9.5	138	0	1.8
	2021/02/08 18:00	9.2	136	0	1.1

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/08 17:00	8.7	136	0	0.9
	2021/02/08 16:00	8.5	135	0	0.7
	2021/02/08 15:00	8	134	0.2	0.5
	2021/02/08 14:00	7.8	134	0.6	0.6
	2021/02/08 13:00	7.9	136	0.2	0.5
	2021/02/08 12:00	8	136	0	0.3
	2021/02/08 11:00	7.8	131	0	1.2
	2021/02/07 22:00	7.2	137	0	0.2
	2021/02/07 21:00	7.3	139	0	0.3
	2021/02/07 20:00	7.6	140	0	0.3
	2021/02/07 19:00	6.8	137	0	0.3
	2021/02/06 13:00	7.9	84	0.2	0.6
	2021/02/06 12:00	8.1	85	0.1	0.5
	2021/02/06 11:00	6.7	87	0	0.2
	2021/02/06 10:00	6.5	128	0	0.2
	2021/02/05 16:00	8	109	0	1.8
	2021/02/05 15:00	7.9	109	0.2	1.8
	2021/02/05 14:00	7.7	110	0.5	1.2
	2021/02/05 13:00	7.4	133	0.4	0.9
	2021/02/05 12:00	7.3	133	0.1	1
	2021/02/05 11:00	7.1	132	0.1	1.2
	2021/02/05 10:00	7.1	130	0.1	1
	2021/02/05 09:00	6.9	129	0.1	1.1
	2021/02/05 08:00	6.7	129	0	0.9
	2021/02/05 07:00	5.7	129	0	0.4
	2021/02/05 06:00	5.8	129	0	0.3
	2021/02/05 05:00	6	128	0	0.5
Unit 32					
	2021/02/21 23:00	2.9	177	0	0.5
	2021/02/21 22:00	3	183	0	0.3
	2021/02/21 21:00	3.1	189	0	0.3
	2021/02/21 20:00	4	183	0	0.9
	2021/02/21 19:00	4.3	187	0	0.6
	2021/02/21 14:00	2.6	175	0	0.2
	2021/02/21 13:00	2.7	177	0	0.2
	2021/02/21 12:00	2.3	167	0	1.2
	2021/02/21 11:00	2.7	174	0	1.3
	2021/02/09 22:00	4.5	164	0	0.7
	2021/02/09 21:00	4.6	165	0	0.6
	2021/02/09 20:00	4.8	164	0	0.5
	2021/02/09 19:00	5.7	175	0	0.8

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/08 23:00	3.9	157	0	0.2
	2021/02/08 22:00	4.1	166	0	0.2
	2021/02/08 21:00	4	168	0	0.2
	2021/02/08 20:00	4	163	0	0.4
	2021/02/08 19:00	4	166	0	0.4
	2021/02/08 18:00	3.9	168	0	0.3
	2021/02/08 17:00	3.7	171	0	0.3
	2021/02/08 16:00	3.4	157	0	1
	2021/02/08 15:00	3.2	159	0	1.1
	2021/02/05 12:00	3.9	166	0	0.6
	2021/02/05 11:00	3.9	167	0	0.4
	2021/02/05 10:00	3.8	165	0	0.4
	2021/02/05 09:00	3.8	167	0	0.5
	2021/02/05 08:00	2.8	157	0	0.3
	2021/02/05 07:00	2.9	161	0	0.3
	2021/02/05 06:00	2.9	164	0	0.2
	2021/02/05 05:00	3.2	164	0	0.2
	2021/02/02 22:00	3.9	175	0	0.4
	2021/02/02 21:00	4	183	0	0.4
	2021/02/02 20:00	4.2	175	0	0.4
	2021/02/02 19:00	4.1	185	0	0.3
	2021/02/02 18:00	4	184	0	0.4
	2021/02/02 17:00	3.6	189	0	0.3
	2021/02/02 16:00	3.1	172	0	0.3
	2021/02/02 15:00	3	173	0	0.3
	2021/02/02 14:00	2.9	175	0	0.2
	2021/02/02 13:00	2.9	177	0	0.3
Unit 41					
	2021/02/24 20:00	6.2	154	0.1	2
	2021/02/24 19:00	6.4	156	0	7.8
	2021/02/24 18:00	6.5	157	0.1	2.9
	2021/02/24 17:00	6.5	156	0.1	1.1
	2021/02/22 21:00	6.2	163	0	2
	2021/02/22 20:00	6.2	162	0.1	0.2
	2021/02/22 19:00	6.6	99	0.1	0.2
	2021/02/21 23:00	5.5	161	0	10.8
	2021/02/21 22:00	5.3	162	0	7.2
	2021/02/21 21:00	5.3	162	0.1	1.7
	2021/02/21 20:00	5.5	162	0.1	0.4
	2021/02/21 19:00	6	166	0.1	0.2
	2021/02/21 17:00	5.2	157	0	0.2

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/21 16:00	5.2	162	0.1	2
	2021/02/21 15:00	5.7	164	0.1	9.4
	2021/02/21 14:00	5.5	162	0.1	6.2
	2021/02/21 13:00	5.2	159	0.1	0.6
	2021/02/21 12:00	5.2	157	0.1	0.5
	2021/02/21 11:00	5.8	160	0	1
	2021/02/11 22:00	8.7	141	0	2
	2021/02/11 21:00	9	143	0	1.8
	2021/02/11 20:00	9.8	143	0.1	2.6
	2021/02/11 19:00	11.9	146	0	12.4
	2021/02/11 18:00	11.5	145	0.1	5.9
	2021/02/11 17:00	10.8	145	0.1	3.6
	2021/02/10 13:00	8.7	149	0.1	0.6
	2021/02/10 12:00	8.7	150	0.1	2.4
	2021/02/10 11:00	9	154	0	13.1
	2021/02/10 10:00	8.9	109	0	11.4
	2021/02/10 09:00	8.3	147	0.1	7.2
	2021/02/10 08:00	7.8	147	0	0.7
	2021/02/10 07:00	7	144	0.1	0.2
	2021/02/10 06:00	7.5	97	0.1	0.2
	2021/02/09 22:00	8.2	148	0.1	7.7
	2021/02/09 21:00	8.1	147	0	2.1
	2021/02/09 20:00	7.9	147	0	0.2
	2021/02/09 19:00	7.8	149	0	0.2
	2021/02/09 12:00	7.5	139	0.1	2.1
	2021/02/09 11:00	7.9	155	0.1	11.4
	2021/02/09 10:00	7.7	151	0	9.2
	2021/02/09 09:00	7.3	124	0.1	1.4
	2021/02/09 08:00	6.9	123	0.1	0.3
	2021/02/09 07:00	6.2	145	0	0.2
	2021/02/08 23:00	7.1	151	0	1.8
	2021/02/08 22:00	6.9	152	0.1	0.6
	2021/02/08 21:00	6.8	152	0	0.2
	2021/02/08 20:00	6.7	154	0	1.6
	2021/02/08 19:00	7	152	0	7.2
	2021/02/08 18:00	7	151	0.1	6.7
	2021/02/08 17:00	6.8	150	0.1	3.6
	2021/02/08 16:00	6.8	151	0.1	1.9
	2021/02/08 15:00	7	151	0.1	5.1
	2021/02/08 14:00	6.8	151	0.5	3
	2021/02/08 13:00	7	149	0.1	1.5
	2021/02/05 13:00	7.3	152	0.3	0.2

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/05 12:00	7.2	154	0.1	1.8
	2021/02/05 11:00	7.3	151	0.1	7
	2021/02/05 10:00	7.2	148	0.1	5.9
	2021/02/05 09:00	7	147	0.1	3.8
	2021/02/05 08:00	6.7	148	0.1	2
	2021/02/05 07:00	7	150	0	4.3
	2021/02/05 06:00	7.1	150	0	2.3
	2021/02/05 05:00	7.2	147	0	1.2
	2021/02/02 22:00	6.5	160	0.1	0.5
	2021/02/02 21:00	6.5	165	0.1	0.4
	2021/02/05 05:00	7.2	147	0	1.2
	2021/02/02 22:00	6.5	160	0.1	0.5
	2021/02/02 21:00	6.5	165	0.1	0.4
	2021/02/02 20:00	6.8	168	0	0.3
	2021/02/02 19:00	7.3	172	0.1	0.7
	2021/02/02 18:00	7.1	175	0.1	0.4
	2021/02/02 17:00	7	179	0	0.3
	2021/02/02 16:00	7	179	0	1.2
	2021/02/02 15:00	6.6	168	0.1	4.5
	2021/02/02 14:00	6.1	168	0.7	0.2
	2021/02/02 13:00	6.4	169	0.3	0.2
	2021/02/01 21:00	5.3	162	0	0.6
	2021/02/01 20:00	5.9	166	0.1	0.7
	2021/02/01 19:00	6.9	166	0.1	1.2
Unit 42					
	2021/02/24 20:00	1.4	170	0.1	0.7
	2021/02/24 19:00	1.2	176	0.1	1.1
	2021/02/24 18:00	0.9	183	0.1	1.1
	2021/02/24 17:00	1.1	180	0.1	1.3
	2021/02/22 20:00	1.2	179	0.1	0.5
	2021/02/22 19:00	1.6	119	0.1	1.6
	2021/02/21 17:00	1.7	166	0.1	0.9
	2021/02/21 16:00	1.1	118	0.1	0.9
	2021/02/21 15:00	1.5	161	0.1	0.7
	2021/02/21 14:00	1.3	184	0.1	0.6
	2021/02/21 13:00	1.3	176	0.1	0.5
	2021/02/21 12:00	1.3	176	0.1	0.6
	2021/02/21 11:00	0.3	175	0.1	0.9
	2021/02/10 13:00	1.9	168	0.2	0.8
	2021/02/10 12:00	1.7	168	0.1	0.6
	2021/02/10 11:00	2.3	167	0.1	1.5

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/10 10:00	2	125	0.1	1.4
	2021/02/10 09:00	1.8	142	0.1	0.9
	2021/02/10 08:00	1.7	164	0.1	0.7
	2021/02/10 07:00	1	162	0.1	0.9
	2021/02/09 22:00	0.1	161	0.1	0.5
	2021/02/09 21:00	0.5	163	0.1	0.5
	2021/02/09 20:00	1.3	163	0.1	0.5
	2021/02/09 19:00	2.3	164	0.1	1.9
	2021/02/09 11:00	2.1	168	0.1	1.5
	2021/02/09 10:00	1.9	164	0.1	1.2
	2021/02/09 09:00	1.7	164	0.1	1
	2021/02/09 08:00	1.6	160	0.1	0.9
	2021/02/09 07:00	1.4	159	0.1	1.2
	2021/02/08 23:00	0.1	157	0.1	0.5
	2021/02/08 22:00	0.2	158	0.1	0.6
	2021/02/08 21:00	0.7	160	0.1	0.6
	2021/02/08 20:00	1.3	163	0	0.8
	2021/02/08 19:00	2.6	169	0.1	1.1
	2021/02/08 18:00	2.2	168	0.1	0.9
	2021/02/08 17:00	2	167	0.1	0.6
	2021/02/08 16:00	1.5	166	0.1	0.6
	2021/02/08 15:00	1.2	169	0.1	0.8
	2021/02/08 14:00	1	172	0.9	0.6
	2021/02/08 13:00	1.1	173	0.2	0.7
	2021/02/05 13:00	1.7	170	0.2	1.2
	2021/02/05 12:00	1.7	174	0.1	1
	2021/02/05 11:00	2.3	174	0.1	1.7
	2021/02/05 10:00	1.9	170	0	1
	2021/02/05 09:00	1.6	166	0.1	0.7
	2021/02/05 08:00	1.5	168	0.1	0.6
	2021/02/05 07:00	0.3	166	0.1	0.5
	2021/02/05 06:00	0.3	165	0.1	0.5
	2021/02/05 05:00	0.7	164	0.1	0.6
	2021/02/03 17:00	1.8	180	0.1	0.6
	2021/02/03 16:00	1.6	178	0.1	0.5
	2021/02/03 15:00	1.2	181	0.2	1.1
	2021/02/03 14:00	1.1	181	0.7	1
	2021/02/02 22:00	0.1	175	0.1	0.5
	2021/02/02 21:00	0.7	179	0	0.5
	2021/02/02 20:00	1.5	182	0.1	0.7
	2021/02/02 19:00	2.4	188	0	1
	2021/02/02 18:00	2.4	190	0.1	1

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/02 17:00	2.2	191	0	0.9
	2021/02/02 16:00	1.6	190	0.1	0.6
	2021/02/02 15:00	1.5	192	0.2	1.1
	2021/02/02 14:00	1.3	195	1	0.8
	2021/02/02 13:00	1.2	198	0.3	0.7
Unit 43					
	2021/02/24 21:00	2.5	143	1.2	0.2
	2021/02/24 20:00	2.4	140	1.2	0.2
	2021/02/24 19:00	2	139	1.1	1.5
	2021/02/24 18:00	1.7	142	1.1	1.1
	2021/02/24 17:00	1.8	138	0.9	1
	2021/02/23 20:00	2.2	137	1.1	0
	2021/02/23 19:00	1.6	133	1.1	0.3
	2021/02/23 18:00	1.6	133	0.9	0.3
	2021/02/22 21:00	2	145	1.1	0.6
	2021/02/22 20:00	2	146	1.1	0.4
	2021/02/22 19:00	2.1	144	1.2	0.5
	2021/02/22 18:00	2.1	144	1.1	0.4
	2021/02/22 17:00	2.1	143	1.2	0.3
	2021/02/22 16:00	2.1	146	1.1	0.2
	2021/02/22 15:00	1	147	1.1	0
	2021/02/22 14:00	0.8	146	1.2	0
	2021/02/22 13:00	0.9	146	1	0
	2021/02/22 12:00	1.4	147	0.9	0
	2021/02/21 23:00	2.1	146	1.1	0.2
	2021/02/21 22:00	1.9	146	1.1	0
	2021/02/21 21:00	1.9	146	1.1	0
	2021/02/21 20:00	2	146	1.2	0
	2021/02/21 19:00	1.6	147	1.1	0
	2021/02/21 18:00	1.6	146	1.1	0
	2021/02/21 17:00	1.6	144	1	0
	2021/02/21 16:00	1.6	144	1	0
	2021/02/21 15:00	1.4	142	1.2	0.2
	2021/02/21 14:00	1.4	140	1.1	0.1
	2021/02/21 13:00	1.5	136	1.1	0.2
	2021/02/21 12:00	1.5	135	1	0.1
	2021/02/21 11:00	1.9	139	0.9	0.4
	2021/02/21 10:00	3.1	143	0.8	1.2
	2021/02/20 13:00	1.7	140	1	0.2
	2021/02/20 12:00	1.8	140	0.9	0.2
	2021/02/20 11:00	0.4	138	0.8	0

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/20 10:00	0.6	137	0.8	0.1
	2021/02/13 22:00	2	127	0.9	0
	2021/02/13 21:00	2.1	130	1	0.1
	2021/02/13 20:00	2.1	129	1	0.1
	2021/02/13 19:00	2	131	1.1	0.2
	2021/02/13 18:00	2	132	1.1	0.1
	2021/02/13 17:00	1.8	130	1.1	0.1
	2021/02/13 16:00	1.8	121	1.1	0.1
	2021/02/13 15:00	1.7	114	1.2	1.4
	2021/02/13 14:00	1.8	129	1.8	1.4
	2021/02/13 13:00	1.9	126	0.9	1.4
	2021/02/12 23:00	2.2	131	1.2	0.7
	2021/02/12 22:00	2.1	132	1.1	0.6
	2021/02/12 21:00	2.4	134	1.1	1
	2021/02/12 20:00	2.3	137	1.1	1
	2021/02/12 19:00	2.4	138	1	0.2
	2021/02/12 18:00	2.3	136	1.1	0.1
	2021/02/12 17:00	2.3	135	1.1	0
	2021/02/12 16:00	2.2	136	1.2	0.1
	2021/02/12 15:00	1.6	130	1.4	2.2
	2021/02/12 14:00	1.7	128	2.2	2.2
	2021/02/12 13:00	2.1	126	1.1	2.4
	2021/02/11 23:00	1.5	118	1.1	0.1
	2021/02/11 22:00	1.5	118	1.2	0.1
	2021/02/11 21:00	1.9	120	1.2	0.2
	2021/02/11 20:00	1.9	123	1.2	0.4
	2021/02/11 19:00	2.9	131	1.1	0.7
	2021/02/11 18:00	2.9	134	1.1	0.9
	2021/02/11 17:00	2.7	134	1.1	0.6
	2021/02/11 16:00	2.5	136	1.1	0.2
	2021/02/11 15:00	2.2	130	1.2	1.6
	2021/02/11 14:00	2.2	130	2.1	1.3
	2021/02/11 13:00	2.3	132	1.3	1.1
	2021/02/11 12:00	2.2	131	1	0.9
	2021/02/11 11:00	1.5	135	0.9	1.2
	2021/02/11 10:00	2.1	133	0.9	1.8
	2021/02/10 14:00	1.9	92	2.4	1.7
	2021/02/10 13:00	2.1	135	1.4	1.1
	2021/02/10 12:00	2	134	0.9	0.8
	2021/02/10 11:00	2.1	132	1	0.9
	2021/02/10 10:00	1.9	98	1.1	0.9
	2021/02/10 09:00	2.1	114	1	0.7

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO2 (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/10 08:00	2.1	130	1	0.4
	2021/02/10 07:00	1.8	130	1.1	0.5
	2021/02/10 06:00	2.4	133	1	1.1
	2021/02/09 23:00	1.7	127	1.2	0.2
	2021/02/09 22:00	1.7	127	1.2	0.3
	2021/02/09 21:00	2	128	1.1	0.5
	2021/02/09 20:00	2.2	128	1	0.6
	2021/02/09 19:00	3	142	0.8	2.2
	2021/02/09 12:00	2.2	128	0.9	1.8
	2021/02/09 11:00	2.1	133	0.9	0.5
	2021/02/09 10:00	2.1	130	1	0.2
	2021/02/09 09:00	2.2	129	1	0.2
	2021/02/09 08:00	2.1	128	1	0.2
	2021/02/09 07:00	2	131	1.1	1.3
	2021/02/09 06:00	1.9	129	1.1	1.5
	2021/02/09 05:00	2.4	131	1	1.9
	2021/02/08 23:00	2.3	128	1.1	1.4
	2021/02/08 22:00	2.4	129	1.1	1.6
	2021/02/08 21:00	2.7	130	1.1	2.1
	2021/02/08 20:00	2.5	133	1.1	2.1
	2021/02/08 19:00	2.3	136	1	1.3
	2021/02/08 18:00	2.2	135	1	0.9
	2021/02/08 17:00	2.3	134	1	0.6
	2021/02/08 16:00	2.2	133	1.1	0.5
	2021/02/08 15:00	2	134	1.3	0.8
	2021/02/08 14:00	1.9	135	2.4	0.7
	2021/02/08 13:00	2	136	1.5	0.5
	2021/02/08 12:00	2.1	135	1	0.5
	2021/02/08 11:00	2.4	134	1	1.5
	2021/02/07 22:00	2.2	140	1.1	0.6
	2021/02/07 21:00	2.3	146	1.1	0.4
	2021/02/07 20:00	2.3	145	1	0.6
	2021/02/07 19:00	2.4	143	0.9	2.2
	2021/02/06 13:00	1.9	85	1.6	1
	2021/02/06 12:00	2	86	1.1	1
	2021/02/06 11:00	1.1	94	1.1	1.7
	2021/02/06 10:00	1.5	132	1	1.7
	2021/02/05 16:00	2	111	1.1	0.8
	2021/02/05 15:00	2	115	1.2	1.5
	2021/02/05 14:00	1.9	113	2.3	1
	2021/02/05 13:00	2.1	140	1.4	0.7
	2021/02/05 12:00	2.1	140	1	0.6

	Date/Time	CO (mg/Nm ³)	NOx (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	75	3500
	2021/02/05 11:00	1.9	143	0.9	0.3
	2021/02/05 10:00	1.9	139	1	0.1
	2021/02/05 09:00	2	134	1	0.1
	2021/02/05 08:00	2	133	1.1	0.1
	2021/02/05 07:00	1.5	132	1.1	0.1
	2021/02/05 06:00	1.6	131	1	0.1
	2021/02/05 05:00	1.8	131	1	0.2
	2021/02/03 20:00	2.3	133	1	0.2
	2021/02/03 19:00	2.3	144	1	0.2
	2021/02/03 18:00	2.3	146	1	0.3
	2021/02/03 17:00	2.3	145	1.1	0.1
	2021/02/03 16:00	2.2	145	1	0.1
	2021/02/03 15:00	1.3	145	1.4	0
	2021/02/03 14:00	1.2	148	2.6	0
	2021/02/03 13:00	1.2	144	1.7	0
	2021/02/03 12:00	1.7	142	1	0.1
	2021/02/02 22:00	2.1	143	1	0.1
	2021/02/02 21:00	2.4	147	1	0.3
	2021/02/02 20:00	2.4	148	1	0.3
	2021/02/02 19:00	2.4	156	1	0
	2021/02/02 18:00	2.3	156	1.1	0
	2021/02/02 17:00	2.3	157	1	0
	2021/02/02 16:00	2.1	156	1.1	0
	2021/02/02 15:00	1.4	150	1.4	0.2
	2021/02/02 14:00	1.2	150	3.1	0.1
	2021/02/02 13:00	1.2	149	1.9	0.1
	2021/02/02 12:00	1.9	149	1.1	0.2
	2021/02/01 21:00	2.2	141	1.2	0.7
	2021/02/01 20:00	2.3	143	1.2	0.7
	2021/02/01 19:00	2.3	148	1.1	2.5
	2021/02/01 18:00	2.7	151	1	3.1
		CO	NO_x	PM	SO₂
Total Emission (Tons)		13.553	146.604	0.211	10.554

COMMENT: All pollutants measured were within allowed limits and no non-conformances were registered for the month under review.

Table 4: Each unit and respective days operating under normal operation (Please note the units rarely run for the entire day)

Unit	Hours operating under normal operation	Test-run hours	Total
11	70	0	70
12	154	0	154
21	54	0	54
22	99	0	99
31	137	0	137
32	39	0	39
41	75	0	75
42	62	0	62
43	150	0	150
<i>Total</i>	<i>840</i>	<i>0</i>	<i>840</i>

3 Monitoring Equipment: Continuous Emission Monitoring System (CEMS) availability

Table 5

Associated Unit	Technology Type	Actual Utilisation (%) for the month of February
<i>Unit 11</i>	CEMS	<i>100%</i>
<i>Unit 12</i>	CEMS	<i>100%</i>
<i>Unit 21</i>	CEMS	<i>100%</i>
<i>Unit 22</i>	CEMS	<i>100%</i>
<i>Unit 31</i>	CEMS	<i>100%</i>
<i>Unit 32</i>	CEMS	<i>100%</i>
<i>Unit 41</i>	CEMS	<i>100%</i>
<i>Unit 42</i>	CEMS	<i>100%</i>
<i>Unit 43</i>	CEMS	<i>100%</i>

4 Monitoring Equipment Calibration

Continuous Emission Monitoring System (CEMS) is always online unless a fault is reported. The system auto calibrates every four (4) hours and raises an alarm if auto calibration is out of spec. Onsite technicians calibrate the system with calibration gas annually.

5 Ambient Monitoring Station

6 Load Factor: 14.08%

7 Leak Detection and Repair programme

No leaks were reported during February 2021

8 Complaints Register

Table 6. Complaints for the month of February 2021

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
<i>None</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>

9 General

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission reports sent to your office.

Trusting the above meets the reporting requirements specified within the stations' Atmospheric Emission License.

Do not hesitate to contact Hilton Westman on 021 9415856 for any related queries.

Yours sincerely



Pamela Mrubata

ANKERLIG POWER STATION