

Mr. Vusi Mahlangu Air Quality Officer DEDET Private bag X11215 NELSPRUIT 1200 Date: 22 February 2021

Enquiries: Mariam Joseph Tel +27 13 297 9828 Fax + 27 86 661 7663

Dear Mr. Mahlangu

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JANUARY 2021

This serves as the monthly report required in terms of Section 6 in Arnot Power Station's Atmospheric Emission License. The emissions are for the month of January 2021, Verified emissions of particulates; SO_2 and NO_x (as NO_2) are also included.

Raw Materials and Products

Table1: Quantity of Raw Materials and Products used/produced for the Month of January 2021

Raw Materials and	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption/ Rate in Month of January
Products used	Coal	Tons/month	1 050 330	524 262.77
	Fuel Oil	Tons/month	10 000	2385.72
Production Rates	Product/ By- Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of January 2021
Todadalon Nates	. Energy	GWh	1 785 600	974.970
	Ash	Tons/month	421 000	126 295

Generation Division Arnot Power Station N4 Nelspruit Road Private Bag X2 Rietkuil 1097 SA Tel +27 13 297 9111 Fax +27 13 297 9142 www.eskom.co.za

Eskom Holdings SOC Ltd Reg No 2002/015527/30

as (av

Abatement Technology

Table 2 Abatement Equipment Control Technology for month of January 2021

rabio E ribatoritorit Equipinion	t control rectinionegy for	month of canada, momit
Associated Unit/Stack		Actual efficiency: (%) for the month of January 2021
North Stack	Fabric Filter Bags	99 7%
South Stack	Fabric Filter Bags	99 8%

Table 2 1

Associated Unit/Stack		Actual Utilisation (%) for the month of January 2021
North Stack	Fabric Filter Bags	100%
South Stack	Fabric Filter Bags	100%

Energy Source Characteristics

Table 3 Energy Source Material Characteristics for the month of -January 2021

rable of Energy course material		anaan j 202 i
Characteristic	Stipulated Range (Unit)	Monthly Average Content
Sulphur Content	0 5 to < 1 (%)	0 690
Ash Content	17 to < 40 (%)	24 09

Table 4 Operating days in compliance to PM AEL Limit – January 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm³)
North	31	0	0	0	0	59.0
South	31	0	0	0	0	44 0
SUM	62	0	0	0	0	

Table 5 Operating days in compliance to NOx AEL Limit – January 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
North	31	0	0	0	0	622 9
South	31	0	0	0	0	677 7
SUM	62	0	0	0	0	

as (av

Table 6: Operating days in compliance to SOx AEL Limit –January 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm³)
North	31	0	0	0	0	1183.7
South	31	0	0	0	0	1336.4
SUM	62	0	0	0	0	

Emissions Reporting




Figure 1: PM emissions (daily averages) for the month of January 2021 against emission limit for the North Stack

as (au




Figure 2: PM emissions (daily averages) for the month of January 2021 against emission limit for the South Stack




Figure 3: SO_2 emissions (daily averages) for the month of January 2021 against emission limit for the North Stack

as (au




Figure 4: SO₂ emissions (daily averages) for the month of January -2021 against emission limit for the South Stack




Figure 5: NO₂ emissions (daily averages) for the month of January -2021 against emission limit for the North Stack

Das (au




Figure 6: NO_2 emissions (daily averages) for the month of January -2021 against emission limit for the South Stack

Table 4: Monthly tonnages for the month of January 2021

Unit	PM (tons)	SO ₂ (tons)	NO ₂ (tons)
Total Tons (North & South Stack)	271.1	6678.6	3430.0

Table 5: Monitor Availability

Unit	PM (%)	SO ₂ (%)	NO ₂ (%)
North Stack	100	0	0
South Stack	99.3	99.5	99.5

As of 11th December 2020 the North stack was reading errors on the gaseous pollutants. Upon further investigation by Control and Instrumentation Department it was found that the monitor was struck by lightning. The monitor was found to be burnt out and the station is in the process of replacing the monitor. Average readings were used to report on the SO₂ and NO₂.

as (av

Table 6 Each unit and respective days operating under normal operation, days in grace period, and section 30 days respectively

Unit	Days operating under normal operation	Days operating in grace period	Days operating under \$ 30
	31	0	0
2	31	0	0
	31	0	0
4	31	0	0
5	31	0	0
() 6 7 (/ /)	31	0	0

Light up information

Continuous reporting is being done even during start-ups, emissions were not affected

Complaints Register

Table 7 Complaints for the month of January 2021

Source Code/ Name Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modeling of pollutants where applicable	14 2 2 2 2 2 2 3 3 4 4 4 4 4 4 4 4 4 4 4	Date by which measure will be implemented
None				

General

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission reports sent to your office

Hoping the above will meet your satisfaction

Compiled by

Lawrence Machebe

ENVIRONMENTAL OFFICER: ARNOT

#Jas (av

Verified by
ADM July
Nomathemba Mpulo
SENIOR TECHNOLOGIST: ARNOT
Supported by
HOU Kouhas.
Rofhiwa Tshikovha
SENIOR ENVIRONMENTAL ADVISOR: ARNOT
Yours sincerely

Tsoro Samuel Mashao

ACTING GENERAL MANAGER: ARNOT