



Mrs Mpho Nembilwi
Nkangala District
P O Box 437
MIDDLEBERG
1050
By email nembilwim@nkangaladm.gov.za'

Date
24 February 2021

Enquiries S Chokoe
Tel +27 13 647 6970

Dear Mrs Mpho Nembilwi

Ref Kendal Power Station AEL (17/4/AEL/MP312/11/15)

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF NOVEMBER 2020 TO JANUARY 2021.

This is a monthly report required in terms of Section 7.4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Compiled by:

Tshildzi Vilane
ENVIRONMENTAL OFFICER- KENDAL

Date: 24/02/2021

Supported by:

Solly Chokoe
ACTING ENVIRONMENTAL MANAGER- KENDAL

Date: 25/02/2021

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTHS OF NOVEMBER 2020 TO JANUARY 2021.

Verified by:


Filono Malatsi
SENIOR TECHNICIAN BOILER ENGINEERING- KENDAL

Date: 24/02/2021

Validated by:


pp
Tendani Rasivhetshela
ACTING BOILER ENGINEERING MANAGER-KENDAL

Date 25/02/2021

Supported by:


Malibongwe Mabizela
ACTING ENGINEERING MANAGER-KENDAL


Date 25/02/2021

Reviewed by:


Bryan Mccourt
AIR QUALITY CENTRE OF EXCELLENCE MANAGER-ESKOM

Date 26/02/2021

Approved by:


Yangaphle Ngcashi
ACTING GENERAL MANAGER-KENDAL

2021.03.01
Date

KENDAL POWER STATION MONTHLY EMISSIONS REPORT
 Atmospheric Emission License 17/4/AEL/MP312/11/15



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption	Consumption Rate Jan-2021
	Coal	Tons	2 260 000	558 653
	Fuel Oil	Tons	5 000	5546,38

Production Rates	Product / By-Product Name	Units		Production Rate Jan-2021
	Energy	GWh	4380	9 683,82
	Ash	Tons	Not specified	170 724,5
	RE Ash	kg/MWh	Not specified	0,240

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units		Stipulated Range	Monthly Average Content
Sulphur Content	%		0,7 TO >1 (%)	0,660
Ash Content	%		30 TO >40 (%)	30,560

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO _x	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMET TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jan-2021	Technology Type	Utilization Jan-2021
Unit 1	ESP + SO ₃	99,9%	SO ₃	88,9%
Unit 2	ESP + SO ₃	99,7%	SO ₃	91,1%
Unit 3	ESP + SO ₃	99,8%	SO ₃	82,5%
Unit 4	ESP + SO ₃	Unit off	SO ₃	Unit off
Unit 5	ESP + SO ₃	Unit off	SO ₃	Unit off
Unit 6	ESP + SO ₃	Unit off	SO ₃	Unit off

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	100,0	0,0	0,0	0,0
Unit 2	99,9	0,0	0,0	0,0
Unit 3	100,0	0,0	0,0	0,0
Unit 4	Unit off	Unit off	Unit off	Unit off
Unit 5	Unit off	Unit off	Unit off	Unit off
Unit 6	Unit off	Unit off	Unit off	Unit off

Note: The QAL 2 parallel tests results have been used to calculate the gaseous emissions hence monitor reliability is zero

6 EMISSION PERFORMANCE

Table 6.1 Monthly tonnages for the month of January 2021

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	30.3	1 554	766
Unit 2	107.0	1 840	1 134
Unit 3	97.9	1 669	878
Unit 4	Unit off	Unit off	Unit off
Unit 5	Unit off	Unit off	Unit off
Unit 6	Unit off	Unit off	Unit off
SUM	235.30	5 063	2 779

Table 6.2 Operating days in compliance to PM AEL Limit - January 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance		Average PM (mg/Nm ³)
Unit 1	27	0	0	0	0	0	19.9
Unit 2	25	3	0	0	3	0	73.9
Unit 3	30	1	0	0	1	0	62.3
Unit 4	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 5	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 6	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
SUM	82	4	0	0	4	0	

Table 6.3 Operating days in compliance to SOx AEL Limit - January 2021


Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance		Average SOx (mg/Nm ³)
Unit 1	29	0	0	0	0	0	800.9
Unit 2	31	0	0	0	0	0	808.6
Unit 3	31	0	0	0	0	0	619.6
Unit 4	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 5	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 6	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
SUM	91	0	0	0	0	0	


Table 6.4: Operating days in compliance to NOx AEL Limit - January 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm ³)
Unit 1	29	0	0	0	0	395,0
Unit 2	31	0	0	0	0	498,3
Unit 3	31	0	0	0	0	326,0
Unit 4	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 5	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
Unit 6	Unit off	Unit off	Unit off	Unit off	Unit off	Unit off
SUM	91	0	0	0	0	


Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contravention	Red	Emissions above ELV but outside grace or S30 incident conditions






High PM emissions on the 02nd and 20th can be attributed to shutdown and on the 16 was due to poor ESP performance.



Unit 3 high PM emissions on the 10th can be attributed poor performance of the electrostatic precipitators fields.

Figure 4: Kendal Unit 4 PM Emissions - January 2021



Unit only ran for 7 hours after synchronisation hence no PM emissions recorded

Figure 5: Kendal Unit 5 PM Emissions - January 2021




Figure 6: Kendal Unit 6 PM Emissions - January 2021













Figure 7: Kendal Unit 1 SOx Emissions - January 2021


















7 COMPLAINTS

There were no complaints for this months

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

ADDENDUM TO MONTHLY EMISSIONS REPORT

Abatement Technology-Table 4

In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as

- ☑ Coal ash content (%) and burnt rate mass
- ☑ Fly Coarse ash ratio of 80.20 - 80% of fly-ash mass obtained from burnt coal goes to ESP
- ☑ Measurement of dust emission by Dust Monitor over a period of time (monthly)

Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \left(\frac{\text{Dust Emission From AQR Report Dust Monitor (tons)}}{(\text{Coal Burnt (tons)} \times \% \text{ Ash Content} \times 80\%)} \right) \times 100$$

Monitor Reliability-Table 5

In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average. The monitor reliability refers to data reliability because the assumed value of 98% reliability is compared to the dust concentration signal. If the dust concentration signal is above 98% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g. 24 hours. The formula is as follows:
$$= (1 - (\text{count hours above 98\%/24hours})) \times 100$$

Emissions Performance

- Note that gaseous emissions were manually entered using independent third party QAL2 parallel test reports due to the unreliability of the CEMS monitors data
- Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2, 3 & 4 due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- Average velocity values from December 2019 correlation report were used for the gaseous emissions on unit 6 with the velocity correction factors
- Units, 4, 5 & 6 was offload during this month for repairs to address emissions issues

Unit 2

Findings

High PM emissions on the 02nd and 20th can be attributed to shutdown and on the 16 was due to poor fields performance

Resolution ESP to be repaired during opportunity maintenance

Unit 3

Unit 3 High PM emissions on the 10th was due to poor fields performance

Resolution ESP to be repaired during opportunity maintenance