

**MATLA POWER STATION MONTHLY EMISSIONS REPORT**

Atmospheric Emission License 17/4/AEL/MP312/11/14



**1 RAW MATERIALS AND PRODUCTS**

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Jul-2020
	Coal	Tons	1 475 000	863 956
Fuel Oil	Tons	2 500	109	

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Jul-2020
	Energy	GWh	2 567	1 647
Ash	Tons	471 000	242 944	
RE PM	kg/MWh	not specified	0,501	

**2 ENERGY SOURCE CHARACTERISTICS**

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.8-1.1	1,00
Ash Content	%	21-40	28,12

### 3 EMISSION LIMITS (mg/Nm<sup>3</sup>)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO
South	200	3500	1200
Unit 4	200	3500	1200
Unit 5	100	3500	1200
Unit 6	100	3500	1200

### 4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jul-2020
South	<i>Electro Static Precipators (ESP)</i>	<i>99,657%</i>
Unit 4	<i>Electro Static Precipators (ESP)</i>	<i>99,401%</i>
Unit 5	<i>Electro Static Precipators (ESP)</i>	<i>99,711%</i>
Unit 6	<i>Electro Static Precipators (ESP)</i>	<i>99,686%</i>

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

### 5 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO		O <sub>2</sub>
South	<i>99,3</i>	<i>99,3</i>	<i>99,5</i>		<i>16,1</i>
Unit 4	<i>91,7</i>	<i>99,7</i>	<i>99,7</i>		<i>56,5</i>
Unit 5	<i>97,4</i>	<i>99,7</i>	<i>99,7</i>		<i>99,4</i>
Unit 6	<i>99,2</i>	<i>92,2</i>	<i>91,8</i>		<i>98,0</i>

### 6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of July-2020

Associated Unit/Stack	PM	SO <sub>x</sub>	NO <sub>x</sub>	
Unit 1	153,9	2 920,5	1 011,0	
Unit 2	0,0	0,0	0,0	
Unit 3	155,3	2 709,7	968,1	
Unit 4	257,5	4 205,0	1 099,8	
Unit 5	115,1	3 318,3	1 125,5	
Unit 6	143,5	3 167,8	1 303,3	
<b>SUM</b>	<b>825,4</b>	<b>16 321,4</b>	<b>5 507,7</b>	

Table 6.2: Operating days in compliance to PM AEL Limit - July 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average PM (mg/Nm <sup>3</sup> )
South	27	3	1	0	4	98,0
Unit 4	22	6	3	0	9	138,3
Unit 5	24	4	1	0	5	66,0
Unit 6	24	5	2	0	7	87,9
<b>SUM</b>	<b>97</b>	<b>18</b>	<b>7</b>	<b>0</b>	<b>25</b>	





Table 6.3: Operating days in compliance to SOx AEL Limit - July 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average SOx (mg/Nm <sup>3</sup> )
South	31	0	0	0	0	1 910,9
Unit 4	31	0	0	0	0	2 252,7
Unit 5	30	0	0	0	0	1 915,3
Unit 6	31	0	0	0	0	1 946,7
<b>SUM</b>	<b>123</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	


Table 6.4: Operating days in compliance to NOx AEL Limit - July 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm <sup>3</sup> )
South	31	0	0	0	0	655,3
Unit 4	31	0	0	0	0	588,4
Unit 5	30	0	0	0	0	652,3
Unit 6	31	0	0	0	0	800,1
<b>SUM</b>	<b>123</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contra-vention		Emissions above ELV but outside grace or S30 incident conditions

**Figure 1: Matla South Stack PM Emissions - July 2020**



**Figure 2: Matla Unit 4 PM Emissions - July 2020**




Figure 3: Matla Unit 5 PM Emissions - July 2020




Figure 4: Matla Unit 6 PM Emissions - July 2020




Figure 5: Matla South Stack SOx Emissions - July 2020




Figure 6: Matla Unit 4 SOx Emissions - July 2020




Figure 7: Matla Unit 5 SOx Emissions - July 2020




Figure 8: Matla Unit 6 SOx Emissions - July 2020




Figure 9: Matla South Stack NOx Emissions - July 2020




Figure 10: Matla Unit 4 NOx Emissions - July 2020






Figure 11: Matla Unit 5 NOx Emissions - July 2020





Figure 12: Matla Unit 6 NOx Emissions - July 2020



## 7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1. PM Start-up information for the month of July-2020

South Stack	<i>Event 1</i>		<i>Event 2</i>		<i>Event 3</i>		<i>Event 4</i>	
Unit No.	<i>Unit 3</i>		<i>Unit 3</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)	<i>9:25 PM</i>	<i>2020/07/15</i>	<i>1:05 AM</i>	<i>2020/07/25</i>				
Draught Group (DG) Shut Down (SD)	<i>DG did not trip or SD</i>	<i>DG did not trip or SD</i>	<i>7:35 AM</i>	<i>2020/07/26</i>				
BO to DG SD (duration)	<i>n/a</i>	DD:HH:MM	<i>01:06:30</i>	DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	<i>9:25 PM</i>	<i>2020/07/15</i>	<i>10:25 PM</i>	<i>2020/07/27</i>				
Synch. to Grid (or BC)	<i>8:30 AM</i>	<i>2020/07/16</i>	<i>11:15 AM</i>	<i>2020/07/28</i>				
Fires in to BC (duration)	<i>00:11:05</i>	DD:HH:MM	<i>00:12:50</i>	DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	<i>12:00 AM</i>	<i>2020/07/17</i>	<i>12:00 AM</i>	<i>2020/07/30</i>				
Emissions below limit from BC (duration)	<i>00:15:30</i>	DD:HH:MM	<i>01:12:45</i>	DD:HH:MM		DD:HH:MM		DD:HH:MM

South Stack ...cont.	<i>Event 5</i>		<i>Event 6</i>		<i>Event 7</i>		<i>Event 8</i>	
Unit No.	<i>no event</i>		<i>no event</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 4	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 5	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	12:55 AM	2020/07/04						
Draught Group (DG) Shut Down (SD)	12:55 AM	2020/07/04						
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	7:40 AM	2020/07/06						
Synch. to Grid (or BC)	2:25 PM	2020/07/06						
Fires in to BC (duration)	00:06:45	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	1:00 AM	2020/07/07						
Emissions below limit from BC (duration)	00:10:35	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 6	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM


7.2: Point Source emissions released during start-up (fires-in) and Shut-down (SD) for the month of July-2020 in mg/Nm<sup>3</sup>


[Include reference to once off test showing typical emissions rates during fires in and SD]

Remember to add attachments here; see ReportAddendum Tab

Reserved for Addendum XXXX

11 General

  
Boiler Engineering      29/01/2021      Date

  
Environmental Department      2021-01-19      Date

  
General Manager      Date

Compiled by: Boiler Engineering Department

ESP & SO<sub>3</sub> System Engineer

For: Department of Environmental Affairs and Tourism

Chief Air Pollution Control Officer

Copies: Eskom Environmental Management

D Herbst  
B Mccourt

Group Technology Engineering

R Rampiar  
E. Patel

Matla Power Station:

Engineering Manager  
Operating Manager  
Maintenance Manager  
Unit Production Manager  
Boiler Engineering Manager  
System Engineer  
Environmental Officer  
Performance and Test  
Production Manager

