

MATLA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/14



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Dec-2020
	Coal	Tons	1 475 000	952 967
	Fuel Oil	Tons	2 500	1 292

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Dec-2020
	Energy	GWh	2 567	1 642
	Ash	Tons	471 000	287 796
	RE PM	kg/MWh	not specified	0,915

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	18-24	18,71
Sulphur Content	%	0.8-1.1	1,00
Ash Content	%	21-40	30,20

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO
South	200	3500	1200
Unit 4	200	3500	1200
Unit 5	100	3500	1200
Unit 6	100	3500	1200

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Dec-2020
South	<i>Electro Static Precipators (ESP)</i>	<i>99,524%</i>
Unit 4	<i>Electro Static Precipators (ESP)</i>	<i>99,313%</i>
Unit 5	<i>Electro Static Precipators (ESP)</i>	<i>98,768%</i>
Unit 6	<i>Electro Static Precipators (ESP)</i>	<i>99,599%</i>

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	PM	SO ₂	NO	CO ₂	O ₂
South	<i>87,8</i>	<i>75,8</i>	<i>75,8</i>		<i>100,0</i>
Unit 4	<i>80,6</i>	<i>99,9</i>	<i>100,0</i>		<i>100,0</i>
Unit 5	<i>41,4</i>	<i>99,5</i>	<i>0,0</i>		<i>99,8</i>
Unit 6	<i>79,9</i>	<i>99,3</i>	<i>99,5</i>		<i>99,1</i>

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of December-2020

Associated Unit/Stack	PM	SO _x	NO _x	CO ₂
Unit 1	155,2	2 375,8	773,7	257 816
Unit 2	258,5	3 291,0	1 079,6	329 382
Unit 3	277,4	3 419,8	1 119,3	342 418
Unit 4	325,1	4 051,3	1 412,5	389 092
Unit 5	327,2	0,0	0,0	327 200
Unit 6	159,6	2 281,8	922,0	242 246
SUM	1 503,0	15 419,7	5 307,0	1 588 154

Table 6.2: Operating days in compliance to PM AEL Limit - December 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average PM (mg/Nm ³)
South	21	4	6	0	10	168,2
Unit 4	20	2	9	0	11	178,2
Unit 5	1	3	11	0	14	416,6
Unit 6	17	2	4	0	6	166,4
SUM	59	11	30	0	41	

Table 6.3: Operating days in compliance to SOx AEL Limit - December 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average SOx (mg/Nm ³)
South	31	0	0	0	0	2 018,6
Unit 4	31	0	0	0	0	2 197,8
Unit 5	0	0	0	0	0	
Unit 6	26	0	0	0	0	2 211,5
SUM	88	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - December 2020

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm ³)
South	31	0	0	0	0	660,5
Unit 4	31	0	0	0	0	763,7
Unit 5	0	0	0	0	0	
Unit 6	26	0	0	0	0	876,7
SUM	88	0	0	0	0	

Table 6.5: Legend Description





Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contra-vention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Matla South Stack PM Emissions - December 2020




Figure 2: Matla Unit 4 PM Emissions - December 2020




Figure 3: Matla Unit 5 PM Emissions - December 2020




Figure 4: Matla Unit 6 PM Emissions - December 2020




Figure 5: Matla South Stack SOx Emissions - December 2020




Figure 6: Matla Unit 4 SOx Emissions - December 2020




Figure 7: Matla Unit 5 SOx Emissions - December 2020




Figure 8: Matla Unit 6 SOx Emissions - December 2020




Figure 9: Matla South Stack NOx Emissions - December 2020




Figure 10: Matla Unit 4 NOx Emissions - December 2020




Figure 11: Matla Unit 5 NOx Emissions - December 2020





Figure 12: Matla Unit 6 NOx Emissions - December 2020



7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1. PM Start-up information for the month of December-2020

South Stack	<i>Event 1</i>		<i>Event 2</i>		<i>Event 3</i>		<i>Event 4</i>	
Unit No.	<i>Unit 1</i>		<i>Unit 1</i>		<i>Unit 1</i>		<i>Unit 1</i>	
Breaker Open (BO)	<i>9:10 PM</i>	<i>2020/12/12</i>	<i>9:25 AM</i>	<i>2020/12/15</i>	<i>8:20 AM</i>	<i>2020/12/19</i>	<i>4:45 AM</i>	<i>2020/12/28</i>
Draught Group (DG) Shut Down (SD)	<i>DG did not trip or SD</i>	<i>DG did not trip or SD</i>	<i>DG did not trip or SD</i>	<i>DG did not trip or SD</i>	<i>DG did not trip or SD</i>	<i>DG did not trip or SD</i>	<i>4:05 AM</i>	<i>2020/12/29</i>
BO to DG SD (duration)	<i>n/a</i>	<i>DD:HH:MM</i>	<i>n/a</i>	<i>DD:HH:MM</i>	<i>n/a</i>	<i>DD:HH:MM</i>	<i>00:23:20</i>	<i>DD:HH:MM</i>
Fires in time	<i>9:10 PM</i>	<i>2020/12/12</i>	<i>9:25 AM</i>	<i>2020/12/15</i>	<i>8:20 AM</i>	<i>2020/12/19</i>	<i>7:40 AM</i>	<i>2021/01/02</i>
Synch. to Grid (or BC)	<i>2:20 PM</i>	<i>2020/12/13</i>	<i>9:30 AM</i>	<i>2020/12/15</i>	<i>2:15 PM</i>	<i>2020/12/19</i>	<i>6:40 PM</i>	<i>2021/01/02</i>
Fires in to BC (duration)	<i>00:17:10</i>	<i>DD:HH:MM</i>	<i>00:00:05</i>	<i>DD:HH:MM</i>	<i>00:05:55</i>	<i>DD:HH:MM</i>	<i>00:11:00</i>	<i>DD:HH:MM</i>
Emissions below limit from BC (end date)	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>
Emissions below limit from BC (duration)	<i>n/a</i>	<i>DD:HH:MM</i>	<i>n/a</i>	<i>DD:HH:MM</i>	<i>n/a</i>	<i>DD:HH:MM</i>	<i>n/a</i>	<i>DD:HH:MM</i>

South Stack ...cont.	<i>Event 5</i>		<i>Event 6</i>		<i>Event 7</i>		<i>Event 8</i>	
Unit No.	<i>no event</i>		<i>no event</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		<i>DD:HH:MM</i>		<i>DD:HH:MM</i>		<i>DD:HH:MM</i>		<i>DD:HH:MM</i>
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		<i>DD:HH:MM</i>		<i>DD:HH:MM</i>		<i>DD:HH:MM</i>		<i>DD:HH:MM</i>
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		<i>DD:HH:MM</i>		<i>DD:HH:MM</i>		<i>DD:HH:MM</i>		<i>DD:HH:MM</i>

Unit No. 4	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 5	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	BO previously	BO previously	10:45 AM	2020/12/18				
Draught Group (DG) Shut Down (SD)	n/a	n/a	10:45 AM	2020/12/18				
BO to DG SD (duration)	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	12:00 PM	2020/12/12	10:45 AM	2020/12/18				
Synch. to Grid (or BC)	4:30 AM	2020/12/16	6:05 PM	2020/12/18				
Fires in to BC (duration)	03:16:30	DD:HH:MM	00:07:20	DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit				
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 6	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	2:00 AM	2020/12/04	1:10 AM	2020/12/25				
Draught Group (DG) Shut Down (SD)	2:00 AM	2020/12/04	1:10 AM	2020/12/25				
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	2:00 AM	2020/12/04	8:50 PM	2020/12/30				
Synch. to Grid (or BC)	5:15 PM	2020/12/06	4:20 AM	2020/12/31				
Fires in to BC (duration)	02:15:15	DD:HH:MM	00:07:30	DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	11:00 PM	2021/01/04				
Emissions below limit from BC (duration)	n/a	DD:HH:MM	04:18:40	DD:HH:MM		DD:HH:MM		DD:HH:MM

7.2: Point Source emissions released during start-up (fires-in) and Shut-down (SD) for the month of December-2020 in mg/Nm³

[Include reference to once off test showing typical emissions rates during fires in and SD]

Remember to add attachments here; see ReportAddendum Tab

Reserved for Addendum XXXX

ADDENDUM TO MONTHLY EMISSIONS REPORT

8 EMERGENCY GENERATION

Emergency Generation *[This is only required for stations that are requested to report on this information]*

Table 8. Emergency Generation per unit for the month of December 2020

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control						
Emergency Hours declared including hours after stand down						
Hours over the Limit during Emergency Generation						

9 COMPLAINTS REGISTER

Table 9. Complaints for the month of December 2020

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date measure will be implemented
<i>(insert name of affected station)</i>	<i>(insert root cause for incident)</i>	<i>(insert emissions associated with incident)</i>	<i>(insert dispersion model information where applicable)</i>	<i>(insert mitigation measures taken)</i>	<i>(insert date of implementation of)</i>

10 S30 INCIDENT OR LEGAL CONTRAVENTION REGISTER

To be completed in the case of a S30 incident or a legal contravention:

Unit no	Incident Start Date	Incident End Date	Incident Cause	Remedial action	S30 Initial notification sent	Date S30 investigation report sent	Date DEA Acknowledgment	Date DEA Acceptable	Comments / Reference No.
South Stack	2020/12/21		Poor coal qualities, low instrument air(dust plant), Dust plant blockages and SO3 fluctuations which led to high hopper levels. High hopper levels caused high emissions.	Load loss taken, brought more compressors.	Yes				
4	2020/12/21	2021/01/05	Poor coal qualities, low instrument air(dust plant), Dust plant blockages and SO3 fluctuations which led to high hopper levels. High hopper levels caused high emissions.	Load loss taken, brought more compressors.	Yes				
5	2020/12/24	2021/01/05	Poor coal qualities, low instrument air(dust plant), Dust plant blockages and SO3 fluctuations which led to high hopper levels. High hopper levels caused high emissions.	Load loss taken, brought more compressors.	Yes				
6	2020/12/24	2020/12/25	Poor coal qualities, low instrument air(dust plant), Dust plant blockages and SO3 fluctuations which led to high hopper levels. High hopper levels caused high emissions.	Load loss taken, brought more compressors.	Yes				