

Mr. Vusi Mahlangu
 Air Quality Officer
 DEDET
 Private bag X11215
 NELSPRUIT
 1200

Date:
 21 May 2021

Enquiries:
 Mariam Joseph
 Tel +27 13 297 9828
 Fax + 27 86 661 7663

Dear Mr. Mahlangu

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL 2021

This serves as the monthly report required in terms of Section 6 in Arnot Power Station's Atmospheric Emission License. The emissions are for the month of April 2021, Verified emissions of particulates; SO₂ and NO_x (as NO₂) are also included.

Raw Materials and Products

Table1: Quantity of Raw Materials and Products used/produced for the Month of April 2021

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption/ Rate in Month of April 2021
	Coal	Tons/month	1 050 330	549 959.0
	Fuel Oil	Tons/month	10 000	1994.86
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of April 2021
	Energy	GWh	1 785 600	1 041.632
	Ash	Tons/month	421 000	130 835.26

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL 2021

Abatement Technology

Table 2: Abatement Equipment Control Technology for month of March 2021

Associated Unit/Stack	Technology Type	Actual Utilisation (%) for the month of April 2021
North Stack	Fabric Filter Bags	99.8%
South Stack	Fabric Filter Bags	99.8%

Table 2.1 Efficiency of Fabric Filter Bags for Month of April 2021

Associated Unit/Stack	Technology Type	Actual Efficiency (%) for the month of March 2021
North Stack	Fabric Filter Bags	100%
South Stack	Fabric Filter Bags	100%

Energy Source Characteristics

Table 3 Energy Source Material Characteristics for the month of April 2021

Characteristic	Stipulated Range (Unit)	Monthly Average Content
Sulphur Content	0.5 to < 1 (%)	0.739
Ash Content	17 to < 40 (%)	23.79

Table 4 Operating days in compliance to PM AEL Limit –April 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
North	30	0	0	0	0	45.9
South	30	0	0	0	0	40.9
SUM	60	0	0	0	0	

Table 5 Operating days in compliance to NOx AEL Limit – April 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm ³)
North	30	0	0	0	0	770.2
South	30	0	0	0	0	630.1
SUM	60	0	0	0	0	

Table 6 Operating days in compliance to SOx AEL Limit –April 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm ³)
North	30	0	0	0	0	1378.9
South	30	0	0	0	0	1208.0
SUM	60	0	0	0	0	

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL 2021

Emissions Reporting




Figure 1: PM emissions (daily averages) for the month of April 2021 against emission limit for the North Stack




Figure 2: PM emissions (daily averages) for the month of April 2021 against emission limit for the South Stack

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL 2021




Figure 3: SO₂ emissions (daily averages) for the month of April 2021 against emission limit for the North Stack




Figure 4: SO₂ emissions (daily averages) for the month of April 2021 against emission limit for the South Stack

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL 2021




Figure 5: NO₂ emissions (daily averages) for the month of April 2021 against emission limit for the North Stack




Figure 6: NO₂ emissions (daily averages) for the month of April 2021 against emission limit for the South Stack

Table 4: Monthly tonnages for the month of April 2021

Unit	PM (tons)	SO ₂ (tons)	NO ₂ (tons)
Total Tons (North & South Stack)	229.1	7 033.4	3 796.6

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL 2021

Table 5. Monitor Availability

Unit	PM (%)	SO ₂ (%)	NO ₂ (%)
North Stack	100.0	99.3	99.6
South Stack	100.0	99.3	99.3

Table 6 Each unit and respective days operating under normal operation, days in grace period, and section 30 days respectively

Unit	Days operating under normal operation	Days operating in grace period	Days operating under S 30
1	30	0	0
2	30	0	0
3	30	0	0
4	30	0	0
5	30	0	0
6	30	0	0

Light up information

Continuous reporting is being done even during start-ups, emissions were not affected

Complaints Register

Table 7 Complaints for the month of April 2021

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

General


New O2 analyser was installed and still need QAL2 test to be done. Once this is done, the new correction factors shall be back fitted from expiry date of 12 April 2021 and new figures shall be included on the coming monthly report.

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission reports sent to your office.

Hoping the above will meet your satisfaction.

**ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL
2021**

Compiled by



Lawrence Machebe

ENVIRONMENTAL OFFICER: ARNOT


Verified by



Nomathemba Mpulo

SENIOR TECHNOLOGIST: ARNOT


Supported by



Rofhiwa Tshikovha

SENIOR ENVIRONMENTAL ADVISOR: ARNOT

Yours sincerely



Tsoro Samuel Mashao

ACTING GENERAL MANAGER: ARNOT