



Generation

Nkangala District Municipality
P O Box 437
Middleburg
1050

Attention:
Mr V Mahlangu

AND

Directorate: Air Quality Management Services
The Director:
Mr Vumile Senene
Department of Environmental Affairs
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

Date: 2021/05/11

Enquiries: Mbali Mhlana -Matla Environmental
☎ +27 17 612 6410

Enquiries: Lele Masote
☎ +27 17 612 6457

Total number of pages:
16

Total number of annexes:

MATLA POWER STATION


Atmospheric Emission License 17/4/AEL/MP312/11/14



BOILER ENGINEERING MANAGER



ENVIRONMENTAL MANAGER



ENGINEERING MANAGER

17/05/2021

DATE

2021-05-17

DATE

17/05/2021

DATE

MATLA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/14


1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Apr-2021
	Coal	Tons	1 475 000	825 593
	Fuel Oil	Tons	2 500	666
Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Apr-2021
	Energy	GWh	2 484	1 447
	Ash	Tons	471 000	245 036
	RE PM	kg/MWh	not specified	0,502

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	16-24	19,39
Sulphur Content	%	0.8-1.1	1,00
Ash Content	%	21-40	29,68

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO
South	200	3500	1200
Unit 4	200	3500	1200
Unit 5	100	3500	1200
Unit 6	100	3500	1200

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Apr-2021
South	<i>Electro Static Precipators (ESP)</i>	<i>99,834%</i>
Unit 4	<i>Electro Static Precipators (ESP)</i>	<i>99,252%</i>
Unit 5	<i>Electro Static Precipators (ESP)</i>	<i>99,658%</i>
Unit 6	<i>Electro Static Precipators (ESP)</i>	<i>99,720%</i>

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
South	<i>99,4</i>	<i>100,0</i>	<i>100,0</i>	<i>100,0</i>
Unit 4	<i>90,0</i>	<i>99,2</i>	<i>99,3</i>	<i>99,4</i>
Unit 5	<i>92,4</i>	<i>99,2</i>	<i>99,4</i>	<i>96,2</i>
Unit 6	<i>94,9</i>	<i>98,9</i>	<i>98,9</i>	<i>99,3</i>

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of April-2021

Associated Unit/Stack	PM	SO _x	NO _x
Unit 1	81,0	3 511,9	882,6
Unit 2	71,2	3 093,3	789,5
Unit 3	0,0	0,0	0,0
Unit 4	317,0	3 898,9	1 313,5
Unit 5	156,4	3 058,1	1 168,8
Unit 6	101,3	2 208,7	998,4
SUM	726,9	15 770,9	5 152,7

Table 6.2: Operating days in compliance to PM AEL Limit - April 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average PM (mg/Nm³)
South	29	1	0	0	1	53,4
Unit 4	21	9	0	0	9	179,8
Unit 5	21	6	1	0	7	102,0
Unit 6	17	5	0	0	5	104,0
SUM	88	21	1	0	22	

Table 6.3: Operating days in compliance to SOx AEL Limit - April 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average SOx (mg/Nm³)
South	30	0	0	0	0	2 354,9
Unit 4	30	0	0	0	0	2 213,7
Unit 5	29	0	0	0	0	1 912,7
Unit 6	25	0	0	0	0	2 201,6
SUM	114	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - April 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm³)
South	30	0	0	0	0	592,7
Unit 4	30	0	0	0	0	746,6
Unit 5	29	0	0	0	0	726,6
Unit 6	24	1	0	0	1	988,3
SUM	113	1	0	0	1	

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contra-vention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Matla South Stack PM Emissions - April 2021




Figure 2: Matla Unit 4 PM Emissions - April 2021




Figure 3: Matla Unit 5 PM Emissions - April 2021




Figure 4: Matla Unit 6 PM Emissions - April 2021




Figure 5: Matla South Stack SOx Emissions - April 2021




Figure 6: Matla Unit 4 SOx Emissions - April 2021




Figure 7: Matla Unit 5 SOx Emissions - April 2021




Figure 8: Matla Unit 6 SOx Emissions - April 2021




Figure 9: Matla South Stack NOx Emissions - April 2021




Figure 10: Matla Unit 4 NOx Emissions - April 2021




Figure 11: Matla Unit 5 NOx Emissions - April 2021





Figure 12: Matla Unit 6 NOx Emissions - April 2021



7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1. PM Start-up information for the month of April-2021

South Stack	<i>Event 1</i>		<i>Event 2</i>		<i>Event 3</i>		<i>Event 4</i>	
Unit No.	<i>Unit 2</i>		<i>Unit 1</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)	<i>1:10 PM</i>	<i>2021/04/11</i>						
Draught Group (DG) Shut Down (SD)	<i>1:50 PM</i>	<i>2021/04/12</i>						
BO to DG SD (duration)	<i>01:00:40</i>	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	<i>1:00 AM</i>	<i>2021/04/16</i>						
Synch. to Grid (or BC)	<i>9:40 AM</i>	<i>2021/04/16</i>						
Fires in to BC (duration)	<i>00:08:40</i>	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	<i>11:00 AM</i>	<i>2021/04/17</i>						
Emissions below limit from BC (duration)	<i>01:01:20</i>	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

South Stack ...cont.	<i>Event 5</i>		<i>Event 6</i>		<i>Event 7</i>		<i>Event 8</i>	
Unit No.	<i>no event</i>		<i>no event</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 4	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 5	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	1:50 AM	2021/04/07						
Draught Group (DG) Shut Down (SD)	1:50 AM	2021/04/07						
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	4:45 AM	2021/04/09						
Synch. to Grid (or BC)	4:50 PM	2021/04/09						
Fires in to BC (duration)	00:12:05	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	8:00 AM	2021/04/13						
Emissions below limit from BC (duration)	03:15:10	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 6	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	BO previously	BO previously	10:45 PM	2021/04/17	10:35 PM	2021/04/29		
Draught Group (DG) Shut Down (SD)	n/a	n/a	10:45 PM	2021/04/17	10:35 PM	2021/04/29		
BO to DG SD (duration)	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	7:10 PM	2021/04/04	3:00 AM	2021/04/19	10:35 PM	2021/04/29		
Synch. to Grid (or BC)	8:00 AM	2021/04/05	9:00 AM	2021/04/19	6:40 AM	2021/04/30		
Fires in to BC (duration)	00:12:50	DD:HH:MM	00:06:00	DD:HH:MM	00:08:05	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	12:00 AM	2021/04/09	12:00 AM	2021/04/21	8:00 PM	2021/05/01		
Emissions below limit from BC (duration)	03:16:00	DD:HH:MM	01:15:00	DD:HH:MM	01:13:20	DD:HH:MM		DD:HH:MM

7.2: Point Source emissions released during start-up (fires-in) and Shut-down (SD) for the month of April-2021 in mg/Nm³


[Include reference to once off test showing typical emissions rates during fires in and SD]


Remember to add attachments here; see ReportAddendum Tab


Reserved for Addendum XXXX

11 General

South Stack gases not working therefore reliability fell below 80% and QAL2 averages used.
Unit 6 has 1 day of exceedance(1203mg/Nm3).
Unit 4 maxed out on the 29-04-2021(436,3mg/Nm3).


11-05-2021
Boiler Engineering Date


17/05/2021
General Manager Date


2021-05-17
Environmental Department Date

Compiled by: Boiler Engineering Department

For: Department of Environmental Affairs and Tourism

Copies: Eskom Environmental Management

Group Technology Engineering

Matla Power Station:

ESP & SO₃ System Engineer

Chief Air Pollution Control Officer

D Herbst
B Mccourt

R Rampiar
E. Patel

Engineering Manager
Operating Manager
Maintenance Manager
Unit Production Manager
Boiler Engineering Manager
System Engineer
Environmental Officer
Performance and Test
Production Manager

