

Ms Mpho Nembilwi
Air Quality Officer
Nkangala District Municipality
P O Box 437
MIDDELBURG
1050

Date:
27 May 2021

Enquiries:
Livhuwani Tshilate
017 615 2317

Ref: 17/4/AEL/MP312/11/09

Dear Ms Nembilwi

KRIEL POWER STATION'S ANNUAL EMISSIONS REPORT FOR FY 2020/21

This serves as the annual report required in terms of Section 7.6 in Kriel Power Station's Atmospheric Emission License, as well as in terms of other reporting requirements listed in the Minimum Emission Standards. The emissions are for Eskom's 2019/20 financial year which is from 1 April 2020 to 31 March 2021. Verified emissions of particulates, SO₂ and NO_x as measured by installed CEMS as well as calculated emissions for CO₂ and N₂O are included.

Name, description and reference number of plant as specified in the AEL:

Name of facility	Eskom Holdings SOC Limited- Kriel Power Station
Description of facility	Coal fired electricity generation
Reference number of plant	Ref. 17/4/AEL/MP312/11/09

Emission Trends:

The emissions in the table below are that of the 2020/2021 financial year.

Table 1: General oversight of emissions at Kriel Power Station 2020/2021

Power Station	Coal-fired emissions (tons/annum)	Fuel-oil emissions (tons/annum)	Total (tons/annum)
Kriel Power Station	CO₂: 8 709 085	CO₂: 150 036	CO₂: 8 859 121
	N₂O: 66.75	N₂O: not calculated	N₂O: 66.75
	PM: 5839.6	PM: not calculated	PM: 5839.6
	SO₂: 107 523	SO₂: 22.57	SO₂: 107 545.57
	NO_x: 48 621.1	NO_x: not calculated	NO_x: 48 621.1

Generation Division
Kriel Power Station
Ogies & Bethal Road
Private Bag X 5009 Kriel 2271 SA
Tel +27 17 615 2000 Fax +27 17 615 2326 www.eskom.co.za




Figure 1: Monthly Particulate Emissions in tons from Kriel Power Station 2020/2021



Figure 2: Monthly SO₂ emissions in tons from Kriel Power Station 2020/2021




Figure 3: Monthly NO₂ emissions in tons from Kriel Power Station 2020/2021



Figure 4: Monthly CO₂ emissions in tons from Kriel Power Station 2020/2021




Figure 5: Monthly Energy sent out in GWh at Kriel Power Station 2020/2021

Monitoring data availability

In terms of Section 18 (c) of the Minimum Emissions Standards, it is a requirement that Kriel Power Station reports on the availability of its continuous emission monitors (PM, SO_x and NO_x).

Table 2: Monitoring Data availability for Kriel Power Station 2020/2021

Pollutants	North Stack	South Stack	Remarks
PM	88.01%	97.2%	-PM monitors were within the MES specified threshold for monitor availability.
SO ₂	97.3%	98.7%	- SO _x monitors were within the MES specified threshold for monitor availability.
NO _x	92.7%	94.3%	- NO _x monitors were within the MES specified threshold for monitor availability.

Compliance Audit Report(s):

There was no compliance audit held in the 2020/21 financial year.

Major upgrades projects:

High Frequency Transformer (HFT) project planned for the 2021/22 financial year.

Greenhouse gas emissions:

The CO₂ and N₂O emissions have been outlined in the tables and graphs above.

Results of correlation tests:

Table 3: Overview of dates of last conducted CEMS verification tests for PM, SO₂ and NO_x (Please see attached Correlations Reports)

Activity	Test Completion Date	Validity
Parallel test for gas monitors	North Stack October 2020	2 years
	South Stack October 2020	
Correlations tests for PM ₁₀ monitors	North Stack November 2019	2 years
	South Stack November 2019	

An explanation of all instances where minimum emission standards were exceeded:

All average exceedances are reported and outlined in the monthly emission reports sent to your offices. A summary of the NEMA Section 30 incidents reported to the DEFF has been included below.

Table 4: Overview of NEMA Section 30 incidents for 2020/221 financial year

Stack	Exceedance dates [from – to]	Reason for exceedance	Remediation measure and effectiveness	Effectiveness	Status
South Stack	30/08/2020 to 06/09/2020	- High hopper levels and ash transportation backlog at unit 5 due to MCB level indicator trip.	- Raising a system deficiency. - Restoring the tripped MCB hopper level indicator. - Conducting training on the DHP on time mode. - Repairing and calibration of unitized dust monitors affected by the incident.	- Measures effective, emissions averaged around 109.35 mg/Nm ³ after the repair.	- Under review by the EMLs
North Stack	07/12/2020 to 18/12/2020	-Failure of 11Kv overhead line due to development of hotspots on the conductor.	- Repair of the defective 11KV overhead line. - Restoration of 18A & 18B conveyor belt. - Refurbish and commission the existing 11KV overhead line. - Repair the	- Measures effective, emissions averaged around 115 mg/Nm ³ after the measures to curb against high emissions were implemented.	- Under review by the EMLs (Ref:14/7/6/2/4/2/1735) . Further incident representation submitted to DEFF based on their guidance.

			defective Stuck Hammers at Unit 1& 2 ESPs		
North Stack	29/12/2020 to 31/01/2021	-Design liability on heat transfer.	- Misfiring SO ₃ electric heater due to heater phase failure - Contaminated Sulphur in the storage tank.	-	- Under review by the EMLs
North Stack	01/02/2020 to 19/02/2020	-Failure of SO ₃ Program Logic Controller system -Power supply failure into the compressor plant	-Source in the service of SO ₃ plant OEM to review all the control logic of the plant -Investigate the cause of the power failure -Ensure availability of Sulphur standby pump. -Repair the Process Airflow Measurement -Clearing of Unit 03 hopper levels -Source in the mobile service air compressor. -Repair the defective SO ₃ plant power pack at Unit 01.	- Measures effective, emissions averaged normalized after the repairs.	- Under review by the EMLs
South Stack	12/02/2021 to 21/02/2021	-Malfunction of the Unit 04 SO ₃ heater	-Repair the defective SO ₃ plant power pack at Unit 04 -Repair the defective SO ₃ plant heater at Unit 04 -Investigate the cause of the power pack failure in the SO ₃ plant	- Measures effective, emissions trended down and averaged around 74 mg/Nm ³ after the repairs.	- Under review by the EMLs

			<ul style="list-style-type: none">-Repair burnt SO₃ blower motor at Unit 06-Clearing of Unit 04 & 06 hopper levels-Review the SO₃ PLC program to optimize plant performance		
--	--	--	---	--	--

NAEIS reporting:

Kriel Power Station submitted its annual report on the NAEIS system by the 31st of March 2021.

The rest of the information demonstrating compliance with the emission license conditions is supplied in the monthly emission reports sent to your office including notifications for Gaseous Emissions Monitors failure.

Hoping the above will meet your satisfaction.

Yours sincerely



Mofongwe Raphasha
KRIEL POWER STATION GENERAL MANAGER