

Mr. Vusi Mahlangu
Air Quality Officer
DEDET
Private bag X11215
NELSPRUIT
1200

Date:
20 July 2021

Enquiries:
Mariam Joseph
Tel +27 13 297 9828
Fax + 27 86 661 7663

Dear Mr. Mahlangu

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JUNE 2021

This serves as the monthly report required in terms of Section 6 in Arnot Power Station's Atmospheric Emission License. The emissions are for the month of June 2021, Verified emissions of particulates; SO₂ and NO_x (as NO₂) are also included.

Raw Materials and Products

Table1: Quantity of Raw Materials and Products used/produced for the Month of June 2021

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption/ Rate in Month of June
	Coal	Tons/month	1 050 330	518 536.66
	Fuel Oil	Tons/month	10 000	2144.78
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of June 2021
	Energy	GWh	1 785 600	946 462
	Ash	Tons/month	421 000	126 159.97

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JUNE 2021

Abatement Technology

Table 2: Abatement Equipment Control Technology for month of June 2021

Associated Unit/Stack	Technology Type	Actual Utilisation (%) for the month of June 2021
North Stack	Fabric Filter Bags	99.7%
South Stack	Fabric Filter Bags	99.9%

Table 2.1 Abatement Equipment Efficiency (%) for the month of June

Associated Unit/Stack	Technology Type	Efficiency Jun-2021
North	<i>Fabric Filter Plant (FFP)</i>	100%
South	<i>Fabric Filter Plant (FFP)</i>	100%

Energy Source Characteristics

Table 3: Energy Source Material Characteristics for the month of -June 2021

Characteristic	Stipulated Range (Unit)	Monthly Average Content
Sulphur Content	0.5 to < 1 (%)	0.592
Ash Content	17 to < 40 (%)	24.33

Table 4 Operating days in compliance to PM AEL Limit –June 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
North	30	0	0	0	0	66.4
South	30	0	0	0	0	35.9
SUM	60	0	0	0	0	

Table 5 Operating days in compliance to NOx AEL Limit – June 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm ³)
North	30	0	0	0	0	805.9
South	30	1	0	0	0	673.5
SUM	60	1	0	0	0	

Table 6: Operating days in compliance to SOx AEL Limit –June 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm ³)
North	30	0	0	0	0	1389.5
South	30	0	0	0	0	1206.7
SUM	60	0	0	0	0	

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JUNE 2021

Emissions Reporting





Figure 1: PM emissions (daily averages) for the month of June 2021 against emission limit for the North Stack



ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JUNE 2021

Figure 2: PM emissions (daily averages) for the month of June 2021 against emission limit for the South Stack





Figure 3: SO₂ emissions (daily averages) for the month of June 2021 against emission limit for the North Stack



ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JUNE 2021

Figure 4: SO₂ emissions (daily averages) for the month of June -2021 against emission limit for the South Stack





Figure 5: NO₂ emissions (daily averages) for the month of June -2021 against emission limit for the North Stack



ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JUNE 2021

Figure 6: NO₂ emissions (daily averages) for the month of June -2021 against emission limit for the South Stack

Table 4: Monthly tonnages for the month of June 2021

Unit	PM (tons)	SO ₂ (tons)	NO ₂ (tons)
Total Tons (North & South Stack)	175.4	4562.8	2608.4

Table 5: Monitor Availability

Unit	PM (%)	SO ₂ (%)	NO ₂ (%)
North Stack	99.9	96.4	99.3
South Stack	100.0	87.6	87.8

Table 6: Each unit and respective days operating under normal operation, days in grace period, and section 30 days respectively

Unit	Days operating under normal operation	Days operating in grace period	Days operating under S 30
1	31	0	0
2	31	0	0
3	31	0	0
4	31	0	0
5	31	0	0
6	31	0	0

Light up information

Continuous reporting is being done even during start-ups, emissions were not affected.

Complaints Register

Table 7. Complaints for the month of June 2021

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

**ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JUNE
2021**

General

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission reports sent to your office.

Hoping the above will meet your satisfaction.

Compiled by



Lawrence Machebe

ENVIRONMENTAL OFFICER: ARNOT


Verified by



Nomathemba Mpulo

SENIOR TECHNOLOGIST: ARNOT


Supported by



Rofhiwa Tshikovha

SENIOR ENVIRONMENTAL ADVISOR: ARNOT

Yours sincerely



Samuel Tsoro Mashao

ACTING GENERAL MANAGER: ARNOT