

Ms Mpho Nembilwi
 Nkangala District Municipality
 PO BOX 437
 MIDDLEBURG
 1050

Date:
 20 June 2021

Enquiries:
 Livhuwani Tshilate
 017 615 2317

Ref: 17/4/AEL/MP312/11/09

Dear Ms Nembilwi

KRIEL POWER STATION'S MONTHLY STACK EMISSIONS REPORT FOR THE MONTH OF MAY 2021

This serves as the monthly report required in terms of Section 7.4 in Kriel Power Station's Atmospheric Emission License 17/4/AEL/MP312/11/09. The emissions are for the month of May 2021. Verified emissions of particulates matter, SO₂ and NO_x (as NO₂) are also included.

Raw Materials and Products

Table 1: Quantity of Raw Materials and Products used/produced for the month of May 2021

Raw Materials and Products used	Raw Material Type	Units	Maximum Permitted Consumption / Rate (Quantity)	Consumption / Rate in Month of 2021
	Coal	Tons/month	1 227 600	705 214.60
	Fuel Oil	Tons/month	5 000	2 383.11
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of May 2021
	Ash	Tons/month	not specified	568.6
	RE PM	kg/MWh	not specified	0.52 <i>(still to be verified)</i>

1/...

Abatement Technology

Table 2: Abatement Equipment Control Technology for May 2021.

Associated Unit/Stack	Technology Type	Minimum Control Efficiency	Actual Efficiency (%)
			May 2021
Unit 1	ESP	98%	99.70%
Unit 2	ESP	98%	99.64%
Unit 3	ESP	98%	99.72%
Unit 4	ESP	98%	Outage
Unit 5	ESP	98%	99.64%
Unit 6	ESP	98%	99.64%

Energy Source Characteristics

Table 3: Energy Source Material Characteristics for the month of May 2021


Characteristic	Stipulated Range (Unit)	Monthly Average Content
Sulphur Content	0.6-1.2 (%)	0.80
Ash Content	21-36 (%)	26.23

Monthly Monitor Reliability

Associated Unit/Stack	PM (%)	SOx (%)	NOx (%)
North	87.36%	87.49%	87.49%
South	96.5%	100%	100%

Emissions Reporting

Graph Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions




Figure 1: PM emissions for the month of May 2021 against emission limit for the North Stack; monthly average was 123.51mg/Nm³




Figure 2: PM emissions for the month of May 2021 against emission limit for the South Stack; monthly average 103.5mg/Nm³




Figure 3. SO₂ emissions for the month of May 2021 against emission limit for the North Stack. The SO_x Limit is 3500mg/Nm³.




Figure 4. SO₂ emissions for the month of May 2021 against emission limit for the South Stack. The SO_x Limit is 3500mg/Nm³.




Figure 5. NO₂ emissions for the month of May 2021 against emission limit for the North Stack. The NO_x Limit is 1600mg/Nm³.




Figure 6. NO₂ emissions for the month of May 2021 against emission limit for the South Stack. The NO_x Limit is 1600mg/Nm³.

Table 4: Monthly tonnages for the month May 2021

Unit	PM (tons)	SO ₂ (tons)	NO ₂ (tons)
SUM	568.6	11 018.9	5 730.4

Table 5: Each unit and respective days operating under normal operation and section 30 days respectively

Table 5.1: Operating days in compliance to PM AEL Limit - May 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Monthly Limit Exceedance	Average PM (mg/Nm ³)
North	26	5	0	0	0	123.5
South	31	0	0	0	0	103.5

Table 5.2: Operating days in compliance to SOx AEL Limit - May 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Daily Exceedance	Average SOx (mg/Nm ³)
North	31	0	0	0	0	2 146.4
South	31	0	0	0	0	2 362.6

Table 5.3: Operating days in compliance to NOx AEL Limit - May 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Daily Exceedance	Average NOx (mg/Nm ³)
North	31	0	0	0	0	1 229.9
South	31	0	0	0	0	1 090.5

Light up information

Table 6: PM Start-up information for the month of May 2021

North Stack	Event 1		Event 2	
Unit No.	Unit 1		Unit 1	
Breaker Open (BO)	11:45 AM	2021/05/08	1:45 PM	2021/05/19
Draught Group (DG) Shut Down (SD)	11:50 PM	2021/05/08	5:00 AM	2021/05/20
BO to DG SD (duration)	00:12:05	DD:HH:MM	00:15:15	DD:HH:MM
Fires in time	9:10 PM	2021/05/13	2:30 AM	2021/05/23
Synch. to Grid (or BC)	5:55 AM	2021/05/16	9:25 AM	2021/05/23
Fires in to BC (duration)	02:08:45	DD:HH:MM	00:06:55	DD:HH:MM
Emissions below limit from BC (end date)	12:00 AM	2021/04/25	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM
North Stack ...Cont.	Event 3		Event 4	
Unit No.	Unit 3		Unit 1	
Breaker Open (BO)	6:50 AM	2021/05/16	11:35 PM	2021/05/29
Draught Group (DG) Shut Down (SD)	8:05 PM	2021/05/16	DG did not trip or SD	DG did not trip or SD
BO to DG SD (duration)	00:13:15	DD:HH:MM	n/a	DD:HH:MM
Fires in time	9:15 PM	2021/05/21	11:35 PM	2021/05/29
Synch. to Grid (or BC)	5:40 PM	2021/05/22	5:10 AM	2021/05/30
Fires in to BC (duration)	00:20:25	DD:HH:MM	00:05:35	DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM

Complaints Register

Table 7: Complaints for the month of May 2021.

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
There was no complaint related to air quality received during the month of May 2021.					

General

The particulate matter (PM10) emissions on the north and south common stacks were within the **monthly limit** during the month of May 2021; North stack recorded the monthly PM10 average emissions figure of **123.5 mg/Nm³** while south stack recorded PM10 monthly average figure of **103.5 mg/Nm³**. The gaseous (NOx & SOx) emissions on the north and south common stacks were also within the **daily limit** during the month of May 2021; refer to graphs above.

NB: The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission reports sent to your office.

Kriel Power Station’s List of NEMA Section 30 Incidents for 2021/2022 Financial Year

Month	Description of Section30 Incidents - including the reference number	Root Cause (s)	Status of S30 Incident with DEFF (open or closed)	Remarks
April - 2021	Upset condition in Units 1, 2 & 3 (north stack) exceeded 48 hours grace period.	<ul style="list-style-type: none"> Caslet key system failure Defective pyrometers 	Open	1 event reported.
May - 2021	No section 30 incident reported.			No event to report.