

Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		

Enquiries: TR. Rammutla

Tel: 014 762 6375

Phumudzo Thivhafuni Date: 2021/07/15

Limpopo Dept. of Economic Development, Environment and

Tourism

Private Bag 9484 POLOKWANE 0700

ThivhafuniPO@ledet.gov.za

Ref: 12/4/12L-W2/A3 - Apr 2020 Rev.1

Dear Phumudzo

MEDUPI POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL 2020

This document serves as the monthly report required in terms of Section 7.7.1 of Medupi Power Station Provisional Atmospheric Emission License (AEL), 12/4/12L-W2/A3.

This report is a reflection of Unit 2, 3, 4, 5 and 6 gaseous and particulate emissions performance against the AEL limit for the month of April 2020 only.

1. Raw Materials and Products

Table 1: Quantity of raw materials and products for Unit 2, 3, 4, 5 and 6 in April 2020

Raw Materials and	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Unit 2,3, 4, 5 and 6 consumption April 2020
Products	Coal	Tons/month	1 875 000	498 337
used	Fuel Oil	Tons/month	40 000	3757.0
Production Rates	Product/ By- Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Unit 2, 3, 4, 5 and 6 Production Rate in Month of April 2020
	Energy	MW	4 800	2072
	Ash Emitted	Tons/month	not specified	156

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.




Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		

Table 2: Daily consumption and production rates

	Reportable hours of Operation				n	Fu	el Cons	umption	(tons)	Production (MW)
Date	2	m	4	2	9		Oil		Coal	Units
Date	Unit 2	Unit	Unit 4	Unit 5	Unit	Aux Boiler	Units	Total	Units	2,3,4,5 &6
01- Apr-20	24,0	0,0	24,0	24,0	0.0	0	14	14	19100	1684
02- Apr -20	24,0	0,0	24,0	21,2	0.0	0	23	23	18409	1637
03- Apr -20	24,0	0,0	24,0	0,0	0.0	0	10	10	17931	1175
04- Apr -20	24,0	0,0	24,0	0,0	0.0	0	13	13	13341	1208
05- Apr -20	24,0	0,0	24,0	0,0	0.0	0	21	21	13621	1128
06- Apr -20	24,0	0,0	24,0	0,0	0.0	0	0	0	13050	1107
07- Apr -20	24,0	0,0	24,0	0,0	0.0	0	91	91	12625	1115
07- Apr -20	24,0	0,0	24,0	0,0	0.0	0	285	285	12493	1558
09- Apr -20	24,0	0,0	24,0	12,7	0.0	0	90	90	15482	1736
10- Apr -20	24,0	0,0	24,0	24,0	0.0	0	32	32	18922	1623
11- Apr -20	15,3	0,0	24,0	24,0	0.0	0	12	12	18112	1633
12- Apr -20	0,0	0,0	24,0	24,0	0.0	0	132	132	15858	1285
13- Apr -20	0,0	0,0	24,0	24,0	0.0	0	569	569	13147	1283
14- Apr -20	0,0	0,0	24,0	24,0	0.0	0	620	620	12728	1398
15- Apr -20	0,0	0,0	24,0	24,0	0.0	0	0	0	12607	1059
16- Apr -20	0,0	0,0	24,0	24,0	0.0	0	40	40	11503	1063
17- Apr -20	0,0	0,0	24,0	24,0	0.0	0	8	8	11475	1061
18- Apr -20	0,0	0,0	24,0	24,0	0.0	0	0	0	11776	1840
20- Apr -20	13,0	0,0	24,0	24,0	0.0	0	437	437	15833	1912
20- Apr -20	24,0	0,0	24,0	8,6	0.0	0	190	190	20642	1958
21- Apr -20	24,0	18,3	24,0	0,0	0.0	0	63	63	19351	1635
22- Apr -20	24,0	24,0	24,0	0,0	0.0	0	18	18	19943	1762
23- Apr -20	24,0	24,0	24,0	0,0	0.0	0	34	34	20565	1779
24- Apr -20	24,0	24,0	24,0	0,0	0.0	0	11	11	20720	1768
25- Apr -20	20,8	24,0	0,0	0,0	0.0	0	4	4	14565	2426
26- Apr -20	0,0	24,0	23,9	0,0	0.0	0	73	73	15055	1655
27- Apr -20	20,4	24,0	24,0	0,0	0.0	0	130	130	18538	1587
28- Apr -20	24,0	24,0	16,9	0,0	0.0	0	172	172	17324	1593
29- Apr -20	24,0	24,0	0,0	0,0	0.0	0	444	444	16482	1780
30- Apr -20	24,0	24,0	0,0	8,6	0.0	0	220	220	17014	2126

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



2. Abatement Technology

Table 3: Abatement Equipment Control Technology utilisation for month of April 2020

Associated Unit/Stack	Technology Type	Efficiency
Unit 1	Fabric Filter Plant (FFP)	-
Unit 2	Fabric Filter Plant (FFP)	99,787%
Unit 3	Fabric Filter Plant (FFP)	99,999%
Unit 4	Fabric Filter Plant (FFP)	99,732%
Unit 5	Fabric Filter Plant (FFP)	99,955%
Unit 6	Fabric Filter Plant (FFP)	-

3. Energy Source Characteristics

Table 4: Energy Source Material Characteristics for the month of April 2020

Characteristic	Stipulated Range Monthly Average Content (% by weight on a dry basis) (% by weight on a dry basis)		
	Coal		
Sulphur Content	1.3 - 2.2	1.430	
Ash Content	35 - 39	34.800	

4. Emissions Reporting

Medupi Power Station uses Continuous Emission Monitoring System which uses the extractive method for analysis.

The emission limits are as follows:


SO₂ Monthly = 3500 mg/Nm³ Dust Daily= 50 mg/Nm³ NO₂ Daily= 750 mg/Nm³


CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.




Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		












CONTROLLED DISCLOSURE




Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021	I	
Review Date	January 2024		












CONTROLLED DISCLOSURE




Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021	I	
Review Date	January 2024		









CONTROLLED DISCLOSURE



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		

Table 5: Monthly tonnages for the month of April 2020

Associated Unit/Stack	PM	SO ₂	NO ₂	со
Unit 1	•	•	•	-
Unit 2	39,7	4 280	716	19
Unit 3	1,7	1 131	169	24
Unit 4	89,2	4 738	584	48
Unit 5	25,3	2 991	487	7
Unit 6	-	-	-	-
SUM	156,0	13 140	1 956	99

5. Comments on the performance and availability of each unit

Medupi power station unit 6 was on outage for the duration of reporting period. Unit 5 had 15 day unreportable days during the month on April 2020, the unit has been offload during this period. There was no exceedance for SOx and NOx at Unit 5 in the month of April 2020. Unit 5 PM limit was exceeded on the last day of April, this was categorised under grace period for light up. Unit 4 recorded 9 PM exceedances which are reported as contravention in this report, SOx and NOx were within the limit as prescribed by Medupi AEL.

Unit 3 SOx and NOx were well within the ambit of the licence during the reporting period. There were no emissions exceedances recorded in unit 3 during the reporting period.

6. Continuous Emission Monitoring Systems (CEMS)

Unit 2, 3 4, 5 and 6 Continuous Emission Monitoring Systems were in operation at all times when the unit was on load.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		

Table 6: Periods during which CEMS was inoperative

Date	Time	CEMS status	Comments
21-31 April 2020	N/A	Unit 3 PM monitor faulty	The ball valve controlling the flow through the instrument wasn't actuating correctly preventing the extracted gas from flowing through the measuring cell.

Table 7: CEMS Monitor Reliability

Associated Unit/Stack	PM	SO ₂	NOx	O ₂
Unit 2	99,9	99,0	99,0	95,5
Unit 3	100,0	81,7	92,2	85,8
Unit 4	99,5	99,5	99,2	99,5
Unit 5	99,1	99,2	99,0	98,1
Unit 6	-	-	=	-

7. CEMS Calibration certificates and equipment used for calibration

See attached Appendix A

8. Ambient Air Quality Monitoring Report

The ambient air data reporting of both March and April 2020 were affected by the COVID-19 lock-down. The Department of Environment, fisheries and forestry was notified of the letter dated 31 March 2020.

9. Visual inspection of the exterior walls of the fuel oil tanks and TVOC Estimation

Visual inspection was conducted and there were no leaks observed on the exterior walls of the fuel oil tanks.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.




Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		

Table 8: Total Volatile Organic Compound (TVOC) for April 2019

CALCULATION	OF EMISSIONS OF TOTAL VOLATILE COMPOU	INDS FROM FUEL OIL ST	ORAGE TANKS
	I		
Date:	Thursday, 30 April 2020		
Station:	Medupi Power Station		
Province:	Limpopo Province		
Tank no.	1-2		
Description:	Outdoor fuel oil storage tank		
Tank Type:	Vertical fixed roof (vented to atmosphere)		
Material stored:	Fuel Oil 150	E CTATION	
	MONTHLY INPUT DATA FOR TH		
	Please only insert relevant monthly data inputs Choose from a dropdown menu in ti		
	The total VOC emissions for the month a		
	IMPORTANT: Do not change <u>any</u> other cells with		
MONTH:	April	out consulting the AQ COE	
GENERAL INFO	· · · · · · · · · · · · · · · · · · ·	Data	Unit
Total number of	-	2	NA NA
Height of tank:*	ruei oli tariks:	14,2	m NA
Diameter of tank.	,	14,2	m
	ighput for the month:	3757	tons/month
Molecular weigh	<u> </u>	166,00	Lb/lb-mole
	AL DATA FOR THE MONTH	Data	Unit
		1	°C
Daily average uniform temperature			°C
Daily maximum ambient temperature 27,37 Daily minimum ambient temperature 13,11			°C
-		· ·	°C
Daily minimum a	mperature range	10.46	
Daily minimum a Daily ambient te	mperature range tion factor	10,46 3.84	kWh/m²/day
Daily minimum a Daily ambient te Daily total insola	tion factor	3,84	kWh/m²/day NA
Daily minimum a Daily ambient te Daily total insola Tank paint colou	tion factor		kWh/m²/day NA NA
Daily minimum a Daily ambient te Daily total insola Tank paint colou Tank paint solar	tion factor r absorbtance	3,84 Aluminum/Specular	NA
Daily minimum a Daily ambient tel Daily total insola Tank paint colou Tank paint solar FINAL OUTPUT:	tion factor r absorbtance	3,84 Aluminum/Specular 0,39 Result	NA NA Unit
Daily minimum a	tion factor r absorbtance	3,84 <u>Aluminum/Specular</u> 0,39 Result	NA NA

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



10. Air quality improvements initiatives and public education and awareness campaigns

No awareness campaign.

11. Complaints Register

Table 9: Complaints for the month of April 2019

Source Code/ Name	Air pollution complaints received	Calculation of Impacts/ emissions associated with the incident	Date of complaint and date of response by the license holder	Results of investigation	Action taken to resolve the complaint
N/A	No complaints received	N/A	N/A	N/A	N/A

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		

Compiled by:	Lufuno Tshidzumba Advisor Senior Environmental Advisor
Verified by:	Malose LangaSystem Engineer Boiler
Supported by:	Sithokozile Hlongwa pp Doller Engineering Manager
Supported by:	Rosetta Rammutla_ <i>TR Rammutla</i>
Supported by:	Jabulani Mkhatshwa

-101

I Dan Mashigo, declares that the information provided in this report is accurate and correct.

Engineering Group Manager

Yours sincerely

Dan Mashido

GENERAL MANAGER: MEDUPI POWER STATION (Acting)

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		

APPENDIX 1: CEMS Calibration certificates

Elemental

Analytics....

12 Angeller Street, Bardene, BOKSBURG, SA, 1459 PO Box 328, ISANDO, SA, 1600 VAT REG #: 421 021 2249 www.e-analytics.co.za Tel: 0861 000 032 Intl. Tel: +27 11 918 6994 Fax: +27 11 894 1037 CO REG #: 2004/007607/07 Info@e-analytics.co.za

CALIBRATION CERTIFICATE

		CERTIFICATE NO:	
			3416
CUSTOMER:	Eskom Medupi	JOB NO:	SC1665
CONTACT NAME:	Lerato Sehume	PHONE:	078 012 9038
MODEL:	Dr Fodisch MGA 23	SERIAL NO:	13669
AUXILIARYEQUIPMENT:	Unit 6	•	

CI	HAN	PRIOR	FINAL	TEST GAS	TEST GAS VALUE	GAS CERTIFICATE NUMBER	EXPIRY DATE
	ZERO	1 ppm	0 ppm	Air	21.0 %	Air	N/A
١'	SPAN	834 ppm	835 ppm	CO	834.6 ppm	3204	03-02-2021
	ZERO	-2 ppm	0 ppm	Air	21.0 %	Air	N/A
2	SPAN	908 ppm	877 ppm	NO	876.7 ppm	12598	21-01-2021
3	ZERO	-47 ppm	0 ppm	Air	21.0 %	Air	N/A
,	SPAN	2584 ppm	2584 ppm	302	2161.7 ppm	5905E	15-05-2020
	ZERO	0.03 %	0.0 %	N2	99.99 %	82410	31-08-2020
4	SPAN	20.39 %	20.95 %	02	20.95 %	Air	N/A

REPORT: SO2 cell diagnostics is low and cell module should be inspected. Inspect all sample lines, filters and rotameter. Calibrate analyser with zero and span gas, calibration was done according to cylinder standards, analyser was responding to all test gas.

Date of Calibration: 25 Feb 2020

Calibration Due Date: May 2020

Technician: J Faber







CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		



12 Angeller Street, Bardene, BOKSBURG, SA, 1459 PO Box 328, ISANDO, SA, 1600 VAT REG #: 421 021 2249 Www.e-analytics.co.za Tel: 0861 000 032 Intl. Tel: +27 11 918 6994 Fax: +27 11 894 1037 CO REG #: 2004/007607/07 Info@e-analytics.co.za

CALIBRATION CERTIFICATE

		CERTIFICATE NO:	
			3415
CUSTOMER:	Eskom Medupi	JOB NO:	SC1665
CONTACT NAME:	Lerato Sehume	PHONE:	078 012 9038
MODEL:	Dr Fodisch MGA 23	SERIAL NO:	13670
AUXILIARYEQUIPMENT:	Unit 5	•	

Ci	HAN	PRIOR	FINAL	TEST GAS	TEST GAS VALUE	GAS CERTIFICATE NUMBER	EXPIRY DATE
ZERO		3 ppm	0 ppm	Air	21.0 %	Air	N/A
٠.	3PAN 856 ppm	856 ppm	835 ppm	co	834.6 ppm	3204	03-02-2021
	ZERO	0 ppm	0 ppm	Air	21.0 %	Air	N/A
-	SPAN	944 ppm	877 ppm	NO	876.7 ppm	12598	21-01-2021
	ZERO	-19 ppm	0 ppm	Alr	21.0 %	Air	N/A
١ ٠	SPAN	2262 ppm	2262 ppm	802	2161.7 ppm	5905E	15-05-2020
	ZERO	0.06 %	0.0 %	N2	99.99 %	82410	31-08-2020
4	SPAN	20.69 %	20.95 %	02	20.95 %	Air	N/A

REPORT: SO2 cell diagnostics is low and cell module should be inspected. Inspect all sample lines, filters and rotameter. Calibrate analyser with zero and span gas, calibration was done according to cylinder standards, analyser was responding to all test gas.

Date of Calibration: 25 Feb 2020
Calibration Due Date: May 2020

Technician: J Faber







CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		



12 Angeller Street, Bardene, BOKSBURG, SA, 1459 PO Box 328, ISANDO, SA, 1600 VAT REG #: 421 021 2249 www.e-analytics.co.za Tel: 0861 000 032 Intl. Tel: +27 11 918 6994 Fax: +27 11 894 1037 CO REG #: 2004/007607/07 Info@e-analytics.co.za

CALIBRATION CERTIFICATE

		CER	TIFICATE NO:
			3414
CUSTOMER:	Eskom Medupi	JOB NO:	SC1665
CONTACT NAME:	Lerato Sehume	PHONE:	078 012 9038
MODEL:	Dr Fodisch MGA 23	SERIAL NO:	13668
ALIXII JARVEGUIPMENT:	Unit 4		

AUXILIARYEQUIPMENT: Unit 4

c	HAN	PRIOR	FINAL	TEST GAS	TEST GAS VALUE	GAS CERTIFICATE NUMBER	EXPIRY DATE
ZERO		1 ppm	0 ppm	Air	21.0 %	Air	N/A
1	SPAN	846 ppm	835 ppm	co	834.6 ppm	3204	03-02-2021
	ZERO	-1 ppm	0 ppm	Air	21.0 %	Air	N/A
2	SPAN	920 ppm	877 ppm	NO	876.7 ppm	12598	21-01-2021
3	ZERO	-31 ppm	0 ppm	Alr	21.0 %	Air	N/A
-	SPAN	2384 ppm	2384 ppm	802	2161.7 ppm	5905E	15-05-2020
4	ZERO	0.07 %	0.0 %	N2	99.99 %	82410	31-08-2020
	SPAN	21.15 %	20.95 %	02	20.95 %	Air	N/A

REPORT: SO2 cell diagnostics is low and cell module should be inspected. Inspect all sample lines, filters and rotameter. Calibrate analyser with zero and span gas, calibration was done according to cylinder standards, analyser was responding to all test gas.

Date of Calibration: 25 Feb 2020 Calibration Due Date: May 2020

Technician: J Faber







CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	January 2021		
Review Date	January 2024		



12 Angeller Street, Bardene, BOKSBURG, SA, 1459 PO Box 328, ISANDO, SA, 1600 VAT REG #: 421 021 2249 www.e-analytics.co.za Tel: 0861 000 032 Intl. Tel: +27 11 918 6994 Fax: +27 11 894 1037 CO REG #: 2004/007607/07 Info@e-analytics.co.za

CALIBRATION CERTIFICATE

		CER	CERTIFICATE NO:		
			3412		
CUSTOMER:	Eskom Medupi	JOB NO:	SC1665		
CONTACT NAME:	Lerato Sehume	PHONE:	078 012 9038		
MODEL:	Dr Fodisch MGA 23	SERIAL NO:	15711		
AUXILIARYEQUIPMENT:	Unit 2				

Ci	HAN	PRIOR	FINAL	TEST GAS	TEST GAS VALUE	GAS CERTIFICATE NUMBER	EXPIRY DATE
ZERO		-2 ppm	0 ppm	Air	21.0 %	Air	N/A
٠.	SPAN 839 ppm	835 ppm	co	834.6 ppm	3204	03-02-2021	
	ZERO	-4 ppm	0 ppm	Air	21.0 %	Air	N/A
-	SPAN	856 ppm	877 ppm	NO	876.7 ppm	12598	21-01-2021
	ZERO	-38 ppm	0 ppm	Air	21.0 %	Air	N/A
١ ٠	SPAN	2220 ppm	2220 ppm	302	2161.7 ppm	5905E	15-05-2020
4	ZERO	0.14 %	0.0 %	N2	99.99 %	82410	31-08-2020
	SPAN	21.11 %	20.95 %	02	20.95 %	Air	N/A

REPORT: SO2 cell diagnostics is low and cell module should be replaced in future. Inspect all sample lines, filters and rotameter. Calibrate analyser with zero and span gas, calibration was done according to cylinder standards, analyser was responding to all test gas.

Date of Calibration: 25 Feb 2020
Calibration Due Date: May 2020

Technician: J Faber







CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.