Eskom		Template Identifier	240-43921804	Rev	6
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	January 2021		
		Review Date	January 2024		
Phumudzo Thivha	funi	ח	ate: 2021/07/15		

Limpopo Dept. of Economic Development, Environment and Tourism Private Bag 9484 POLOKWANE 0700 Date: 2021/07/15 Enquiries: TR. Rammutla Tel: 014 762 6375

ThivhafuniPO@ledet.gov.za

Ref: 12/4/12L-W2/A3 - June 2020 Rev.1

Dear Phumudzo

MEDUPI POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF JUNE 2020

This document serves as the monthly report required in terms of Section 7.7.1 of Medupi Power Station Provisional Atmospheric Emission License (AEL), 12/4/12L-W2/A3.

This report is a reflection of Unit 2, 3, 4, 5 and 6 gaseous and particulate emissions performance against the AEL limit for the month of June 2020 only.

1. Raw Materials and Products

 Table 1: Quantity of raw materials and products for Unit 2, 3, 4, 5 and 6 in June 2020

Raw Materials and	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Unit 2,3, 4, 5 and 6 consumption June 2020
Products	Coal	Tons/month	1 875 000	789 747
used	Fuel Oil	Tons/month	40 000	1444
Production Rates	Product/ By- Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Unit 2, 3, 4, 5 and 6 Production Rate in Month of June 2020
	Energy	MW	4 800	2957
	Ash Emitted	Tons/month	not specified	240.6

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	January 2021		1
		Review Date	January 2024		

Table 2: Daily consumption and production rates

	Report	table ho	ours of (Operatio	n	Fu	el Cons	umption	(tons)	Production (MW)
Date	2	e	4	5	9		Oil		Coal	Units
Date	Unit	Unit	Unit 4	Unit	Unit	Aux Boiler	Units	Total	Units	2,3,4,5 &6
01- Jun-20	24,0	24,0	24,0	24,0	0,0		30	30	25660	2318,1
02- Jun -20	24,0	24,0	24,0	24,0	0,0		22	22	24688	2392,2
03- Jun -20	24,0	24,0	24,0	24,0	0,0		3	3	26146	2524,1
04- Jun -20	24,0	24,0	24,0	24,0	0,0		15	15	26168	2535,8
05- Jun -20	24,0	24,0	13,3	24,0	0,0		0.0	0.0	25010	2557,6
06- Jun -20	24,0	24,0	0,0	24,0	0,0		149	149	23550	2498,3
07- Jun -20	24,0	24,0	22,8	24,0	0,0		130	130	27571	2540,3
08- Jun -20	5,5	24,0	24,0	24,0	0,0		4	4	26146	2363,3
09- Jun -20	15,3	24,0	24,0	24,0	0,0		0.0	0.0	26516	2413,1
10- Jun -20	19,6	24,0	24,0	24,0	0,0		44	44	25578	2465,7
11- Jun -20	0,0	24,0	24,0	24,0	0,0		0.0	0.0	19549	1836,7
12- Jun -20	0,0	24,0	24,0	24,0	0,0		0.0	0.0	17942	1680,3
13- Jun -20	0,0	22,6	24,0	24,0	0,0		13	13	18432	1760,1
14- Jun -20	0,0	0,0	24,0	24,0	0,0		2	2	12707	1354,9
15- Jun -20	4,8	0,0	24,0	24,0	0,0		0.0	0.0	17991	1773,7
16- Jun -20	24,0	3,2	24,0	24,0	0,0		154	154	25495	2357,8
17- Jun -20	24,0	24,0	24,0	24,0	0,0		0.0	0.0	26587	2424,7
18- Jun -20	24,0	24,0	24,0	24,0	0,0		6	6	30870	2652,9
19- Jun -20	24,0	24,0	24,0	24,0	17,0		0.0	0.0	31109	2488,4
20- Jun -20	24,0	24,0	24,0	24,0	24,0		521	521	28165	2206,6
21- Jun -20	24,0	24,0	24,0	24,0	24,0		0.0	0.0	31159	2385,5
22- Jun -20	24,0	24,0	24,0	24,0	24,0		60	60	33489	2582,4
23- Jun -20	24,0	24,0	24,0	24,0	24,0		0.0	0.0	34647	2535,3
24- Jun -20	24,0	24,0	24,0	11,5	24,0		214	214	32670	2349,1
25- Jun -20	24,0	24,0	24,0	6,5	24,0		6	6	34304	2557,3
26- Jun -20	24,0	24,0	24,0	24,0	24,0		5	5	34348	2435,1
27- Jun -20	24,0	24,0	24,0	24,0	24,0		0.0	0.0	31986	2247,5
28- Jun -20	24,0	24,0	24,0	24,0	24,0		24	24	30026	2248,4
29- Jun -20	24,0	24,0	24,0	24,0	24,0		42	42	32467	2484,3
30- Jun -20	24,0	24,0	24,0	24,0	24,0		0.0	0.0	33968	2530,3

Note: fuel oil consumption by the auxiliary boilers for the month of June was not verified.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	January 2021		
		Review Date	January 2024		

2. Abatement Technology

 Table 3: Abatement Equipment Control Technology utilisation for month of June 2020

Associated Unit/Stack	Technology Type	Efficiency
Unit 1	Fabric Filter Plant (FFP)	-
Unit 2	Fabric Filter Plant (FFP)	99,959%
Unit 3	Fabric Filter Plant (FFP)	99,967%
Unit 4	Fabric Filter Plant (FFP)	99,819%
Unit 5	Fabric Filter Plant (FFP)	99,882%
Unit 6	Fabric Filter Plant (FFP)	99,867%

3. Energy Source Characteristics

Table 4: Energy Source Material Characteristics for the month of June 2020

Characteristic	Stipulated Range (% by weight on a dry basis)	Monthly Average Content (% by weight on a dry basis)			
	Coal				
Sulphur Content	1.3 - 2.2	1.38			
Ash Content	35 - 39	34.5			

4. Emissions Reporting

Medupi Power Station uses Continuous Emission Monitoring System which uses the extractive method for analysis.

The emission limits are as follows:


 SO_2 Monthly = 3500 mg/Nm³ Dust Daily= 50 mg/Nm³ NO₂ Daily= 750 mg/Nm³


CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.


() Eskom		Template Identifier	240-43921804	Rev	6
	Medupi Power Station Monthly Emissions Report	Document Identifier240-88543153	240-88543153	Rev	2
		Effective Date	January 2021	L	
		Review Date	January 2024		

Medupi Power Station graphical representation of emissions data










CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database. No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.





AEL Limit U5 MW

100

0

(2) Eskom		Template Identifier	240-43921804	Rev	6
	Medupi Power Station Monthly Emissions Report	ns Report Document Identifier 240-88543153 Effective Date January 2021	Rev	2	
			January 2021		
		Review Date	January 2024		








CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database. No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Eskom		Template Identifier	240-43921804	Rev	6
	Medupi Power Station Monthly Emissions Report	hly Emissions Report	240-88543153	Rev	2
			January 2021		
		Review Date	January 2024		











CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database. No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

€skom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	January 2021		<u> </u>
		Review Date	January 2024		






Note: Point 31 on all graphs represent the 1st of July 2020. The figures above are deliberately numbered in a random fashion. There were issues with unit 5 NOx monitoring instrument in the beginning on of the month.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database. No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.



		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	January 2021		
		Review Date	January 2024		

Table 5: Monthly tonnages for the month of June 2020

Associated Unit/Stack	РМ	SO2	NO ₂	со
Unit 1	0.0	0	0	0
Unit 2	21,1	4 400	748	26
Unit 3	22,1	4 700	561	77
Unit 4	97,7	5 020	640	54
Unit 5	68,4	4 929	741	106
Unit 6	31,2	1 303	285	10
SUM	240,6	20 352	2 974	273

5. Comments on the performance and availability of each unit

Gaseous emissions on all units were within the limit for June reporting period. Exceedances due to upset conditions were evident on unit 4 and 5. Exceedances on unit 4 were reported in terms of NEMA s30. Unit 6 exceedances were only identified during data back-fitting and are as such reported as contraventions.

6. Continuous Emission Monitoring Systems (CEMS)

Unit 2, 3, 4, 5 and 6 Continuous Emission Monitoring Systems were in operation at all times when the unit was on load. Unit 5 and 6 NOx emissions monitoring instrument had issues between 1 and 11 June 2020.

Table 6: Periods during which CEMS was inoperative

Date	Time	CEMS status	Comments
1-11 June 2020	N/A	NOx monitor faulty	The monitor was fixed

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	January 2021		1
		Review Date	January 2024		

Table 7: CEMS Monitor Reliability

Associated Unit/Stack	РМ	SO₂	NOx	Oz
Unit 2	100,0	98,3	98,3	97,7
Unit 3	100,0	98,7	99,8	97,3
Unit 4	99,9	99,9	99,9	99,9
Unit 5	100,0	99,9	61,7	99,7
Unit 6	100,0	77,6	72,1	71,5

7. CEMS Calibration certificates and equipment used for calibration

See attached Appendix A

8. Ambient Air Quality Monitoring Report

The Ambient Air Quality Monitoring and Dust fall-out report are emailed to the Licensing authority on a monthly basis.

9. Visual inspection of the exterior walls of the fuel oil tanks and TVOC Estimation

Visual inspection was conducted and there were no leaks observed on the exterior walls of the fuel oil tanks.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	January 2021		<u> </u>
		Review Date	January 2024		

Table 8: Total Volatile Organic Compound (TVOC) for June 2020

(€) €ska	om			
_				
CALCULATION	OF EMISSIONS OF TOTAL VOLATI	LE COMPOU	NDS FROM FUEL OIL ST	ORAGE TANKS*
Date:	30 June 2020			
Station:	Medupi Power Station			
Province:	Limpopo Province			
Tank no.	1-2			
Description:	Outdoor fuel oil storage tank			
Tank Type:	Vertical fixed roof (vented to atmosphe	re)		
Material stored:	Fuel Oil 150			
	MONTHLY INPUT DA	ATA FOR THE	E STATION	
	Please only insert relevant monthly	y data inputs	into the <u>blue cells</u> below	
	Choose from a dropdov		· · · · · · · · · · · · · · · · · · ·	
	The total VOC emissions for	the month a	are in the <u>red cells</u>	
	IMPORTANT: Do not change any ot	her cells witho	out consulting the AQ CoE	
MONTH:	June			
GENERAL INFO	RMATION:		Data	Unit
Total number of	fuel oil tanks:		2	NA
Height of tank:*			14.2	m
Diameter of tank	:		12	m
Net fuel oil throu	ighput for the month:		<u>1444</u>	tons/month
Molecular weigh	t of the fuel oil:		166.00	Lb/lb-mole
METEROLOGIC	AL DATA FOR THE MONTH		Data	Unit
Daily average an	nbient temperature		16.61	°C
Daily maximum a	mbient temperature		25.19	°C
Daily minimum ar	nbient temperature		9.38	°C
Daily ambient ter	nperature range		15.81	°C
Daily total insola	tion factor		3.45	kWh/m²/day
Tank paint colou	r		<u>Aluminum/Specular</u>	NA
Tank paint solar	absorbtance		0.39	NA
FINAL OUTPUT:			Result	Unit
Breathing losses	5:		0.71	kg/month
Working losses:			0.04	kg/month
TOTAL LOSSES	(Total TVOC Emissions for the mont	h):	0.75	kg/month
	erformed on this spreadsheet are taken fi		PA AP-42- Section 7.1 Orga	nic Liquid Storage

*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail -PeressJ@nyc.rr.com.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	January 2021		
		Review Date	January 2024		

10. Air quality improvements initiatives and public education and awareness campaigns

No awareness campaign.

11. Complaints Register

Table 9: Complaints for the month of June 2020

Source Code/ Name	Air pollution complaints received	Calculation of Impacts/ emissions associated with the incident	Date of complaint and date of response by the license holder	Results of investigation	Action taken to resolve the complaint
N/A	No complaints received	N/A	N/A	N/A	N/A

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	January 2021		
		Review Date	January 2024		

Compiled by:	Lufuno Tshidzumba
Verified by:	Malose Langa System Engineer Boiler
Supported by:	Sithokozile Hlongwa_pp
Supported by:	Rosetta Rammutla <u>TR Rammutla</u> Environmental Manager
Supported by:	Jabulani Mkhatshwa Engineering Group Manager

I Dan Mashigo, declares that the information provided in this report is accurate and correct.

Yours sincerely

Dan Mashigo

GENERAL MANAGER: MEDUPI POWER STATION (Acting)

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

										Template Ident	ifier	240-43921804			Rev	6
₿€	skom			Mee	dupi	i Power Station	Monthly Emiss	ions Repo	rt	Document Iden	Document Identifier240-88543153Rev				1	
										Effective Date		January 2018				
										Review Date		January 2021				
Elemental Elemental Elemental Elemental Elemental Elemental Elemental Elemental Elemental Elemental Elemental Elemental Elemental	12 Angelier Street BOKSBURG, SA, PO Box 323, ISAN VAT REG #: 4210 www.e-ansiviles.co	1459 DO, SA, 1600 21 2249	Fax: CO REG #	0861 000 032 +27 11 918 6994 +27 11 954 1037 : 2004/007607/07 Shries.co.za		A	PPENDIX 1: CE 12 Angelier Stree BOKSBURG, SA, PO Box 328, ISAV VAT REG #: 4211 www.e-snahrlica.co	t, Bardene, 1459 IDO, BA, 1600 221 2249	Tel: Inti. Tel: Fax:	0861 000 032 +27 11 918 6994 +27 11 894 1037 2004/007607/07	Elemental Augure Speciality	12 Angeller Stret BOKSBURG, 3A PO Box 328, ISA VAT REG #: 421 www.e-snahtka.	, 1459 NDO, SA, 1600 021 2249	Fax: CO REG #	0861 000 032 +27 11 918 6994 +27 11 894 1037 : 2004/007607/07 aMics.co.za	
	CALIBRATION	I CERTIFIC	CATE				CALIBRATIO		ATE			CALIBRATIO		CATE		
			CE	RTIFICATE NO:	ן ר			1	050	TIFICATE NO:				CF	RTIFICATE	NO:
				3501					UER	3503					3502	
CUSTOMER:	Eskom Medupi		JOB NO:	SC1713	$\downarrow \parallel$	CUSTOMER:	Eskom Medupi		JOB NO:	SC1713	CUSTOMER:	Eskom Medupi		JOB NO:	SC1713	
CONTACT NAME:	Lerato Sehume		TEL:	078 012 9038		CONTACT NAME:	Lerato Sehume			078 012 9038	CONTACT NAME:	Lerato Sehume		TEL:	078 012 903	3
MODEL:	Dr Fodisch MGA 23	SERIAL NO:	15711			MODEL:	Dr Fodisch MGA 23	SERIAL NO:	15711		MODEL:	Dr Fodisch MGA 23	SERIAL NO:	15712		

SERIAL NO: 15/11 AUXILIARY EQUIPMENT: Unit 2


Cł	IAN	PRIOR	FINAL	TEST GAS	TEST GAS VALUE	GAS CERTIFICATE NUMBER	EXPIRY DATE
	Zero	-1 ppm	0 ppm	Air	20.95 %	Air	N/A
co	Span	834 ppm	835 ppm	co	836.4 ppm	P20F000332	2021-02-03
NO	Zero	-2 ppm	0 ppm	Air	20.95 %	Air	N/A
NO	Span	884 ppm	877 ppm	NO	876.7 ppm	P20F000346	2021-01-21
	Zero	-75 ppm	0	Air	20.95 %	Air	N/A
802	Span	2102 ppm	2200 ppm	802	2200.0 ppm	P20F000345	2021-02-21
02	Zero	0.04 %	0.00 %	N2	99.99 %	92520	2021-02-27
02	Span	21.10 %	20.95 %	Air	20.95 %	Air	N/A

REPORT: Inspect all sample lines, filters and coolers, filter elements need to be change. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas.

Date of Calibration: 25 May 2020 Calibration Due Date: Aug 2020 Technician: J. Faber







Unit 4

REPORT: Inspect all sample lines, filters and coolers, filter element need to be change. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas.

Date of Calibration: 25 May 2020 Calibration Due Date: Aug 2020 Technician: J. Faber

AUXILIARY EQUIPMENT:



Document Number: TH-PFC-002-F1 Rev 2



			PO Box VAT RE	12 Angelier Street, Bardene, BOKSBURG, 3A, 1459 PO Box 328, ISANDO, 3A, 1500 VAT REG #: 421 021 2249 www.e-analytics.co.za			Tel: 0861 000 032 Intt. Tel: +27 11 918 6994 Fax: +27 11 994 1037 CO REG #: 2004/007607/07 Info@t=analytics.co.za		
CALIBRATION CERTIFICATE									
							CE	RTIFICA	TE NO:
								350	2
CUST	OMER:		Esko	om Medupi			JOB NO:	SC1713	-
CONT		ME:	Lera	to Sehume			TEL:	078 012	9038
MODE				odisch MGA	22	SERIAL NO:	15712		
	_			odisch MGA	23	SERIAL NU:	19/12		
AUXIL	JARY E	QUIPME	NT:			Unit 3			
ci	IAN	PRIC	R	FINAL	TEST GAS	TEST GAS VALUE	GAS CERTIFICATE		EXPIRY DATE
	Zero	2 pp	m	0 ppm	Air	20.95 %	Alr		N/A
co	Span	829 p	pm	835 ppm	co	836.4 ppm	P20FO0	0332	2021-02-03
NO	Zero	9 pp	3	0 ppm	Air	20.95 %	Alt		N/A
	Span	866 p	pm	877 ppm	NO	876.7 ppm	P20FO0		2021-01-21
802	Zero	4 pp		0	Air	20.95 %	Alr		N/A
	Span	2021 p		2200 ppm	802	2200.0 ppm	P20FO0		2021-02-21 2021-02-27
02	Zero	-0.01		0.00 %	N2	99.99 %	925		2021-02-27 N/A
analyse respond	Span 20.35 % 20.95 % Air 20.95 % Air N/A REPORT: Inspect all sample lines, filters and coolers, filter element need to be change. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas. N/A								
25 May Calibra Aug 20 Techni	Date of Calibration: 25 May 2020 Calibration Due Date: Aug 2020 Technician: J. Faber								
	Bicler + Long SERVOMEX TELEDYNE ANALYTICAL INSTRUMENTS								
	ANEASUS	ARLE ASSAULTA	a				ANALYTI	CAL INS	INUMENTS

				PO Box VAT RE	OK88URG, 8A, 1459 Intl. Tel: +27 11				4 1037
			C	ALIBRA	TION	I CERTIFIC	CATE		
							CE	RTIFICA	TE NO:
								350	2
CUST	OMER:		Esko	om Medupi			JOB NO:	SC1713	-
CONT	ACT NA	ME:	Lera	to Sehume			TEL:	078 012	9038
MODE	EL:		Dr F	odisch MGA	23	SERIAL NO:	15712		
AUXIL	JARY E	QUIPME	NT:			Unit 3	-		
						1			
c	HAN	PRIO	R	FINAL	TEST GAS	TEST GAS VALUE	GAS CERTIFICATE		EXPIRY DATE
~~	Zero	2 ppr	m	0 ppm	Air	20.95 %	Air	r	N/A
co	Span	829 p;	pm	835 ppm	co	836.4 ppm	P20FO0	0332	2021-02-03
NO	Zero	9 pp		0 ppm	Air	20.95 %	Air		N/A
	Span	866 p		877 ppm	NO	876.7 ppm	P20FO0		2021-01-21
802	Zero	4 pp		0	Air	20.95 %	Air P20F000345		N/A
	Span	2021 p	-	2200 ppm	802	2200.0 ppm			2021-02-21 2021-02-27
02	Zero Span	-0.01 20.35		0.00 %	N2 Air	99.99 % 20.95 %	92520 Air		2021-02-27 N/A
REPORT: Inspect all sample lines, filters and coolers, filter element need to be change. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas.									
Date of Calibration: 25 May 2020 Calibration Due Date: Aug 2020 Technician: J. Faber									
Bieler + Lang SERVOMEX TELEDYNE ANALYTICAL INSTRUMENTS									



CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

A Teledyne Technologies Company

Eskom		Template Identifier	240-43921804	Rev	6
	Medupi Power Station Monthly Emissions Report	Document Identifier 240-88543153		Rev	1
		Effective Date	January 2018		
		Review Date	January 2021		



12 Angeller Street, Bardene, BOKSBURG, SA, 1459 PO Box 328, ISANDO, SA, 1600 VAT REG #: 421 021 2249 www.e-analytics.co.za

CALIBRATION CERTIFICATE

0861 000 032 Tel: Intl. Tel: +27 11 918 6994 +27 11 894 1037 Fax: CO REG #: 2004/007607/07 info@e-analytics co za



12 Angelier Street, Bardene, BOKSBURG, SA, 1459 PO Box 328, ISANDO, SA, 1600 VAT REG #: 421 021 2249 www.e-analytics.co.za

Tel: Intl. Tel: Fax: CO REG Info@e

CALIBRATION CERTIFICATE

		CERTIFICATE NO:		
				3504
CUSTOMER:	Eskom Medupi		JOB NO:	SC1713
CONTACT NAME:	Lerato Sehume		TEL:	078 012 9038
MODEL:	SERIAL NO:	13670		
AUXILIARY EQUIPM	Unit 5			

CHAN		PRIOR	FINAL	TEST GAS	TEST GAS VALUE	GAS CERTIFICATE NUMBER	EXPIRY DATE
~~	Zero	6 ppm	0 ppm	Air	20.95 %	Air	N/A
co	Span	848 ppm	835 ppm	co	836.4 ppm	P20F000332	2021-02-03
NO	Zero	4 ppm	0 ppm	Air	20.95 %	Air	N/A
	Span	885 ppm	877 ppm	NO	876.7 ppm	P20F000346	2021-01-21
	Zero	-40 ppm	0	Air	20.95 %	Air	N/A
802	Span	2079 ppm	2200 ppm	302	2200.0 ppm	P20F000345	2021-02-21
~	Zero	0.02 %	0.00 %	N2	99.99 %	92520	2021-02-27
02	Span	20.49 %	20.95 %	Air	20.95 %	Air	N/A

REPORT: Inspect all sample lines, filters and coolers, filter elements need to be change. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas.

Date of Calibration: 25 May 2020 Calibration Due Date: Aug 2020 Technician: J. Faber

- Ales Bigler+Lang SERVOMEX S Document Number: TH-PFC-002-F1 Rev 2



CUSTOMER: Eskom Medupi JOB NO CONTACT NAME: TEL: Lerato Sehume MODEL: Dr Fodisch MGA 23 SERIAL NO: 13669 AUXILIARY EQUIPMENT: Unit 6

	ci	IAN	PRIOR	FINAL	GAS	TEST GAS VALUE	GAS CEI NUI
		Zero	-0 ppm	0 ppm	Air	20.95 %	
	co	Span	840 ppm	835 ppm	co	836.4 ppm	P20F
		Zero	-6 ppm	0 ppm	Air	20.95 %	1
NO	Span	884 ppm	877 ppm	NO	876.7 ppm	P20F	
	802	Zero	-2 ppm	0	Air	20.95 %	1
		Span	2462 ppm	2462 ppm	802	2200.0 ppm	P20F
	02	Zero	0.32 %	0.00 %	N2	99.99 %	92
	02	Span	20.63 %	20.95 %	Air	20.95 %	1

REPORT: Inspect all sample lines, filters and coolers, filter elements need to be change. SO2 cell diagnostics is low and cell does not calibrate on cylinder value, but cell is still reacting, and O2 cell sensitivity start to go down. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas.

Date of Calibration: 25 May 2020 Calibration Due Date: Aug 2020 Technician: J. Faber





CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database. No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

0861 000 032 Tel: +27 11 918 6994 : +27 11 918 6994 REG #: 2004/007607/07								
E								
CE	RTIFICA	TE NO:						
	350	5						
NO:	SC1713							
L:	078 012 9038							
9								
NUMB	IFICATE	EXPIRY DATE						
Air		N/A						
20F00	0332	2021-02-03						
Air		N/A						
20F00	0346	2021-01-21						
Air		N/A						
20F00		2021-02-21 2021-02-27						
9252	-	2021-02-27 N/A						
Air		NA						
