


| | | | | | |
|---|--|---------------------|--------------|-----|---|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |

Phumudzo Thivhafuni

Date: 2021/06/31

Limpopo Dept. of Economic Development, Environment and Tourism

Enquiries: TR. Rammutla

Private Bag 9484
POLOKWANE
0700

Tel: 014 762 6375

ThivhafuniPO@ledet.gov.za

Ref: 12/4/12L-W2/A3 – Oct 2020 Rev1

Dear Phumudzo

MEDUPI POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF OCTOBER 2020

This document serves as the monthly report required in terms of Section 7.7.1 of Medupi Power Station Provisional Atmospheric Emission License (AEL), 12/4/12L-W2/A3.

This report is a reflection of Unit 2, 3, 4, 5 and 6 gaseous and particulate emissions performance against the AEL limit for the month of October 2020 only.

1. Raw Materials and Products

Table 1: Quantity of raw materials and products for Unit 2, 3, 4, 5 and 6 in October 2020

| Raw Materials and Products used | Raw Material Type | Unit | Maximum Permitted Consumption/ Rate (Quantity) | Unit 2, 3, 4, 5 and 6 consumption October 2020 |
|---------------------------------|--------------------------|------------|--|--|
| | Coal | Tons/month | 1 875 000 | 692 471 |
| | Fuel Oil | Tons/month | 40 000 | 2088 |
| Production Rates | Product/ By-Product Name | Unit | Maximum Production Capacity Permitted (Quantity) | Unit 2, 3, 4, 5 and 6 Production Rate in Month of October 2020 |
| | Energy | MW | 4 800 | 2399 |
| | Ash Emitted | Tons/month | not specified | 239,1 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.


| | | | | | | |
|---|--|----------------------------|---------------------|------------|----------|--|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 | |
| | | Document Identifier | 240-88543153 | Rev | 2 | |
| | | Effective Date | January 2021 | | | |
| | | Review Date | January 2024 | | | |


Table 2: Daily consumption and production rates

| Date | Reportable hours of Operation | | | | | Coal usage | Production rate (MW) | | | | |
|----------------|-------------------------------|--------|--------|--------|--------|------------|----------------------|-----|-----|-----|-----|
| | Unit 2 | Unit 3 | Unit 4 | Unit 5 | Unit 6 | | U2 | U3 | U4 | U5 | U6 |
| 01-October- 20 | 12,3 | 24,0 | 0,0 | 24,0 | 24,0 | 25508 | 481 | 600 | 148 | 631 | 577 |
| 02-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 26179 | 532 | 573 | 0 | 643 | 619 |
| 03-October- 20 | 24,0 | 19,0 | 0,0 | 24,0 | 24,0 | 24325 | 510 | 566 | 0 | 612 | 623 |
| 04-October- 20 | 24,0 | 0,0 | 0,0 | 24,0 | 24,0 | 16048 | 480 | 498 | 0 | 482 | 562 |
| 05-October- 20 | 24,0 | 10,5 | 0,0 | 24,0 | 24,0 | 24384 | 450 | 657 | 0 | 561 | 570 |
| 06-October- 20 | 24,0 | 10,4 | 0,0 | 24,0 | 24,0 | 19405 | 437 | 482 | 0 | 533 | 460 |
| 07-October- 20 | 24,0 | 5,8 | 0,0 | 24,0 | 24,0 | 22872 | 383 | 581 | 0 | 546 | 599 |
| 08-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 25159 | 426 | 613 | 0 | 559 | 622 |
| 09-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 24604 | 450 | 569 | 0 | 569 | 580 |
| 10-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 24178 | 450 | 599 | 0 | 576 | 532 |
| 11-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 24715 | 450 | 615 | 0 | 641 | 527 |
| 12-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 25562 | 450 | 671 | 0 | 646 | 575 |
| 13-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 24195 | 450 | 559 | 0 | 588 | 552 |
| 14-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 22422 | 439 | 470 | 0 | 552 | 532 |
| 15-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 22007 | 436 | 522 | 0 | 571 | 473 |
| 16-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 22435 | 450 | 488 | 0 | 600 | 508 |
| 17-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 22959 | 450 | 497 | 0 | 615 | 568 |
| 18-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 23644 | 450 | 587 | 0 | 601 | 549 |
| 19-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 24410 | 450 | 600 | 0 | 628 | 547 |
| 20-October- 20 | 24,0 | 24,0 | 0,0 | 13,9 | 3,3 | 17075 | 450 | 559 | 173 | 584 | 456 |
| 21-October- 20 | 24,0 | 24,0 | 1,1 | 0,7 | 0,0 | 19068 | 403 | 491 | 282 | 470 | 0 |
| 22-October- 20 | 24,0 | 24,0 | 10,2 | 24,0 | 0,0 | 22082 | 448 | 606 | 320 | 632 | 0 |
| 23-October- 20 | 24,0 | 24,0 | 8,6 | 24,0 | 0,0 | 23362 | 450 | 643 | 334 | 645 | 0 |
| 24-October- 20 | 24,0 | 24,0 | 5,6 | 24,0 | 0,0 | 17561 | 450 | 439 | 330 | 577 | 0 |
| 25-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 0,0 | 17496 | 450 | 450 | 0 | 612 | 214 |
| 26-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 4,7 | 22494 | 440 | 465 | 0 | 586 | 522 |
| 27-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 24,0 | 22793 | 450 | 487 | 0 | 515 | 550 |
| 28-October- 20 | 24,0 | 24,0 | 0,0 | 24,0 | 8,9 | 22647 | 457 | 667 | 0 | 580 | 471 |
| 29-October- 20 | 22,6 | 24,0 | 0,0 | 24,0 | 6,3 | 25425 | 469 | 665 | 0 | 618 | 565 |
| 30-October- 20 | 0,0 | 24,0 | 0,0 | 24,0 | 24,0 | 18510 | 0 | 553 | 0 | 600 | 555 |
| 31-October- 20 | 0,0 | 24,0 | 0,0 | 24,0 | 24,0 | 18952 | 0 | 570 | 0 | 653 | 552 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

| | | | | | | |
|---|--|---------------------|--------------|-----|---|--|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 | |
| | | Document Identifier | 240-88543153 | Rev | 2 | |
| | | Effective Date | January 2021 | | | |
| | | Review Date | January 2024 | | | |

2. Abatement Technology

Table 3: Abatement Equipment Control Technology efficiency for month of October 2020

| Associated Unit/Stack | Technology Type | Efficiency |
|-----------------------|---------------------------|------------|
| Unit 1 | Fabric Filter Plant (FFP) | - |
| Unit 2 | Fabric Filter Plant (FFP) | 99,882% |
| Unit 3 | Fabric Filter Plant (FFP) | 99,919% |
| Unit 4 | Fabric Filter Plant (FFP) | 99,964% |
| Unit 5 | Fabric Filter Plant (FFP) | 99,896% |
| Unit 6 | Fabric Filter Plant (FFP) | 99,839% |

3. Energy Source Characteristics

Table 4: Energy Source Material Characteristics for the month of October 2020

| Characteristic | Stipulated Range (% by weight on a dry basis) | Monthly Average Content (% by weight on a dry basis) |
|-----------------|---|--|
| Coal | | |
| Sulphur Content | 1.3 - 2.2 | 1.360 |
| Ash Content | 35 - 39 | 34.270 |

Table 5: Energy Source Material Characteristics for the month of October 2020

| Characteristic | Stipulated Range (%) | Monthly Average Content (%) |
|-----------------|----------------------|-----------------------------|
| Oil | | |
| Sulphur Content | 0.5 - 3.5 | 2.1 |
| Ash Content | 0.02 - 0.1 | 0.020 |

4. Emissions Reporting

Medupi Power Station uses Continuous Emission Monitoring System which uses the extractive method for analysis.

The emission limits are as follows:

SO₂ Monthly = 3500 mg/Nm³

Dust Daily = 50 mg/Nm³

NO₂ Daily = 750 mg/Nm³

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.



Medupi Power Station Monthly Emissions Report

| | | | |
|---------------------|--------------|-----|---|
| Template Identifier | 240-43921804 | Rev | 6 |
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | January 2021 | | |
| Review Date | January 2024 | | |

Figure 2: Medupi Unit 2 PM Emissions - October 2020




Figure 3: Medupi Unit 3 PM Emissions - October 2020




Figure 4: Medupi Unit 4 PM Emissions - October 2020





Figure 5: Medupi Unit 5 PM Emissions - October 2020



CONTROLLED DISCLOSURE





When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.



Medupi Power Station Monthly Emissions Report

| | | | |
|---------------------|--------------|-----|---|
| Template Identifier | 240-43921804 | Rev | 6 |
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | January 2021 | | |
| Review Date | January 2024 | | |



CONTROLLED DISCLOSURE





When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.



Medupi Power Station Monthly Emissions Report

| | | | |
|---------------------|--------------|-----|---|
| Template Identifier | 240-43921804 | Rev | 6 |
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | January 2021 | | |
| Review Date | January 2024 | | |



CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.



Medupi Power Station Monthly Emissions Report

| | | | |
|---------------------|--------------|-----|---|
| Template Identifier | 240-43921804 | Rev | 6 |
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | January 2021 | | |
| Review Date | January 2024 | | |

Figure 16: Medupi Unit 4 NOx Emissions - October 2020




Figure 17: Medupi Unit 5 NOx Emissions - October 2020





Figure 18: Medupi Unit 6 NOx Emissions - October 2020



CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.


| | | | | | |
|---|--|----------------------------|---------------------|------------|----------|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |

Table 7: Monthly tonnages for the month of October 2020

| Unit | PM (tons) | SO ₂ (tons) | NO ₂ (tons) | CO (tons) |
|------------|-----------|------------------------|------------------------|-----------|
| 1 | - | - | - | - |
| 2 | 56,3 | 4 226 | 668 | 20 |
| 3 | 47,3 | 4 230 | 421 | 185 |
| 4 | 1,4 | 213 | 51 | 3 |
| 5 | 59,6 | 5 669 | 713 | 37 |
| 6 | 74,5 | 4 096 | 661 | 34 |
| SUM | 239,1 | 18 434 | 2 515 | 278 |

5. Comments on the performance and availability of each unit

Medupi Power station complied with the average emissions limit for SO_x and NO_x pollutants in all units during the reporting period. A total of 14 PM exceedances were recorded in 5 units for the reporting period, all this exceedances were picked after back-fitting of data and is reported as a contravention in this report. Unit 4 was off for most of the reporting period, Unit 3 and 5 were available on all the days during the reporting period, Unit 2 and 6 were off for 2 and 4 days respectively.

6. Continuous Emission Monitoring Systems (CEMS)

Unit 2, 3, 4, 5 and 6 Continuous Emission Monitoring Systems were in operation at all times when the unit was on load.

Table 6: Periods during which CEMS was inoperative


| Date | Time | CEMS status | Comments |
|------|------|-------------|----------|
| N/A | N/A | N/A | N/A |

Table 7: CEMS Monitor Reliability

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document October be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

| | | | | | |
|---|--|---------------------|--------------|-----|---|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |

| Associated Unit/Stack | PM | SO ₂ | NO | O ₂ |
|-----------------------|------------|-----------------|------------|----------------|
| Unit 1 | <i>n/a</i> | <i>n/a</i> | <i>n/a</i> | <i>n/a</i> |
| Unit 2 | 99,6 | 99,4 | 99,4 | 99,0 |
| Unit 3 | 99,9 | 99,4 | 96,9 | 97,4 |
| Unit 4 | 100,0 | 52,1 | 52,8 | 31,8 |
| Unit 5 | 100,0 | 100,0 | 100,0 | 100,0 |
| Unit 6 | 99,6 | 99,6 | 99,6 | 80,8 |

7. CEMS Calibration certificates and equipment used for calibration

See attached Appendix A

8. Ambient Air Quality Monitoring Report

The Ambient Air Quality Monitoring and Dust fall-out report are emailed to the Licensing authority on a monthly basis.

9. Visual inspection of the exterior walls of the fuel oil tanks, fuel oil inventory data and TVOC Estimation


Visual inspection was conducted and there were no leaks observed on the exterior walls of the fuel oil tanks.


Table 8: Total Volatile Organic Compound (TVOC) for October 2020

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document October be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.


| | | | | | |
|---|--|----------------------------|---------------------|------------|----------|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |

| | | |
|--|--|-------------------------|
|  | | |
| CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS* | | |
| Date: | 30 October 2020 | |
| Station: | Medupi Power Station | |
| Province: | Limpopo Province | |
| Tank no. | 1-2 | |
| Description: | Outdoor fuel oil storage tank | |
| Tank Type: | Vertical fixed roof (vented to atmosphere) | |
| Material stored: | Fuel Oil 150 | |
| <p align="center"> MONTHLY INPUT DATA FOR THE STATION Please only insert relevant monthly data inputs into the <i>blue cells</i> below Choose from a dropdown menu in the <i>green cells</i> The total VOC emissions for the month are in the <i>red cells</i> IMPORTANT: Do not change <i>any</i> other cells without consulting the AQ CoE </p> | | |
| MONTH: | October | |
| GENERAL INFORMATION: | | |
| | Data | Unit |
| Total number of fuel oil tanks: | 2 | NA |
| Height of tank:* | 14.2 | m |
| Diameter of tank: | 12 | m |
| Net fuel oil throughput for the month: | 2088 | tons/month |
| Molecular weight of the fuel oil: | 166.00 | Lb/lb-mole |
| METEROLOGICAL DATA FOR THE MONTH | | |
| | Data | Unit |
| Daily average ambient temperature | 26.19 | °C |
| Daily maximum ambient temperature | 33.65 | °C |
| Daily minimum ambient temperature | 19.11 | °C |
| Daily ambient temperature range | 14.54 | °C |
| Daily total insolation factor | 5.81 | kWh/m ² /day |
| Tank paint colour | <i>Aluminum/Specular</i> | NA |
| Tank paint solar absorbtance | 0.39 | NA |
| FINAL OUTPUT: | | |
| | Result | Unit |
| Breathing losses: | 0.74 kg/month | |
| Working losses: | 0.06 kg/month | |
| TOTAL LOSSES (Total TVOC Emissions for the month): | 0.80 kg/month | |
| <small> *Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Trittech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com. </small> | | |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document October be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

| | | | | | |
|---|--|----------------------------|---------------------|------------|----------|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |

10. Air quality improvements initiatives and public education and awareness campaigns

No awareness campaign.

11. Complaints Register


Table 9: Complaints for the month of October 2020

| Source Code/ Name | Air pollution complaints received | Calculation of Impacts/ emissions associated with the incident | Date of complaint and date of response by the license holder | Results of investigation | Action taken to resolve the complaint |
|-------------------|-----------------------------------|--|--|--------------------------|---------------------------------------|
| N/A | No complaints received | N/A | N/A | N/A | N/A |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document October be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

| | | | | | |
|---|--|----------------------------|---------------------|------------|----------|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |

Compiled by:

Lufuno Tshidzumba
Senior Environmental Advisor



Verified by:

Malose Langa
System Engineer Boiler



Supported by:

Sithokozile Hlongwa pp
Boiler Engineering Manager




Supported by:

Rosetta Rammutla
Environmental Manager



Supported by:

Jabulani Mkhatsywa
Engineering Group Manager



I Dan Mashigo, declares that the information provided in this report is accurate and correct.

Yours sincerely




Dan Mashigo
GENERAL MANAGER: MEDUPI POWER STATION (Acting)


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document October be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

| | | | | | |
|---|--|----------------------------|---------------------|------------|----------|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |

APPENDIX 1: CEMS Calibration certificates



12 Angeller Street, Bardene,
BOKSBURG, SA, 1459
PO Box 328, ISANDO, SA, 1600
VAT REG #: 421 021 2249
www.e-analytics.co.za

Tel: 0861 000 032
Intl. Tel: +27 11 918 6994
Fax: +27 11 894 1037
CO REG #: 2004/007607/07
info@e-analytics.co.za


CALIBRATION CERTIFICATE


| | | | | | | | |
|-----------------------------|-------------------|-------------------|-------|----------------|--------------|------------------------|--|
| | | | | | | CERTIFICATE NO: | |
| | | | | | | 3641 | |
| CUSTOMER: | Eskom Medupi | | | JOB NO: | SC1757 | | |
| CONTACT NAME: | Lerato Sehume | | | TEL: | 078 012 9038 | | |
| MODEL: | Dr Fodisch MGA 23 | SERIAL NO: | 15711 | | | | |
| AUXILIARY EQUIPMENT: | Unit 2 | | | | | | |

| CHAN | PRIOR | FINAL | TEST GAS | TEST GAS VALUE | GAS CERTIFICATE NUMBER | EXPIRY DATE | |
|------|-------|----------|----------|----------------|------------------------|-------------|------------|
| CO | Zero | -1 ppm | 0 ppm | Air | 20.95 % | N/A | |
| | Span | 837 ppm | 835 ppm | CO | 836.4 ppm | P20FO00332 | 2021-02-03 |
| NO | Zero | -1 ppm | 0 ppm | Air | 20.95 % | N/A | |
| | Span | 878 ppm | 877 ppm | NO | 876.7 ppm | P20FO00346 | 2021-01-21 |
| SO2 | Zero | -15 ppm | 0 | Air | 20.95 % | N/A | |
| | Span | 2203 ppm | 2200 ppm | SO2 | 2200.0 ppm | P20FO00345 | 2021-02-21 |
| O2 | Zero | -0.08 % | 0.00 % | N2 | 99.99 % | 92520 | 2021-02-27 |
| | Span | 21.10 % | 20.95 % | Air | 20.95 % | Air | N/A |


REPORT: Inspect all sample lines, filters and coolers, filter elements need to be change. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas.

Date of Calibration:
18 Aug 2020
Calibration Due Date:
Nov 2020
Technician:
J. Faber






Document Number: TH-PFC-002-F1 Rev 2




CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document October be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

| | | | | | |
|---|--|----------------------------|---------------------|------------|----------|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |



Elemental Analytics
Analyser Specialists

12 Angeller Street, Bardene,
BOKSBURG, SA, 1459
PO Box 328, ISANDO, SA, 1500
VAT REG #: 421 021 2249
www.e-analytics.co.za

Tel: 0861 000 032
Intl. Tel: +27 11 918 6994
Fax: +27 11 894 1037
CO REG #: 2004/007607/07
info@e-analytics.co.za


CALIBRATION CERTIFICATE


| | | | | | |
|-----------------------------|-------------------|-------------------|----------------|--------------|--|
| CERTIFICATE NO: | | | | | |
| 3642 | | | | | |
| CUSTOMER: | Eskom Medupi | | JOB NO: | SC1757 | |
| CONTACT NAME: | Lerato Sehume | | TEL: | 078 012 9038 | |
| MODEL: | Dr Fodisch MGA 23 | SERIAL NO: | 15712 | | |
| AUXILIARY EQUIPMENT: | Unit 3 | | | | |

| CHAN | | PRIOR | FINAL | TEST GAS | TEST GAS VALUE | GAS CERTIFICATE NUMBER | EXPIRY DATE |
|------|------|----------|----------|----------|----------------|------------------------|-------------|
| CO | Zero | -2 ppm | 0 ppm | Air | 20.95 % | Air | N/A |
| | Span | 839 ppm | 835 ppm | CO | 836.4 ppm | P20F000332 | 2021-02-03 |
| NO | Zero | -3 ppm | 0 ppm | Air | 20.95 % | Air | N/A |
| | Span | 882 ppm | 877 ppm | NO | 876.7 ppm | P20F000346 | 2021-01-21 |
| SO2 | Zero | 0 ppm | 0 | Air | 20.95 % | Air | N/A |
| | Span | 2249 ppm | 2200 ppm | SO2 | 2200.0 ppm | P20F000345 | 2021-02-21 |
| O2 | Zero | -0.05 % | 0.00 % | N2 | 99.99 % | 92520 | 2021-02-27 |
| | Span | 20.97 % | 20.95 % | Air | 20.95 % | Air | N/A |


REPORT: Inspect all sample lines, filters and coolers, filter elements need to be change. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas.

Date of Calibration:
18 Aug 2020
Calibration Due Date:
Nov 2020
Technician:
J. Faber





Document Number: TH-PFC-002-F1 Rev 2





A Teledyne Technologies Company

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document October be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

| | | | | | |
|---|--|----------------------------|---------------------|------------|----------|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |



Elemental Analytics
Analytical Specialists

12 Angeller Street, Bardene,
BOKSBURG, SA, 1459
PO Box 328, ISANDO, SA, 1600
VAT REG #: 421 021 2249
www.e-analitics.co.za

Tel: 0861 000 032
Intl. Tel: +27 11 918 6994
Fax: +27 11 894 1037
CO REG #: 2004/007607/07
info@e-analitics.co.za


CALIBRATION CERTIFICATE


| | | | | | |
|-----------------------------|-------------------|-------------------|-------|----------------|--------------|
| CERTIFICATE NO: | | | | | |
| 3643 | | | | | |
| CUSTOMER: | Eskom Medupi | | | JOB NO: | SC1757 |
| CONTACT NAME: | Lerato Sehume | | | TEL: | 078 012 9038 |
| MODEL: | Dr Fodisch MGA 23 | SERIAL NO: | 13668 | | |
| AUXILIARY EQUIPMENT: | Unit 4 | | | | |

| CHAN | PRIOR | FINAL | TEST GAS | TEST GAS VALUE | GAS CERTIFICATE NUMBER | EXPIRY DATE | |
|------|-------|----------|----------|----------------|------------------------|-------------|------------|
| CO | Zero | 0 ppm | 0 ppm | Air | 20.95 % | N/A | |
| | Span | 833 ppm | 835 ppm | CO | 836.4 ppm | P20F000332 | 2021-02-03 |
| NO | Zero | -2 ppm | 0 ppm | Air | 20.95 % | N/A | |
| | Span | 878 ppm | 877 ppm | NO | 876.7 ppm | P20F000346 | 2021-01-21 |
| SO2 | Zero | -9 ppm | 0 | Air | 20.95 % | N/A | |
| | Span | 2257 ppm | 2200 ppm | SO2 | 2200.0 ppm | P20F000345 | 2021-02-21 |
| O2 | Zero | 0.12 % | 0.00 % | N2 | 99.99 % | 92520 | 2021-02-27 |
| | Span | 21.04 % | 20.95 % | Air | 20.95 % | N/A | N/A |


REPORT: Inspect all sample lines, filters and coolers, filter elements need to be change. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas.

Date of Calibration:
17 Aug 2020
Calibration Due Date:
Nov 2020
Technician:
J. Faber






Document Number: TH-PFC-002-F1 Rev 2




CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document October be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

| | | | | | |
|---|--|----------------------------|---------------------|------------|----------|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |



12 Angeller Street, Bardene,
BOKSBURG, SA, 1459
PO Box 328, ISANDO, SA, 1600
VAT REG #: 421 021 2249
www.e-analytics.co.za

Tel: 0861 000 032
Intl. Tel: +27 11 918 6994
Fax: +27 11 894 1037
CO REG #: 2004/007607/07
info@e-analytics.co.za

CALIBRATION CERTIFICATE


CERTIFICATE NO:
3644


| | | | |
|-----------------------------|-------------------|-------------------|--------------|
| CUSTOMER: | Eskom Medupi | JOB NO: | SC1757 |
| CONTACT NAME: | Lerato Sehume | TEL: | 078 012 9038 |
| MODEL: | Dr Fodisch MGA 23 | SERIAL NO: | 13670 |
| AUXILIARY EQUIPMENT: | Unit 5 | | |

| CHAN | PRIOR | FINAL | TEST GAS | TEST GAS VALUE | GAS CERTIFICATE NUMBER | EXPIRY DATE | |
|------|-------|----------|----------|----------------|------------------------|-------------|------------|
| CO | Zero | -25 ppm | 0 ppm | Air | 20.95 % | N/A | |
| | Span | 815 ppm | 835 ppm | CO | 836.4 ppm | P20FO00332 | 2021-02-03 |
| NO | Zero | -18 ppm | 0 ppm | Air | 20.95 % | N/A | |
| | Span | 857 ppm | 877 ppm | NO | 876.7 ppm | P20FO00346 | 2021-01-21 |
| SO2 | Zero | -34 ppm | 0 | Air | 20.95 % | N/A | |
| | Span | 2236 ppm | 2200 ppm | SO2 | 2200.0 ppm | P20FO00345 | 2021-02-21 |
| O2 | Zero | 0.05 % | 0.00 % | N2 | 99.99 % | 92520 | 2021-02-27 |
| | Span | 21.13 % | 20.95 % | Air | 20.95 % | Air | N/A |

REPORT: Inspect all sample lines, filters and coolers, filter elements need to be change. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas.


Date of Calibration:
17 Aug 2020
Calibration Due Date:
Nov 2020
Technician:
J. Faber





SERVOMEX
A HEADSTART ADVANTAGE

Document Number: TH-PFC-002-F1 Rev 2





TELEDYNE ANALYTICAL INSTRUMENTS
A Teledyne Technologies Company

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document October be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

| | | | | | |
|---|--|----------------------------|---------------------|------------|----------|
|  | Medupi Power Station Monthly Emissions Report | Template Identifier | 240-43921804 | Rev | 6 |
| | | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | January 2021 | | |
| | | Review Date | January 2024 | | |



Elemental Analytics
Analytical Specialists

12 Angeller Street, Bardene,
BOKSBURG, SA, 1459
PO Box 328, ISANDO, SA, 1600
VAT REG #: 421 021 2249
www.e-analytics.co.za

Tel: 0861 000 032
Intl. Tel: +27 11 918 6994
Fax: +27 11 894 1037
CO REG #: 2004/007607/07
info@e-analytics.co.za


CALIBRATION CERTIFICATE


| | | | | | |
|-----------------------------|-------------------|-------------------|-------|----------------|--------------|
| CERTIFICATE NO: | | | | | |
| 3645 | | | | | |
| CUSTOMER: | Eskom Medupi | | | JOB NO: | SC1757 |
| CONTACT NAME: | Lerato Sehume | | | TEL: | 078 012 9038 |
| MODEL: | Dr Fodisch MGA 23 | SERIAL NO: | 13669 | | |
| AUXILIARY EQUIPMENT: | Unit 6 | | | | |

| CHAN | PRIOR | FINAL | TEST GAS | TEST GAS VALUE | GAS CERTIFICATE NUMBER | EXPIRY DATE | |
|------|-------|----------|----------|----------------|------------------------|-------------|------------|
| CO | Zero | -5 ppm | 0 ppm | Air | 20.95 % | Air | N/A |
| | Span | 831 ppm | 835 ppm | CO | 836.4 ppm | P20FO00332 | 2021-02-03 |
| NO | Zero | -15 ppm | 0 ppm | Air | 20.95 % | Air | N/A |
| | Span | 868 ppm | 877 ppm | NO | 876.7 ppm | P20FO00346 | 2021-01-21 |
| SO2 | Zero | -83 ppm | 0 | Air | 20.95 % | Air | N/A |
| | Span | 2389 ppm | 2389 ppm | SO2 | 2200.0 ppm | P20FO00345 | 2021-02-21 |
| O2 | Zero | -0.36 % | 0.00 % | N2 | 99.99 % | 92520 | 2021-02-27 |
| | Span | 21.34 % | 20.95 % | Air | 20.95 % | Air | N/A |


REPORT: Inspect all sample lines, filters and coolers, filter elements need to be change. SO2 cell diagnostics is low and cell does not calibrate on cylinder value, but cell is still reacting, and O2 cell sensitivity start to go down. Calibrate analyser with zero and span gas, calibration was done according to cylinder values, analyser was responding to all test gas.

Date of Calibration:
17 Aug 2020
Calibration Due Date:
Nov 2020
Technician:
J. Faber





SERVOMEX
A MEASUREMENT ADVANTAGE



TELEDYNE ANALYTICAL INSTRUMENTS
A Teledyne Technologies Company

Document Number: TH-PFC-002-F1 Rev 2

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

No part of this document October be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.