		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	1
		Effective Date	February 2018		
		Review Date	February 2024		

Stanley Koenaite

Waterberg District Municipality Private Bag X1018 Modimolle 0510 Date: 2021/06/30 Enquiries: TR. Rammutla Tel: 014 762 6375

skoenaite@waterberg.gov.za

Ref: H16/1/13-AEL/M1/R1 – May 2021

Dear Mr Koenaite

# MEDUPI POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF MAY 2021

This document serves as the monthly emissions report required in terms of Section 7.7.1 of Medupi Power Station Provisional Atmospheric Emission License (AEL), H16/1/13-AEL/M1/R1.

This report is a reflection of Unit 2, 3, 4, 5 and 6 gaseous and particulate emissions performance against the AEL limit for the month of May 2021 only.

#### 1. Raw Materials and Products

 Table 1: Quantity of raw materials and products for Unit 2, 3, 4, 5 and 6 in May 2021

Raw Materials and	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Unit 2, 3, 4, 5 and 6 consumption May 2021
Products	Coal	Tons/month	1 875 000	793 723
used	Fuel Oil	Tons/month	20 000	1452,000
Production Rates	Product/ By- Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Unit 2, 3, 4, 5 and 6 Production Rate in Month of May 2021
	Energy	MW	4 800	2426
	Ash Emitted	Tons/month	not specified	233,3

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	1
		Effective Date	e February 2018		
		Review Date	February 2024		

#### Table 2: Daily consumption and production rates

	Report	able hou	irs of Op	peration	ı		Production rate (MW)				
	2	m	4	ß	9	Coal		Flouu			
Date	Unit	Unit	Unit	Unit	Unit	usage	U2	U3	U4	U5	U6
01-May- 21	24,0	24,0	0,0	0,0	24,0	20064	621,1	655,9	off	off	568,8
02-May- 21	24,0	24,0	0,0	0,0	24,0	18487	574,2	535,2	off	off	565,6
03-May- 21	24,0	24,0	0,0	0,0	24,0	23808	691,2	450,1	440,3	off	600,0
04-May- 21	24,0	24,0	22,2	0,0	24,0	25602	713,3	417,6	657,1	off	591,7
05-May- 21	24,0	24,0	24,0	0,0	24,0	24760	630,7	406,5	699,9	off	556,9
06-May- 21	24,0	24,0	24,0	0,0	24,0	26347	622,8	541,3	650,5	off	544,7
07-May- 21	24,0	24,0	24,0	0,0	24,0	27532	705,5	636,9	633,0	off	558,5
08-May- 21	24,0	24,0	24,0	0,0	24,0	26877	713,7	604,3	650,7	off	530,5
09-May- 21	24,0	24,0	24,0	0,0	24,0	28023	756,3	561,8	653,6	off	570,4
10-May- 21	24,0	24,0	24,0	0,0	18,9	24639	651,1	511,8	655,2	off	552,6
11-May- 21	24,0	24,0	24,0	0,0	0,0	25277	681,1	693,5	687,3	off	457,3
12-May- 21	24,0	24,0	24,0	0,0	14,5	28620	690,1	662,6	671,8	off	587,8
13-May- 21	24,0	24,0	24,0	0,0	9,3	23189	542,0	496,3	685,1	off	445,6
14-May- 21	24,0	7,8	24,0	0,0	7,6	21209	487,3	471,6	697,7	off	562,4
15-May- 21	24,0	0,0	24,0	0,0	24,0	22593	473,1	425,3	673,5	off	545,8
16-May- 21	24,0	17,8	24,0	0,0	24,0	24686	450,0	553,5	686,6	off	570,0
17-May- 21	24,0	24,0	24,0	0,0	24,0	26586	506,9	699,8	698,4	off	570,0
18-May- 21	24,0	24,0	24,0	0,0	24,0	27511	579,4	703,3	680,3	off	570,0
19-May- 21	24,0	24,0	24,0	0,0	24,0	24398	476,2	542,8	off	off	624,9
21-May- 21	24,0	24,0	24,0	0,0	24,0	28305	594,6	698,6	685,2	off	684,7
21-May- 21	24,0	24,0	24,0	0,0	24,0	28764	611,6	687,4	676,2	off	701,0
22-May- 21	24,0	24,0	24,0	0,0	24,0	28282	566,4	698,8	696,4	off	726,4
23-May- 21	24,0	24,0	24,0	0,0	24,0	27593	586,8	714,2	665,5	off	633,1
24-May- 21	24,0	24,0	24,0	0,0	24,0	28090	685,7	684,2	593,6	off	580,2
25-May- 21	24,0	24,0	24,0	0,0	24,0	25563	618,5	751,2	671,9	off	522,4
26-May- 21	24,0	24,0	24,0	0,0	24,0	26762	743,5	465,1	700,0	off	568,4
27-May- 21	24,0	24,0	24,0	0,0	24,0	28026	788,6	518,0	719,0	off	529,9
28-May- 21	24,0	24,0	24,0	0,0	24,0	25787	549,8	549,5	679,3	off	529,9
29-May- 21	24,0	24,0	24,0	0,0	24,0	24620	554,0	569,8	531,0	off	530,0
30-May- 21	24,0	24,0	24,0	0,0	24,0	26827	621,5	545,4	740,8	off	530,1
31-May- 21	24,0	24,0	24,0	0,0	24,0	24897	550,8	481,4	719,4	off	530,0

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	1
		Effective Date	February 2018		
		Review Date	February 2024		

# 2. Abatement Technology

 Table 3: Abatement Equipment Control Technology efficiency for month of May 2021

Associated Unit/Stack	Technology Type	Efficiency
Unit 1	Fabric Filter Plant (FFP)	-
Unit 2	Fabric Filter Plant (FFP)	99,962%
Unit 3	Fabric Filter Plant (FFP)	99,902%
Unit 4	Fabric Filter Plant (FFP)	99,946%
Unit 5	Fabric Filter Plant (FFP)	-
Unit 6	Fabric Filter Plant (FFP)	99,794%

# 3. Energy Source Characteristics

 Table 4: Energy Source Material Characteristics for the month of May 2021

Characteristic	Stipulated Range (% by weight on a dry basis)	Monthly Average Content (% by weight on a dry basis)		
	Coal			
Sulphur Content	1.3 - 2.2	1.250		
Ash Content	35 - 39	33,680		

 Table 5: Energy Source Material Characteristics for the month of May 2021

Characteristic	Stipulated Range (%)	Monthly Average Content (%)		
	Oil			
Sulphur Content	0.5 - 3.5	2.0		
Ash Content	0.02 - 0.1	0.010		

# 4. Emissions Reporting

Medupi Power Station uses Continuous Emission Monitoring System which uses the extractive method for analysis.

The emission limits are as follows:

 $SO_2$  Monthly = 3500 mg/Nm<sup>3</sup> Dust Daily

Dust Daily= 50 mg/Nm<sup>3</sup>

NO<sub>2</sub> Daily= 750 mg/Nm<sup>3</sup>

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	1
		Effective Date	February 2018		
		Review Date	February 2024		











Note: exceedances of PM limit are due incident of bag damages in the PJFF plant, cell are isolated and inspected online to identify those influencing emissions. Online bag replacement is done on those cells with high dust emissions.

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database. No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

() Eskom		Template Identifier	240-43921804	Rev	6	
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	1	
		Effective Date	February 2018	February 2018		
		Review Date	February 2024			



Note: SO<sub>2</sub> emissions intermittent exceedances of daily limit of 3500mg/Nm<sup>3</sup> (station internal limit) is evident in the SO<sub>2</sub> figures, there was no incident that led to exceedance of the monthly limit of 3500mg/Nm<sup>3</sup> (AEL limit) for unit 2, 4 and 6. Unit 3 exceeded the limit by 47mg/Nm<sup>3</sup>.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database. No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	1
		Effective Date	February 2018		
		Review Date	February 2024		



# 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 Section 30 Contravention

# Figure 18: Medupi Unit 6 NOx Emissions - May 2021



Medupi Power Station graphical representation of the daily average emissions

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database. No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.



		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	1
		Effective Date	February 2018		
		Review Date	February 2024		

#### Table 7: Monthly tonnages for the month of May 2021

Unit	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>2</sub> (tons)	CO (tons)
1	-	-	-	-
2	24,2	6 010	658	50
3	57,9	5 376	399	49
4	33,2	8 707	1 206	86
5	0,0	0	0	0
6	118,0	6 477	839	95
SUM	233,3	26 570,3	3 101,7	281,4

# 5. Shutdown/start-up information

Table 8: PM Start-up information for the month of May 2021

Unit No.	3	
Breaker Open (BO)	7:50 am	2021/05/14
Draught Group (DG) Shut Down (SD)	7:50 am	2021/05/14
BO to DG SD (duration)	00:00:00	DD:HH:MM
Fires in time	12:40 am	2021/05/15
Synch. to Grid (or BC)	6:10 am	2021/05/15
Fires in to BC (duration)	00:05:30	DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD:HH:MM

# 6. Continuous Emission Monitoring Systems (CEMS)

Unit 2, 3, 4, 5 and 6 Continuous Emission Monitoring Systems were in operation at all times when the unit was on load.

#### Table 6: Periods during which CEMS was inoperative

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom		Template Identifier	240-43921804	Rev	6
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	1
		Effective Date	February 2018		
		Review Date	February 2024		

Date	Time	CEMS status	Comments
May 2021	N/A	N/A	N/A

#### Table 7: CEMS Monitor Reliability

Associated Unit/Stack	РМ	SO₂	NO	Oz
Unit 1	-	-	-	-
Unit 2	100,0	100,0	100,0	100,0
Unit 3	100,0	100,0	100,0	90,6
Unit 4	100,0	100,0	100,0	99,8
Unit 5	-	-	-	-
Unit 6	99,7	84,5	84,5	84,5

# 7. CEMS Calibration certificates and equipment used for calibration

CEMS calibration certificates shall be made available for all units upon request.

# 8. Ambient Air Quality Monitoring Report

The Ambient Air Quality Monitoring and Dust fall-out report are emailed to the Licensing authority on a monthly basis.

### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

() Eskom		Template 240-43921804 Identifier		Rev	6
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	1
		Effective Date	February 2018		
		Review Date	February 2024		

# 9. Visual inspection of the exterior walls of the fuel oil tanks and TVOC Estimation

Visual inspection was conducted and there were no leaks observed on the exterior walls of the fuel oil tanks.

#### Table 8: Total Volatile Organic Compound (TVOC) for May 2021

FINAL OUTPUT:	Result	Unit
Breathing losses:	0,70	) kg/month
Working losses:	0,04	1 kg/month
TOTAL LOSSES (Total TVOC Emissions for the month):	0,74	4 kg/month
*Calculations performed on this spreadsheet are taken from the USEF	PA AP-42- Section 7.1 Org	anic Liquid Storage
Tanks - January 1996. This spreadsheet is derived from materials prov	vided by Jimmy Peress, PE	E, Tritech Consulting
Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mai		-454-6330, e-mail -
PeressJ@nyc.rr.com.		

# 10. Air quality improvements initiatives and public education and awareness campaigns

No awareness campaign.

# **11. Complaints Register**

Table 9: Complaints for the month of May 2021

Source Code/ Name	Air pollution complaints received	Calculation of Impacts/ emissions associated with the incident	Date of complaint and date of response by the license holder	Results of investigation	Action taken to resolve the complaint
N/A	No complaints received	N/A	N/A	N/A	N/A

# CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	1
		Effective Date	February 2018		
		Review Date	February 2024		

Compiled by:	Lufuno Tshidzumba <u>Tshidzumbal</u> Senior Environmental Advisor
Verified by:	Malose Langa System Engineer Boiler
Verified by:	Petri De Kock System Engineer C&I
Supported by:	Sithokozile Hlongwa Boiler Engineering Manager
Supported by:	Rosetta Rammutla_ <u>7R_Rammutla</u> Environmental Manager
Supported by:	Jabulani Mkhatshwa Engineering Group Manager

I Dan Mashigo, declares that the information provided in this report is accurate and correct.

Yours sincerely

2021.07.02

Dan Mashigo **GENERAL MANAGER: MEDUPI POWER STATION (Acting)** 

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.