

Mr. Vusi Mahlangu
Air Quality Officer
DEDET
Private bag X11215
NELSPRUIT
1200

Date:
14 August 2021

Enquiries:
Mariam Joseph
Tel +27 13 297 9828
Fax + 27 86 661 7663

Dear Mr. Mahlangu

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JULY 2021

This serves as the monthly report required in terms of Section 6 in Arnot Power Station's Atmospheric Emission License. The emissions are for the month of July 2021, Verified emissions of particulates; SO₂ and NO_x (as NO₂) are also included.

Raw Materials and Products

Table1: Quantity of Raw Materials and Products used/produced for the Month of July 2021

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption/ Rate in Month of July
	Coal	Tons/month	1 050 330	467352.3
	Fuel Oil	Tons/month	10 000	2192.01
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of July 2021
	Energy	GWh	1 785 600	899.50
	Ash	Tons/month	421 000	110762.49

Abatement Technology

Table 2: Abatement Equipment Control Technology for month of July 2021

Generation Division
Arnot Power Station
N4 Nelspruit Road
Private Bag X2 Rietkuil 1097 SA
Tel +27 13 297 9111 Fax +27 13 297 9142 www.eskom.co.za

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JULY 2021

Associated Unit/Stack	Technology Type	Actual Utilisation (%) for the month of July 2021
North Stack	Fabric Filter Bags	99.8%
South Stack	Fabric Filter Bags	99.9%

Table 2.1 Abatement Equipment Efficiency Utilisation (%) for the month of July 2021

Associated Unit/Stack	Technology Type	Efficiency July-2021
North	<i>Fabric Filter Plant (FFP)</i>	100%
South	<i>Fabric Filter Plant (FFP)</i>	100%

Energy Source Characteristics

Table 3: Energy Source Material Characteristics for the month of July- 2021

Characteristic	Stipulated Range (Unit)	Monthly Average Content
Sulphur Content	0.5 to < 1 (%)	0.665
Ash Content	17 to < 40 (%)	23.70

Table 4 Operating days in compliance to PM AEL Limit –July 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
North	30	0	0	0	0	43.1
South	30	0	0	0	0	21.9
SUM	60	0	0	0	0	

Table 5 Operating days in compliance to NOx AEL Limit – July 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm ³)
North	30	0	0	0	0	762.6
South	30	0	0	0	0	538.4
SUM	60	0	0	0	0	

Table 6: Operating days in compliance to SOx AEL Limit –July 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm ³)
North	30	0	0	0	0	1475.6
South	30	0	0	0	0	1125.9
SUM	60	0	0	0	0	

Emissions Reporting

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JULY 2021




Figure 1: PM emissions (daily averages) for the month of July 2021 against emission limit for the North Stack

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JULY 2021




Figure 2: PM emissions (daily averages) for the month of July 2021 against emission limit for the South Stack




Figure 3: SO₂ emissions (daily averages) for the month of July 2021 against emission limit for the North Stack

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JULY 2021




Figure 4: SO₂ emissions (daily averages) for the month of July -2021 against emission limit for the South Stack




Figure 5: NO₂ emissions (daily averages) for the month of July -2021 against emission limit for the North Stack

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JULY 2021




Figure 6: NO₂ emissions (daily averages) for the month of July -2021 against emission limit for the South Stack

Table 4: Monthly tonnages for the month of July 2021

Unit	PM (tons)	SO ₂ (tons)	NO ₂ (tons)
Total Tons (North & South Stack)	109.5	4471.8	2236.8

Table 5: Monitor Availability

Unit	PM (%)	SO ₂ (%)	NO ₂ (%)
North Stack	100	94.8	97.6
South Stack	100	96.1	99.2

Table 6: Each unit and respective days operating under normal operation, days in grace period, and section 30 days respectively

Unit	Days operating under normal operation	Days operating in grace period	Days operating under S 30
1	30	0	0
2	30	0	0
3	30	0	0
4	30	0	0

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JULY 2021

5	30	0	0
6	30	0	0

Light up information

Continuous reporting is being done even during start-ups, emissions were not affected.

Complaints Register

Table 7. Complaints for the month of July 2021

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

General

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission reports sent to your office.

**ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JULY
2021**

Hoping the above will meet your satisfaction.

Compiled by



Lawrence Machebe

ENVIRONMENTAL OFFICER: ARNOT

Verified by



Nomathemba Mpulo

SENIOR TECHNOLOGIST: ARNOT


Supported by



Rofhiwa Tshikovha

SENIOR ENVIRONMENTAL ADVISOR: ARNOT

Yours sincerely



Samuel Tsoro Mashao

ACTING GENERAL MANAGER: ARNOT