



Mrs Mpho Nembilwi
Nkangala District
P O Box 437
MIDDLEBERG
1050
By email nembilwim@nkangaladm.gov.za'

Date
29 July 2021

Enquiries S Chokoe
Tel +27 13 647 6970

Dear Mrs Mpho Nembilwi

Ref Kendal Power Station AEL (17/4/AEL/MP312/11/15)

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF JUNE 2021.

This is a monthly report required in terms of Section 7 4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Compiled by:

Tshildzi Vilane
ENVIRONMENTAL OFFICER- KENDAL

Date: 29/07/2021

Supported by:

Solly Chokoe
ACTING ENVIRONMENTAL MANAGER- KENDAL

Date: 29/07/2021

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTHS OF JUNE 2021.

Verified by:


Hlono Malatsi
SENIOR TECHNICIAN BOILER ENGINEERING- KENDAL

Date: 29/07/2021

Validated by:


Tendani Rasivhetshela
ACTING BOILER ENGINEERING MANAGER-KENDAL

Date 29/07/2021

Supported by:


Malibongwe Mabizela
ACTING ENGINEERING MANAGER-KENDAL

Date 29/07/2021

Approved by:


Yangaphe Ngcashi
GENERAL MANAGER-KENDAL

Date 2021.08.03

KENDAL POWER STATION MONTHLY EMISSIONS REPORT
 Atmospheric Emission License 17/4/AEL/MP312/11/15



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Jun-2021
	Coal	Tons		2 260 000
Fuel Oil	Tons		2 000	2743,58

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Jun-2021
	Energy	GWh(MW)		2963,52
Ash	Tons		770 000	263 283,7
RE Ash	kg/MWh		not specified	0,410

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	<1 (%)	0,800
Ash Content	%	40 (%)	32,560

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO _x	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMET TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jun-2021	Technology Type	Utilization Jun-2021
Unit 1	ESP + SO ₃	99,9%	SO ₃	85,0%
Unit 2	ESP + SO ₃	99,7%	SO ₃	93,7%
Unit 3	ESP + SO ₃	99,5%	SO ₃	58,5%
Unit 4	ESP + SO ₃	99,6%	SO ₃	82,8%
Unit 5	ESP + SO ₃	97,4%	SO ₃	SO3 server not available after unit was back to load
Unit 6	ESP + SO ₃	Off-line	SO ₃	Off-line

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	99,4	100,0	100,0	99,9
Unit 2	99,7	100,0	100,0	99,9
Unit 3	99,6	100,0	99,0	98,8
Unit 4	100,0	100,0	98,3	98,0
Unit 5	71,4	100,0	94,3	100,0
Unit 6	Off-line	Off-line	Off-line	Off-line

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of June 2021

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	42,9	3 970	1 081
Unit 2	142,8	4 637	1 647
Unit 3	199,1	2 933	908
Unit 4	153,4	2 108	656
Unit 5	600,0	1 278	402
Unit 6	Off-line	Off-line	Off-line
SUM	1 138,08	14 925	4 695

Table 6.2: Operating days in compliance to PM AEL Limit - June 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	31	0	0	0	0	20,2
Unit 2	25	5	0	0	5	101,8
Unit 3	14	12	0	0	12	139,0
Unit 4	12	7	2	2	11	176,3
Unit 5	1	1	11	0	12	922,7
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	83	25	13	2	40	

Table 6.3: Operating days in compliance to SOx AEL Limit - June 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average SOx (mg/Nm ³)
Unit 1	31	0	0	0	0	2 933,6
Unit 2	31	0	0	0	0	2 370,8
Unit 3	28	0	0	0	0	2 046,5
Unit 4	26	0	0	0	0	2 088,2
Unit 5	16	0	0	0	0	1 807,8
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	132	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - June 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm ³)
Unit 1	31	0	0	0	0	800,7
Unit 2	31	0	0	0	0	836,2
Unit 3	28	0	0	0	0	629,7
Unit 4	26	0	0	0	0	645,0
Unit 5	16	0	0	0	0	583,7
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	132	0	0	0	0	

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contra-vention	Red	Emissions above ELV but outside grace or S30 incident conditions






Figure 2: Kendal Unit 2 PM Emissions - June 2021



On the 01st and the 02nd the high emissions can be attributed to Sulphur common plant supply pump failure

On the 10th the high emissions can be attributed multiple trips of the SO3 plant due low BET and due to main blower that was faulty

Figure 3: Kendal Unit 3 PM Emissions - June 2021




the high PM emissions can be attributed to Sulphur common plant supply pump failure

High PM emissions can be attributed to RH secondary A/H's very low heat transfer causing high BET and resulting in SO3 plant underperforming between the 4th and 17th.

the high PM emissions can be attributed to faulty compartment level and closure of hopper knife gates

Figure 4: Kendal Unit 4 PM Emissions - June 2021




the high PM emissions can be attributed to Sulphur common plant supply pump failure

High PM emissions can be attributed to unit light-up.

Contravention picked up after reporting tool amendment

High PM emissions can be attributed to maintenance work on Unit 3 & 4 Aux steam supply valve.



the high emissions can be attributed to poor performance of the ESP due to poor performance of the ESP fields due to some technical issues of the CE rapper system that must be tested while boiler is on load based on the plant monitoring system programme software





Figure 8: Kendal Unit 2 SOx Emissions - June 2021




Figure 9: Kendal Unit 3 SOx Emissions - June 2021




Figure 10: Kendal Unit 4 SOx Emissions - June 2021




Figure 11: Kendal Unit 5 SOx Emissions - June 2021




Figure 12: Kendal Unit 6 SOx Emissions - June 2021




Figure 13: Kendal Unit 1 NOx Emissions - June 2021




Figure 14: Kendal Unit 2 NOx Emissions - June 2021




Figure 15: Kendal Unit 3 NOx Emissions - June 2021




Figure 16: Kendal Unit 4 NOx Emissions - June 2021




Figure 17: Kendal Unit 5 NOx Emissions - June 2021





Figure 18: Kendal Unit 6 NOx Emissions - June 2021



7 COMMENTS

There were no complaints for this months

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

ADDENDUM TO MONTHLY EMISSIONS REPORT

Abatement Technology-Table 4

In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as

- Ⓜ Coal ash content (%) and burnt rate mass
- Ⓜ Fly Coarse ash ratio of 80-20 - 80% of fly-ash mass obtained from burnt coal goes to ESP
- Ⓜ Measurement of dust emission by Dust Monitor over a period of time (monthly)

Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \frac{(\text{Dust Emission From AQR Report} - \text{Dust Monitor (tons)})}{(\text{Coal Burnt (tons)} \times \% \text{Ash Content} \times 80\%)} \times 100$$

Monitor Reliability-Table 5

In terms of the minimum emissions standard, the requirement is that a monitor should be 98% reliable on a monthly average. The monitor reliability refers to data reliability because the assumed value of 98% reliability is compared to the dust concentration signal. If the dust concentration signal is above 98% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g. 24 hours. The formula is as follows:

$$= (1 - (\text{count hours above 98\%/24 hours})) \times 100$$

Emissions Performance

- Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2, 3, 4 & 5 due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- Unit 6 was still offload during this month for repairs to address emissions issues

Unit 2

Findings On the 01st and the 02nd the high emissions can be attributed to Sulphur common plant supply pump failure. On the 10th the high emissions can be attributed to multiple trips of the SO3 plant due to low BET and due to main blower that was faulty.

Resolution

Sulphur common plant supply pump and SO3 plant blower were repaired.

Unit 3

Findings On the 01st and the 02nd the high PM emissions can be attributed to Sulphur common plant supply pump failure. High PM emissions can be attributed to Right Hand secondary Air Heater which was very low heat transfer causing high back end temperatures and resulting in SO3 plant underperforming between the 4th and 17th. On 29th & 30th high PM emissions can be attributed to faulty compartment level and closure of hopper knife gates.

Resolution

The common plant supply pumps were repaired.

Unit 4

Findings On the 01st and the 02nd the high PM emissions can be attributed to Sulphur common plant supply pump failure. On the 12th & 13th and on 18th & 19th High PM emissions can be attributed to unit light-up.

On 22 to 24 High PM emissions can be attributed to maintenance work on Unit 3 & 4 Auxiliary steam supply valve.

Resolution

The plant was repaired.

Unit 5

Findings the high emissions can be attributed to poor performance of the ESP fields due to some technical issues of the CE rapping systems that must be tested while the boiler is on load based on the plant monitoring system (PMS) programme software.

Resolution

A decision is taken to keep fields in service at reduced power to avoid dislodging too much fly ash during ESP fields rapping so as to prevent choking of conveyors.