	Matimba Power Station Emissions report	Matimba Power Station
---	---	------------------------------

Title: **Matimba Power Station January
2021 emissions report**

Document Identifier: **RP/247/003**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area
Applicability: **Environment**

Revision: **3**

Total Pages: **38**

Report Date: **October 2021**

Disclosure
Classification: **Controlled**

Compiled by



**WC Mocke
Environmental Officer**

Date: 2021/10/27


Functional Responsibility



**MC Mamabolo
Environmental Manager**

Date: 29 October 2021

Authorized by



**CO Mabotja
General Manager**

Date: 2021/10/29

Content

	Page
1. Report Summary	4
2. Emission information	5
2.1 Raw materials and products	5
2.2 Abatement technology	5
2.3 Energy source characteristics	6
2.4 Emissions reporting	6
2.4.1 Particulate Matter Emissions	6
2.4.2 Gaseous Emissions	12
2.4.3 Total Volatile Organic Compounds	24
2.4.4 Greenhouse gas (CO ₂) emissions	25
2.5 Daily power generated	25
2.6 Pollutant Tonnages	32
2.7 Reference values	32
2.8 Continuous Emission Monitors	33
2.8.1 Reliability	33
2.8.2 Changes, downtime and repairs	34
2.8.3 Sampling dates and times	34
2.9 Start-up information	35
2.10 Emergency generation	36
2.11 Complaints register	36
2.12 Air quality improvements and social responsibility conducted	36
2.12.1 Air quality improvements	36
2.12.2 Social responsibility conducted	36
2.13 Ambient air quality monitoring	36
2.14 Electrostatic precipitator and Sulphur plant status	37
2.15 General	38
3. Attachments	38
4. Report Conclusion	38
Table 1: Quantity of Raw Materials and Products used/produced for the month	5
Table 2: Abatement Equipment Control Technology Utilised	5
Table 3: Energy Source Material Characteristics	6
Table 4: Total volatile compound estimates	24
Table 5: Daily power generated per unit in MWh for the month of January 2021	25
Table 6: Pollutant tonnages for the month of January 2021	32
Table 7: Reference values for data provided	32
Table 8: Average % availability of monitors for the month of January 2021.	33
Table 9: Start-up information	35

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Emergency generation	36
Table 11: Complaints.....	36

Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of January 2021	6
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of January 2021	7
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of January 2021	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of January 2021	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of January 2021	10
Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of January 2021	11
Figure 7: SO ₂ daily average emissions against emission limit for unit 1 for the month of January 2021	12
Figure 8: SO ₂ daily average emissions against emission limit for unit 2 for the month of January 2021	13
Figure 9: SO ₂ daily average emissions against emission limit for unit 3 for the month of January 2021	14
Figure 10: SO ₂ daily average emissions against emission limit for unit 4 for the month of January 2021	15
Figure 11: SO ₂ daily average emissions against emission limit for unit 5 for the month of January 2021	16
Figure 12: SO ₂ daily average emissions against emission limit for unit 6 for the month of January 2021	17
Figure 13: NO _x daily average emissions against emission limit for unit 1 for the month of January 2021	18
Figure 14: NO _x daily average emissions against emission limit for unit 2 for the month of January 2021	19
Figure 15: NO _x daily average emissions against emission limit for unit 3 for the month of January 2021	20
Figure 16: NO _x daily average emissions against emission limit for unit 4 for the month of January 2021	21
Figure 17: NO _x daily average emissions against emission limit for unit 5 for the month of January 2021	22
Figure 18: NO _x daily average emissions against emission limit for unit 6 for the month of January 2021	23
Figure 19: Unit 1 daily generated power in MWh for the month of January 2021	26
Figure 20: Unit 2 daily generated power in MWh for the month of January 2021	27
Figure 21: Unit 3 daily generated power in MWh for the month of January 2021	28
Figure 22: Unit 4 daily generated power in MWh for the month of January 2021	29
Figure 23: Unit 5 daily generated power in MWh for the month of January 2021	30
Figure 24: Unit 6 daily generated power in MWh for the month of January 2021	31

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (12/4/12L-W4/A4) in March 2020. Condition 7.7.1 of the License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in condition 7.7.1 for January 2021.



Due to recommendations received from an internal emission data review the Matimba Power Station January 2021 emissions report was reviewed.

Changes were made to correlation curves which were incorrectly captured and averaged Quality Assurance level 2 test data was used where raw data was unreliable.

These changes influenced the pollutant tonnages and the monitor reliability reported in the revision 2 of the report. The influenced data has been updated and is provided in the specific sections in the report

During the period under review, Matimba experienced seven exceedances of the daily particulate matter emission limit ($50\text{mg}/\text{Nm}^3$), all exceedances were within the 48hour grace period. No exceedances of the daily NO_x emission limit ($750\text{mg}/\text{Nm}^3$), and of the monthly SO_x limit ($3500\text{mg}/\text{Nm}^3$) occurred.

Gaseous emission monitoring availability was below the required 90% for unit 1, unit 2, unit 4 and unit 6.

Issues mentioned above are discussed further under the respective sections within the report.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	1 050 144
	Fuel Oil	Tons/month	1 200	1117,61
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	GWh	4 212.6	2 010,816

The coal and fuel oil consumptions rates for the month of January 2021 were within the permitted maximum limit. The consumption rate for fuel oil increased compared to previous months, this was due to multiple unit start-ups (three in total) during the reporting period.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	Electrostatic Precipitator	100%	99,93%
Unit 2	Electrostatic Precipitator	100%	99,94%
Unit 3	Electrostatic Precipitator	100%	99,89%
Unit 4	Electrostatic Precipitator	100%	99,88%
Unit 5	Electrostatic Precipitator	100%	99,92%
Unit 6	Electrostatic Precipitator	100%	99,86%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO ₃ Plant	100%	87,1%
Unit 2	SO ₃ Plant	100%	93,5%
Unit 3	SO ₃ Plant	100%	93,5%
Unit 4	SO ₃ Plant	100%	90,3%
Unit 5	SO ₃ Plant	100%	100%
Unit 6	SO ₃ Plant	100%	96,8%

Matimba experienced challenges with regards to sulphur plant availability. Long lead times for delivery for spares and unplanned breakdowns caused units 1, 2, 3, 4 and 6 to not achieve the required 100% availability of the respective sulphur plants. Planned maintenance activities can also cause availability to not reach 100%.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3 Energy source characteristics

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	0.8-1.6%	1.321%
	Ash Content	30-40%	32.590%

Energy source characteristics remained within the ranges stipulated in the license.

2.4 Emissions reporting

2.4.1 Particulate Matter Emissions

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of January 2021

Interpretation:

All daily averages below particulate emission limit of 50 mg/Nm³.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of January 2021

Interpretation:

All daily averages below particulate emission limit of 50 mg/Nm³.

CONTROLLED,

Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of January 2021

Interpretation:

Unit 3 exceeded the particulate emission limit of 50 mg/Nm³ on the 10th and 11th of January 2021. The exceedances were due to defects within the ash handling plant. Defects were addressed and no further exceedances were noted. The 48-hour grace period was not exceeded.

CONTROLLED,

Unit 4 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of January 2021

Interpretation:

Unit 4 exceeded the particulate emission limit of 50 mg/Nm³ on the 19th and 20th and 27th of January 2021. The exceedances were due to breakdowns on the Sulphur plant. The plant was repaired and emissions returned to normal. The exceedances did not exceed the 48-hour grace period.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of January 2021

Interpretation:

All daily averages below particulate emission limit of 50 mg/Nm³.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 Particulate Emissions




Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of January 2021

Interpretation:

Unit 6 exceeded the particulate emission limit of 50 mg/Nm³ on the 8th and 9th of January 2021 due to defects on the sulphur plant. The exceedances did not exceed the 48-hour grace period. Unit 6 is currently on outage and defects on the sulphur plant are being addressed.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.2 Gaseous Emissions


Unit 1 SO₂ Emissions

Figure 7: SO₂ daily average emissions against emission limit for unit 1 for the month of January 2021

Interpretation:

All daily averages below monthly SO₂ emission limit of 3500 mg/Nm³.

Average Emission data for the 1st until the 14th of January 2021 was used due to the monitor giving faulty readings for that time period. Monitor was repaired on the 14th.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 SO₂ Emissions

Figure 8: SO₂ daily average emissions against emission limit for unit 2 for the month of January 2021

Interpretation:

Unit 2 experienced increased SO_x emissions on the 14th and of January 2021 and from the 24th to the 26th of January 2021. The monthly average remained below the limit of 3500mg/Nm³ with a monthly average of 3358mg/Nm³

Average Emission data for the 1st until the 13th of January 2021 was used due to the monitor computer being defective. The computer was repaired on the 13th of January 2021.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 SO₂ Emissions

Figure 9: SO₂ daily average emissions against emission limit for unit 3 for the month of January 2021

Interpretation:

All daily averages below monthly SO₂ emission limit of 3500 mg/Nm³.

Average Emission data for the 13th and 14th of January 2021 was used due to faulty monitor readings.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 SO₂ Emissions

Figure 10: SO₂ daily average emissions against emission limit for unit 4 for the month of January 2021

Interpretation:

Unit 4 experienced increased SO_x emissions on 18 January 2021. The monthly average remained below the limit of 3500mg/Nm³.

Unit 4 gaseous emission monitor started providing faulty readings on the 20th of January 2021. Averaged QAL 2 values were used for reporting SO_x emission data for January 2021.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 5 SO₂ Emissions

Figure 11: SO₂ daily average emissions against emission limit for unit 5 for the month of January 2021

Interpretation:

All daily averages below monthly SO₂ emission limit of 3500 mg/Nm³.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 SO₂ Emissions

Figure 12: SO₂ daily average emissions against emission limit for unit 6 for the month of January 2021

Interpretation:

All daily averages below monthly SO₂ emission limit of 3500 mg/Nm³.

Average Emission data from the 12th until the 29th of January 2021. Gaseous emission monitor provided faulty readings due to a defective pressure sensor and computer.

Unit 6 was shut down on the 29th of January 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 NO_x Emissions




Figure 13: NO_x daily average emissions against emission limit for unit 1 for the month of January 2021

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

Average Emission data for the 1st until the 14th of January 2021 was used due to the monitor giving faulty readings for that time period. Monitor was repaired on the 14th.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 NO_x Emissions

Figure 14: NO_x daily average emissions against emission limit for unit 2 for the month of January 2021

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³

Average Emission data for the 1st until the 13th of January 2021 was used due to the computer being defective. The computer was repaired on the 13th of January 2021.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 NO_x Emissions

Figure 15: NO_x daily average emissions against emission limit for unit 3 for the month of January 2021

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

Average Emission data for the 13th and 14th of January 2021 was used due to faulty monitor readings.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 NO_x Emissions

Figure 16: NO_x daily average emissions against emission limit for unit 4 for the month of January 2021

Interpretation:

Unit 4 gaseous emission monitor started providing faulty readings on the 20th of January 2021. Averaged QAL 2 values were used for reporting NO_x emission data for January 2021.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 5 NO_x Emissions

Figure 17: NO_x daily average emissions against emission limit for unit 5 for the month of January 2021

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 NO_x Emissions

Figure 18: NO_x daily average emissions against emission limit for unit 6 for the month of January 2021

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

Average Emission data from the 12th until the 29th of January 2021. Gaseous emission monitor provided faulty readings due to a defective pressure sensor and computer.

Unit 6 was shut down on the 29th of January 2021


CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Wednesday, 24 February 2021	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center">MONTHLY INPUT DATA FOR THE STATION</p> <p align="center">Please only insert relevant monthly data inputs into the blue cells below</p> <p align="center">Choose from a dropdown menu in the green cells</p> <p align="center">The total VOC emissions for the month are in the red cells</p> <p align="center">IMPORTANT: Do not change any other cells without consulting the AQ CoE</p>		
MONTH:	January	
GENERAL INFORMATION:	Data	Unit
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	1117,610	tons/month
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
METEOROLOGICAL DATA FOR THE MONTH	Data	Unit
Daily average ambient temperature	25,11	°C
Daily maximum ambient temperature	31,57	°C
Daily minimum ambient temperature	17,48	°C
Daily ambient temperature range	14,10	°C
Daily total insolation factor	5,87	kWh/m²/day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
FINAL OUTPUT:	Result	Unit
Breathing losses:	0,60	kg/month
Working losses:	0,03	kg/month
TOTAL LOSSES (Total TVOC Emissions for the month):	0,63	kg/month
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Trittech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, No.R. 994) and are not included in the monthly AEL compliance report.

2.5 Daily power generated

Table 5: Daily power generated per unit in MWh for the month of January 2021

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2021/01/01	14798,5	14107,5	15976,9	0	15449,2	14443
2021/01/02	14560,7	13945,1	15314,6	0	15270,8	13522,3
2021/01/03	12590,3	13795,3	11026,5	0	12699,8	12421,1
2021/01/04	14461,5	14253,9	10934,7	0	15032,4	14145,9
2021/01/05	14149,8	13770	0	0	14920	13730,5
2021/01/06	13535,8	12772,3	0	0	14303	12625,9
2021/01/07	14594	14520,5	0	0	15263	14843,6
2021/01/08	14963	14152	0	0	15754,7	12991,1
2021/01/09	14806,5	13215	3635,2	0	15633,9	11837,4
2021/01/10	13428,9	12763,2	13962,6	0	13956,7	10441,1
2021/01/11	14976,5	12567,5	13998	0	14454,6	11590,6
2021/01/12	15068	12828,8	12951	0	14794,2	12755
2021/01/13	15152,7	12251,5	12843,8	0	15282,2	13232
2021/01/14	15277	12388,9	12968,7	0	15340,4	12748,4
2021/01/15	15274,7	12942,1	15082,6	0	15767,3	13315,3
2021/01/16	15028,3	13228,9	15797,2	0	14918,3	12577
2021/01/17	13669,2	12254,7	14515,7	0	14003,7	11604,1
2021/01/18	15256	15020,5	15828,9	202,3	11991,8	11754,5
2021/01/19	13651,4	13822,9	13632,2	6442	14152,8	11670,9
2021/01/20	13955,7	13444,6	12717,7	10565	14078,7	12428,5
2021/01/21	14874,5	13615,7	15477,6	10064	14790,8	11744,7
2021/01/22	14818,6	13074,9	15298,5	10420	14803	12858,8
2021/01/23	14776,6	13562,7	15012,7	11143	14160	12033,7
2021/01/24	12649,1	13578,4	14202,5	12555	13376,9	12317,5
2021/01/25	14154,5	14485,5	14462,7	12341	14380,3	12123,6
2021/01/26	13645,3	14680,1	13762,1	12731	14148	12049,5
2021/01/27	14832,5	14928,8	15531,9	12592	15775,2	12393,5
2021/01/28	14599,1	13980,9	15871,5	11729	15918,3	11974,4
2021/01/29	15073,5	14645,2	14378	12504	15796,6	1320,13
2021/01/30	14904	14802	14510,2	11995	15730,8	0
2021/01/31	14568,1	14462,5	12832,3	13081	15854,2	0

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 19: Unit 1 daily generated power in MWh for the month of January 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 2 daily generated power in MWh for the month of January 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 21: Unit 3 daily generated power in MWh for the month of January 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 22: Unit 4 daily generated power in MWh for the month of January 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 23: Unit 5 daily generated power in MWh for the month of January 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 24: Unit 6 daily generated power in MWh for the month of January 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.6 Pollutant Tonnages

Table 6: Pollutant tonnages for the month of January 2021

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)	CO ₂ (tons)
Unit 1	45,8	6 211,0	963,8	427 235
Unit 2	35,1	7 358,0	1 034,7	478 904
Unit 3	55,2	6 348,2	996,6	402 568
Unit 4	24,9	2 160,8	409,9	142 524
Unit 5	50,4	6 202,8	887,1	427 538
Unit 6	68,4	5 669,5	963,0	352 332
SUM	279,8	33 950,4	5 255,2	2 231 101

The emitted pollutant tonnages for January 2021 are provided in table 6.

2.7 Reference values

Table 7: Reference values for data provided

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	8,77	7,55	7,00	7,57	7,92	8,59
Moisture	%	5,32	5,30	5,49	2,37	5,52	4,30
Velocity	m/s	29,4	27,0	29,7	21,9	27,6	28,2
Temperature	°C	140,8	133,1	133,5	133,2	130,4	123,5
Pressure	mBar	929,4	931,1	914,8	879,0	926,2	889,1

Table 7 shows the reference values for the emission data provided for the month of January 2021.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8 Continuous Emission Monitors

2.8.1 Reliability

Table 8: Average percentage (%) availability of monitors for the month of January 2021.

Associated Unit/Stack	PM	SO ₂	NO	CO ₂
Unit 1	100,0	56,7	56,7	0,0
Unit 2	100,0	56,3	56,3	53,1
Unit 3	100,0	96,7	96,7	57,9
Unit 4	100,0	0,0	0,0	0,0
Unit 5	100,0	96,6	96,6	96,5
Unit 6	99,9	39,2	39,2	39,2

Unit 1, unit 2, unit 4, unit 6 gaseous emission monitors and unit 3 CO₂ monitor performed below the required limit of 90% availability stipulated within the atmospheric emission license.

Unit 1 was available 100% of the time but provided faulty readings. The monitor was repaired on the 14th of January 2021. CO₂ and O₂ raw data was replaced with average Quality Assurance Level 2 (QAL2) values due to the monitors providing unreliable data.

Unit 2 gaseous emission monitor did not achieve 90% availability due to a failed computer. The computer was replaced on the 13th of January 2021 and the monitor returned to 100% availability.

Unit 4 gaseous emission monitor started providing faulty readings on the 20th of January 2021. Average QAL 2 values were used for reporting purposes.

Unit 6 gaseous emission monitor provided faulty readings from the 12th of January 2021 due to a faulty pressure sensor and failed computer. The sensor and computer has been repaired. The was on outage since the 30th of January 2021.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8.2 Changes, downtime and repairs

Unit 1

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 2

- Unit 2 Gaseous analyser did not achieve 90% availability as per the license requirement. This is due to a fluctuating availability after each calibration. The monitor has since been repaired again and is being closely monitored.
- No downtime or repairs done on the particulate monitors

Unit 3

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 4

- Unit 4 Gaseous emission monitor is reading and is available, however, the data is not getting through to the servers for storage. Service provider has been contacted and monitor will be repaired by 28 February 2021.
- No downtime or repairs done on the particulate monitors

Unit 5

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 6

- Unit 6 gaseous monitor was not available from the 13th of January 2021. The monitor has since been repaired.
- No downtime or repairs done on the particulate monitors

2.8.3 Sampling dates and times

Continuous

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.9 Start-up information

Table 9: Start-up information

Unit	3	
Fires in	09h21	2021-01-09
Synchronization with Grid	16h35	2021-01-09
Emissions below limit	16h35	2021-01-09
Fires in to synchronization	7.38	HOURS
Synchronization to < Emission limit	0	HOURS

Unit	4	
Fires in	15h20	2021-01-17
Synchronization with Grid	05h37	2021-01-18
Emissions below limit	07h23	2021-01-18
Fires in to synchronization	14.28	HOURS
Synchronization to < Emission limit	1.77	HOURS

Unit	4	
Fires in	15h55	2021-01-18
Synchronization with Grid	23h14	2021-01-18
Emissions below limit	02h03	2021-01-19
Fires in to synchronization	7.32	HOURS
Synchronization to < Emission limit	2.82	HOURS

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10 Emergency generation

Table 10: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	620	620	490	207	620	563
Emergency Hours declared including hours after stand down	632	632	500	214	632	573
Days over the Limit during Emergency Generation	0	0	3	2	0	2

2.11 Complaints register

Table 11: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

2.12 Air quality improvements and social responsibility conducted

2.12.1 Air quality improvements

None

2.12.2 Social responsibility conducted

None

2.13 Ambient air quality monitoring

The monitoring site experienced incoming power interruptions due to a faulty earth leakage inside the monitoring hut. This affected the functioning of the analysers and led to low data recovery at the Marapong Air Quality Monitoring site.

The average data recovery for the period was 33,2% and the station availability was 32,6%.

Detailed information regarding this issue can be found in Attachment 1, "FEEDBACK Marapong January 2021 REPORT_Final".

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.14 Electrostatic precipitator and Sulphur plant status

Unit 1

- 0 out of 32 precipitator fields is out of service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 2

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 3

- 2 out of 32 precipitator fields is out of service. Repairs will be done during the next opportunity outage.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 4

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 5

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 6

- 3 out of 32 precipitator fields is out of service. Repairs will be done during the next opportunity outage.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

SO3 common plant

- No abnormalities on the sulphur storage plant.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.15 General

Name and reference number of the monitoring method used:

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

None

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.