 Eskom	<b>Matimba Power Station Emissions report</b>	<b>Matimba Power Station</b>
-----------------------------------------------------------------------------------------	---------------------------------------------------	------------------------------

Title: **Matimba Power Station February  
2021 emissions report**

Document Identifier: **RP/247/004**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area  
Applicability: **Environment**

Revision: **2**

Total Pages: **39**

Report Date: **October 2021**

Disclosure  
Classification: **Controlled**

**Compiled by**


**Functional Responsibility**

**Authorized by**




**WC Mocke  
Environmental Officer**

Date: 2021/10/27



**MC Mamabolo  
Environmental Manager**

Date: 29/10/2021



**CO Mabotja  
General Manager**

Date: 2021/10/29

## Content

	Page
1. Report Summary .....	4
2. Emission information .....	5
2.1 Raw materials and products .....	5
2.2 Abatement technology .....	5
2.3 Energy source characteristics .....	6
2.4 Emissions reporting .....	6
2.4.1 Particulate Matter Emissions .....	6
2.4.2 Gaseous Emissions .....	12
2.4.3 Total Volatile Organic Compounds .....	24
2.5 Daily power generated .....	25
2.6 Pollutant Tonnages .....	32
2.7 Reference values .....	32
2.8 Continuous Emission Monitors .....	33
2.8.1 Reliability .....	33
2.8.2 Changes, downtime and repairs .....	34
2.8.3 Sampling dates and times .....	34
2.9 Start-up information .....	35
2.10 Emergency generation .....	36
2.11 Complaints register .....	37
2.12 Air quality improvements and social responsibility conducted .....	37
2.12.1 Air quality improvements .....	37
2.12.2 Social responsibility conducted .....	37
2.13 Ambient air quality monitoring .....	37
2.14 Electrostatic precipitator and Sulfur plant status .....	38
2.15 General .....	39
3. Attachments .....	39
4. Report Conclusion .....	39

## Tables

Table 1: Quantity of Raw Materials and Products used/produced for the month .....	5
Table 2: Abatement Equipment Control Technology Utilised .....	5
Table 3: Energy Source Material Characteristics .....	6
Table 4: Total volatile compound estimates .....	24
Table 5: Daily power generated per unit in MWh for the month of February 2021 .....	25
Table 6: Pollutant tonnages for the month of February 2021 .....	32
Table 7: Reference values for data provided .....	32
Table 8: Average % availability of monitors for the month of February 2021 .....	33
Table 9: Start-up information .....	35

## CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Emergency generation .....	36
Table 11: Complaints.....	37

## Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of February 2021 .....	6
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of February 2021 .....	7
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of February 2021 .....	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of February 2021 .....	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of February 2021 .....	10
Figure 6: SO <sub>2</sub> daily average emissions against emission limit for unit 1 for the month of February 2021 .....	12
Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of February 2021 .....	13
Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of February 2021 .....	14
Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 4 for the month of February 2021 .....	15
Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 5 for the month of February 2021 .....	16
Figure 11: NO <sub>x</sub> daily average emissions against emission limit for unit 1 for the month of February 2021 .....	18
Figure 12: NO <sub>x</sub> daily average emissions against emission limit for unit 2 for the month of February 2021 .....	19
Figure 13: NO <sub>x</sub> daily average emissions against emission limit for unit 3 for the month of February 2021 .....	20
Figure 14: NO <sub>x</sub> daily average emissions against emission limit for unit 4 for the month of February 2021 .....	21
Figure 15: NO <sub>x</sub> daily average emissions against emission limit for unit 5 for the month of February 2021 .....	22
Figure 16: Unit 1 daily generated power in MWh for the month of February 2021 .....	26
Figure 17: Unit 2 daily generated power in MWh for the month of February 2021 .....	27
Figure 18: Unit 3 daily generated power in MWh for the month of February 2021 .....	28
Figure 19: Unit 4 daily generated power in MWh for the month of February 2021 .....	29
Figure 20: Unit 5 daily generated power in MWh for the month of February 2021 .....	30
Figure 21: Unit 6 daily generated power in MWh for the month of February 2021 .....	31

## CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (12/4/12L-W4/A4) in March 2020. Condition 7.7.1 of the License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in condition 7.7.1 for February 2021.



Due to recommendations received from an internal emission data review the Matimba Power Station February 2021 emissions report was reviewed.

Changes were made to correlation curves which were incorrectly captured and averaged Quality Assurance level 2 test data was used where raw data was unreliable.

These changes influenced the pollutant tonnages and the monitor reliability reported in the revision 1 of the report. The influenced data has been updated and is provided in the specific sections in the report

During the period under review, Matimba experienced two exceedances of the daily particulate matter emission limit ( $50\text{mg}/\text{Nm}^3$ ). Both exceedances remained within the 48 hour grace period. No exceedances of the monthly  $\text{SO}_x$  limit ( $3500\text{mg}/\text{Nm}^3$ ) or the daily  $\text{NO}_x$  limit ( $750\text{mg}/\text{Nm}^3$ ) occurred.

Issues mentioned above are discussed further under the respective sections within the report.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2. Emission information

### 2.1 Raw materials and products

**Table 1:** Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	904 789
	Fuel Oil	Tons/month	1 200	814,407
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	GWh	4 212.6	1 810,957

The coal and fuel oil consumptions rates for the month of February 2021 were within the permitted maximum limit.

### 2.2 Abatement technology

**Table 2:** Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	Electrostatic Precipitator	100%	99,94
Unit 2	Electrostatic Precipitator	100%	99,92
Unit 3	Electrostatic Precipitator	100%	99,91
Unit 4	Electrostatic Precipitator	100%	99,85
Unit 5	Electrostatic Precipitator	100%	99,91
Unit 6	Electrostatic Precipitator	100%	Unit on outage
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO <sub>3</sub> Plant	100%	100%
Unit 2	SO <sub>3</sub> Plant	100%	100%
Unit 3	SO <sub>3</sub> Plant	100%	100%
Unit 4	SO <sub>3</sub> Plant	100%	85%
Unit 5	SO <sub>3</sub> Plant	100%	100%
Unit 6	SO <sub>3</sub> Plant	100%	Unit on outage

Unplanned breakdowns caused unit 4 to not achieve the required 100% availability of its sulphur plant. The plant has since been repaired.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.3 Energy source characteristics

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	0.8-1.6%	1,259
	Ash Content	30-40%	31,171

Energy source characteristics remained within the ranges stipulated in the license.

## 2.4 Emissions reporting

### 2.4.1 Particulate Matter Emissions

#### Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of February 2021

#### Interpretation:


All daily averages below particulate emission limit of 50 mg/Nm³.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 2 Particulate Emissions



**Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of February 2021**

**Interpretation:**

All daily averages below particulate emission limit of 50 mg/Nm<sup>3</sup>.


CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## Unit 3 Particulate Emissions



**Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of February 2021**

**Interpretation:**


All daily averages below particulate emission limit of 50 mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 4 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of February 2021**

**Interpretation:**


Unit 4 exceeded the particulate emission limit of 50 mg/Nm<sup>3</sup> on the 25<sup>th</sup> of February 2021. The exceedance was due to breakdowns on the ash handling plant. The plant was repaired and emissions returned to normal. The exceedance did not exceed the 48-hour grace period.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 5 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of February 2021**

**Interpretation:**

All daily averages below particulate emission limit of 50 mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



### Unit 6 Particulate Emissions

**Interpretation:**


Unit was on outage for the whole of February 2021

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.4.2 Gaseous Emissions

Unit 1 SO<sub>2</sub> Emissions

**Figure 6: SO<sub>2</sub> daily average emissions against emission limit for unit 1 for the month of February 2021**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO<sub>2</sub> Emissions

**Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of February 2021**

**Interpretation:**


All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



Unit 3 SO<sub>2</sub> Emissions

**Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of February 2021**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO<sub>2</sub> Emissions

**Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 4 for the month of February 2021**

**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 SO<sub>2</sub> Emissions




Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of February 2021

Interpretation:

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



### Unit 6 SO<sub>2</sub> Emissions


**Interpretation:**

Unit was on outage for the whole of February 2021

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 NO<sub>x</sub> Emissions

**Figure 11: NO<sub>x</sub> daily average emissions against emission limit for unit 1 for the month of February 2021**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO<sub>x</sub> Emissions

**Figure 12: NO<sub>x</sub> daily average emissions against emission limit for unit 2 for the month of February 2021**

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 NO<sub>x</sub> Emissions

Figure 13: NO<sub>x</sub> daily average emissions against emission limit for unit 3 for the month of February 2021

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



Unit 4 NO<sub>x</sub> Emissions





Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of February 2021

Interpretation:

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.  
No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO<sub>x</sub> Emissions

**Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of February 2021**

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### Unit 6 NO<sub>x</sub> Emissions

**Interpretation:**

Unit on outage


**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Friday, 19 March 2021	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <u>blue cells</u> below</p> <p align="center">Choose from a dropdown menu in the <u>green cells</u></p> <p align="center">The total VOC emissions for the month are in the <u>red cells</u></p> <p align="center">IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE</p>		
MONTH:	February	
<b>GENERAL INFORMATION:</b>		
	<b>Data</b>	<b>Unit</b>
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	814,407	tons/month
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
<b>METEROLOGICAL DATA FOR THE MONTH</b>		
	<b>Data</b>	<b>Unit</b>
Daily average ambient temperature	26,20	°C
Daily maximum ambient temperature	32,94	°C
Daily minimum ambient temperature	20,71	°C
Daily ambient temperature range	12,24	°C
Daily total insolation factor	5,72	kWh/m <sup>2</sup> /day
Tank paint colour	Grey/medium	NA
Tank paint solar absorptance	0,68	NA
<b>FINAL OUTPUT:</b>		
	<b>Result</b>	<b>Unit</b>
Breathing losses:	0.57 kg/month	
Working losses:	0.02 kg/month	
<b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>	<b>0.59 kg/month</b>	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.5 Daily power generated

**Table 5:** Daily power generated per unit in MWh for the month of February 2021

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2021/02/01	14698,1	14880,7	14319,7	13655	10385,4	0
2021/02/02	14932,1	14830,3	14397,3	13142	8454,5	0
2021/02/03	14634,7	15079,3	14366,5	14219	14380	0
2021/02/04	11826,8	15224,1	15177,7	11692	15821,5	0
2021/02/05	12758,2	15182,7	14885,1	13369	16100,7	0
2021/02/06	15115,3	15079,2	14726,1	12453	15986,9	0
2021/02/07	14384,4	14706,5	15180,8	14128	14976	0
2021/02/08	14842,4	14394,3	14346,3	13080	15653,1	0
2021/02/09	15283	13865,3	14456	12764	15898,5	0
2021/02/10	15201,3	14283,8	12374,3	12432	15251,9	0
2021/02/11	14106,5	14356,3	14155,7	13414	14848,1	0
2021/02/12	14775,7	14386,3	14857,9	13577	15845,3	0
2021/02/13	14715,9	15231,5	14902,9	14860	15975,4	0
2021/02/14	14546,4	15144,1	14702,6	14622	15825,8	0
2021/02/15	14147,2	15027,1	14662	12504	15362,8	0
2021/02/16	14602,5	14685,4	15053,1	14792	15237,9	0
2021/02/17	14961,5	14778,3	15268,7	15705	15547,9	0
2021/02/18	13673,1	14738	14516,2	15161	11791,5	0
2021/02/19	14613,7	14943,6	14177,9	14328	12921,1	0
2021/02/20	14091,7	14624,5	15630,1	15418	15645,9	0
2021/02/21	5843,27	14848,5	15998,5	15593	16041,8	0
2021/02/22	14875,2	15420,4	16168,6	11129	16150,5	0
2021/02/23	14096,1	15418,5	16138,7	0	16099,7	0
2021/02/24	13855,1	1538,8	16132,3	8619	16148,8	0
2021/02/25	14001,1	12182,7	16202,5	9534	15886,1	0
2021/02/26	14162,4	14233,8	16214,3	14276	16118	0
2021/02/27	13963	15027,1	14258,5	14776	15376,8	0
2021/02/28	12452,9	13760,3	12929,1	12255	12692,2	0

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 16: Unit 1 daily generated power in MWh for the month of February 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.





Figure 17: Unit 2 daily generated power in MWh for the month of February 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.






**Figure 18: Unit 3 daily generated power in MWh for the month of February 2021**

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.





**Figure 19: Unit 4 daily generated power in MWh for the month of February 2021**

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.





Figure 20: Unit 5 daily generated power in MWh for the month of February 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 21: Unit 6 daily generated power in MWh for the month of February 2021**

**Note:** Unit is on outage

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.6 Pollutant Tonnages

**Table 6:** Pollutant tonnages for the month of February 2021

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	CO <sub>2</sub> (tons)
Unit 1	29,6	5 259,8	828,3	408 788
Unit 2	40,6	6 446,6	981,6	451 728
Unit 3	48,4	6 828,9	1 139,8	406 134
Unit 4	56,5	5 455,3	1 117,5	330 608
Unit 5	47,6	5 305,6	827,7	372 580
Unit 6	0,0	0,0	0,0	0
<b>SUM</b>	222,6	29 296,2	4 895,0	1 969 837

The emitted pollutant tonnages for February 2021 are provided in table 6. Unit 6 was on outage for the whole of February 2021.

## 2.7 Reference values

**Table 7:** Reference values for data provided

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	6,20	6,32	7,66	6,80	7,91	
Moisture	%	5,31	5,24	4,66	3,88	5,69	
Velocity	m/s	29,9	27,6	30,5	25,0	26,8	
Temperature	°C	140,9	130,9	132,3	137,7	128,6	
Pressure	mBar	932,7	933,6	916,0	928,9	930,0	

Table 7 shows the reference values for the emission data provided for the month of February 2021. Unit 6 was on outage for the whole of February 2021.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.8 Continuous Emission Monitors

### 2.8.1 Reliability

**Table 8:** Average percentage (%) availability of monitors for the month of February 2021.

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	CO <sub>2</sub>
Unit 1	100,0	100,0	99,7	25,0
Unit 2	100,0	90,0	90,0	90,0
Unit 3	100,0	100,0	100,0	0,0
Unit 4	100,0	100,0	100,0	90,7
Unit 5	100,0	100,0	100,0	93,0
Unit 6	Unit off	Unit off	Unit off	Unit off

Unit 1 and 3 CO<sub>2</sub> monitors did not achieve the required 90% reliability. Averaged data was used for unit 1 from the 8<sup>th</sup> of February until the 28<sup>th</sup> and average QAL 2 data was used for unit 3 from the 1<sup>st</sup> until the 28<sup>th</sup> of February 2021. The monitors were available however, the raw data was replaced due to unreliability of the accuracy of the monitor.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## **2.8.2 Changes, downtime and repairs**

### **Unit 1**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 2**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 3**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 4**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 5**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 6**

- Unit 6 has been on outage for the whole month of February 2021

## **2.8.3 Sampling dates and times**

Continuous

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.9 Start-up information

Table 9: Start-up information

Unit	1	
Fires in	21h13	2021-02-04
Synchronization with Grid	23h28	2021-02-04
Emissions below limit	03h49	2021-02-05
Fires in to synchronization	2,25	HOURS
Synchronization to < Emission limit	4,35	HOURS

Unit	1	
Fires in	11h00	2021-02-21
Synchronization with Grid	12h52	2021-02-21
Emissions below limit	15h04	2021-02-21
Fires in to synchronization	1,87	HOURS
Synchronization to < Emission limit	2,2	HOURS

Unit	2	
Fires in	13h59	2021-02-24
Synchronization with Grid	20h14	2021-02-24
Emissions below limit	21h30	2021-02-24
Fires in to synchronization	6,25	HOURS
Synchronization to < Emission limit	1,27	HOURS

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	4	
<b>Fires in</b>	00h11	2021-02-24
<b>Synchronization with Grid</b>	05h16	2021-02-24
<b>Emissions below limit</b>	11h02	2021-02-25
<b>Fires in to synchronization</b>	5,08	HOURS
<b>Synchronization to &lt; Emission limit</b>	29,77	HOURS

<b>Unit</b>	4	
<b>Fires in</b>	14h27	2021-02-25
<b>Synchronization with Grid</b>	17h38	2021-02-25
<b>Emissions below limit</b>	19h46	2021-02-25
<b>Fires in to synchronization</b>	3,18	HOURS
<b>Synchronization to &lt; Emission limit</b>	2,13	HOURS

## 2.10 Emergency generation

**Table 10:** Emergency generation

	<b>Unit 1</b>	<b>Unit 2</b>	<b>Unit 3</b>	<b>Unit 4</b>	<b>Unit 5</b>	<b>Unit 6</b>
<b>Emergency Generation hours declared by national Control</b>	167,28	425,76	531,36	345,36	531,36	0
<b>Emergency Hours declared including hours after stand down</b>	174,28	433,76	540,36	352,36	540,36	0
<b>Days over the Limit during Emergency Generation</b>	0	0	0	2	0	0

Unit 4 particulate emissions exceeded the 50mg/Nm<sup>3</sup> emission limit on the 4<sup>th</sup> and 25<sup>th</sup> of February 2021. The exceedances did not exceed the 48 hour grace period. Detailed emission information for unit 4 particulate emissions can be found on figure 4.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.11 Complaints register

Table 11: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

## 2.12 Air quality improvements and social responsibility conducted

### 2.12.1 Air quality improvements

None

### 2.12.2 Social responsibility conducted

None

## 2.13 Ambient air quality monitoring

Six exceedances of the PM<sub>2.5</sub> daily limit and one exceedance of the PM<sub>10</sub> daily limit was noted. No other parameters exceeded the set limits during the monitoring period.

Ambient CO and NO<sub>2</sub> concentrations at Marapong monitoring site show influence of emissions from low level sources in the area while ambient SO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> concentrations show influence of emissions from low level sources, tall stack emitters and other industrial activities.

The average data recovery for the period was 98,4% and the station availability was 98,2%.

Detailed results can be found in Attachment 1, "Marapong monthly Report\_February 2021".

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## **2.14 Electrostatic precipitator and Sulphur plant status**

### **Unit 1**

- 0 out of 32 precipitator fields is out of service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **Unit 2**

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **Unit 3**

- 2 out of 32 precipitator fields is out of service. Repairs will be done during the next opportunity outage.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **Unit 4**

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **Unit 5**

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **Unit 6**

- Unit 6 has been on outage for the whole month of February 2021

### **SO3 common plant**

- No abnormalities on the sulphur storage plant.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.15 General

Name and reference number of the monitoring method used:

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues

## 3. Attachments

- Attachment 1: Marapong monthly Report\_February 2021

## 4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.