 Eskom	<b>Matimba Power Station Emissions report</b>	<b>Matimba Power Station</b>
---	---	------------------------------

Title: **Matimba Power Station March 2021 emissions report** Document Identifier: **RP/247/005**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **2**

Total Pages: **37**

Report Date: **October 2021**

Disclosure Classification: **Controlled**

**Compiled by**

**Functional Responsibility**

**Authorized by**




**WC Mocke  
Environmental Officer**

Date: 2021/10/27



**MC Mamabolo  
Environmental Manager**

Date: 29/10/2021



**CO Mabotja  
General Manager**

Date: 2021/10/29

## Content

	Page
1. Report Summary .....	4
2. Emission information .....	5
2.1 Raw materials and products .....	5
2.2 Abatement technology .....	5
2.3 Energy source characteristics .....	6
2.4 Emissions reporting .....	6
2.4.1 Particulate Matter Emissions .....	6
2.4.2 Gaseous Emissions .....	12
2.4.3 Total Volatile Organic Compounds .....	24
2.4.4 Greenhouse gas (CO <sub>2</sub> ) emissions .....	25
2.5 Daily power generated .....	25
2.6 Pollutant Tonnages .....	31
2.7 Reference values .....	31
2.8 Continuous Emission Monitors .....	32
2.8.1 Reliability .....	32
2.8.2 Changes, downtime and repairs .....	33
2.8.3 Sampling dates and times .....	33
2.9 Start-up information .....	34
2.10 Emergency generation .....	35
2.11 Complaints register .....	35
2.12 Air quality improvements and social responsibility conducted .....	35
2.12.1 Air quality improvements .....	35
2.12.2 Social responsibility conducted .....	35
2.13 Ambient air quality monitoring .....	36
2.14 Electrostatic precipitator and Sulphur plant status .....	36
2.15 General .....	37
3. Attachments .....	37
4. Report Conclusion .....	37
Table 1: Quantity of Raw Materials and Products used/produced for the month .....	5
Table 2: Abatement Equipment Control Technology Utilised .....	5
Table 3: Energy Source Material Characteristics .....	6
Table 4: Total volatile compound estimates .....	24
Table 5: Daily power generated per unit in MWh for the month of March 2021 .....	25
Table 6: Pollutant tonnages for the month of March 2021 .....	31
Table 7: Reference values for data provided .....	31
Table 8: Average percentage (%) availability of monitors for the month of March 2021. ....	32
Table 9: Start-up information .....	34

### CONTROLLED

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Emergency generation .....	35
Table 11: Complaints .....	35

## Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of March 2021 .....	6
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of March 2021 .....	7
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of March 2021 .....	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of March 2021 .....	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of March 2021 .....	10
Figure 6: SO <sub>2</sub> daily average emissions against emission limit for unit 1 for the month of March 2021 .....	12
Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of March 2021 .....	13
Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of March 2021 .....	14
Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 4 for the month of March 2021 .....	15
Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 5 for the month of March 2021 .....	16
Figure 11: NO <sub>x</sub> daily average emissions against emission limit for unit 1 for the month of March 2021 .....	18
Figure 12: NO <sub>x</sub> daily average emissions against emission limit for unit 2 for the month of March 2021 .....	19
Figure 13: NO <sub>x</sub> daily average emissions against emission limit for unit 3 for the month of March 2021 .....	20
Figure 14: NO <sub>x</sub> daily average emissions against emission limit for unit 4 for the month of March 2021 .....	21
Figure 15: NO <sub>x</sub> daily average emissions against emission limit for unit 5 for the month of March 2021 .....	22
Figure 16: Unit 1 daily generated power in MWh for the month of March 2021 .....	26
Figure 17: Unit 2 daily generated power in MWh for the month of March 2021 .....	27
Figure 18: Unit 3 daily generated power in MWh for the month of March 2021 .....	28
Figure 19: Unit 4 daily generated power in MWh for the month of March 2021 .....	29
Figure 20: Unit 5 daily generated power in MWh for the month of March 2021 .....	30

**CONTROLLED**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (12/4/12L-W4/A4) in March 2020. Condition 7.7.1 of the License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in condition 7.7.1 for March 2021.



Due to recommendations received from an internal emission data review the Matimba Power Station March 2021 emissions report was reviewed.

Changes were made to correlation curves which were incorrectly captured and averaged Quality Assurance level 2 test data was used where raw data was unreliable.

These changes influenced the pollutant tonnages and the monitor reliability reported in the revision 1 of the report. The influenced data has been updated and is provided in the specific sections in the report

During the period under review, Matimba experienced two exceedances of the daily particulate matter emission limit ( $50\text{mg}/\text{Nm}^3$ ). Both exceedances remained within the 48 hour grace period. No exceedances of the monthly  $\text{SO}_x$  limit ( $3500\text{mg}/\text{Nm}^3$ ) or the daily  $\text{NO}_x$  limit ( $750\text{mg}/\text{Nm}^3$ ) occurred.

The Gaseous emission ( $\text{SO}_x$  and  $\text{NO}_x$ ) monitors for unit 4 and unit 5 did not achieve the required 90% reliability. The monitors were repaired on the 31<sup>st</sup> of March 2021 and has been 100% available since then.

Issues mentioned above are discussed further under the respective sections within the report.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2. Emission information

### 2.1 Raw materials and products

**Table 1:** Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	1 325 970
	Fuel Oil	Tons/month	1 200	550,488
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	GWh	4 212.6	2 048,435

The coal and fuel oil consumptions rates for the month of March 2021 were within the permitted maximum limit.

### 2.2 Abatement technology

**Table 2:** Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	Electrostatic Precipitator	100%	99,95%
Unit 2	Electrostatic Precipitator	100%	99,95%
Unit 3	Electrostatic Precipitator	100%	99,94%
Unit 4	Electrostatic Precipitator	100%	99,90%
Unit 5	Electrostatic Precipitator	100%	99,94%
Unit 6	Electrostatic Precipitator	100%	Unit Off load
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO <sub>3</sub> Plant	100%	100%
Unit 2	SO <sub>3</sub> Plant	100%	100%
Unit 3	SO <sub>3</sub> Plant	100%	100%
Unit 4	SO <sub>3</sub> Plant	100%	90,3%
Unit 5	SO <sub>3</sub> Plant	100%	100%
Unit 6	SO <sub>3</sub> Plant	100%	Unit Off load

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.3 Energy source characteristics

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	0.8-1.6%	1,283
	Ash Content	30-40%	33,316

Energy source characteristics remained within the ranges stipulated in the license.

## 2.4 Emissions reporting

### 2.4.1 Particulate Matter Emissions

#### Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of March 2021

#### Interpretation:

All daily averages below particulate emission limit of 50 mg/Nm³.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of March 2021

**Interpretation:**

All daily averages below particulate emission limit of 50 mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of March 2021

**Interpretation:**


All daily averages below particulate emission limit of 50 mg/Nm<sup>3</sup>.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 4 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of March 2021**

**Interpretation:**


Unit 4 exceeded the particulate emission limit of 50 mg/Nm<sup>3</sup> on the 1<sup>st</sup> and 9<sup>th</sup> of March 2021. The exceedances were due to defects on the sulphur plant. The plant was repaired and emissions returned to normal. The exceedances did not exceed the 48-hour grace period.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 5 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of March 2021**

**Interpretation:**

All daily averages below particulate emission limit of 50 mg/Nm<sup>3</sup>.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



### Unit 6 Particulate Emissions

**Interpretation:**

Unit on outage

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.4.2 Gaseous Emissions


Unit 1 SO<sub>2</sub> Emissions

Figure 6: SO<sub>2</sub> daily average emissions against emission limit for unit 1 for the month of March 2021


## Interpretation:

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO<sub>2</sub> Emissions

**Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of March 2021**

**Interpretation:**

Unit 2 experienced increased SO<sub>x</sub> emissions on 5, 9, 12-14 and 30 March 2021. The emissions remained below the monthly limit of 3500mg/Nm<sup>3</sup> with an average of 3359mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Unit 3 SO<sub>2</sub> Emissions

Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of March 2021

**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 SO<sub>2</sub> Emissions

Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 4 for the month of March 2021

#### Interpretation:


All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

Data from the 23<sup>rd</sup> of March 2021 until the 31<sup>st</sup> of March 2021 was removed and averaged data for the month was used due to a defect on the monitor after calibration on the 23<sup>rd</sup> of March 2021. The monitor was repaired on the 31<sup>st</sup> and emission readings returned to normal.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 SO<sub>2</sub> Emissions

**Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of March 2021**

**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

Data from the 23<sup>rd</sup> of March 2021 until the 31<sup>st</sup> of March 2021 was removed and averaged data for the month was used due to a defect on the monitor after calibration on the 23<sup>rd</sup> of March 2021. The monitor was repaired on the 31<sup>st</sup> and emission readings returned to normal.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## Unit 6 SO<sub>2</sub> Emissions

### Interpretation:

Unit on outage

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 1 NO<sub>x</sub> Emissions

Figure 11: NO<sub>x</sub> daily average emissions against emission limit for unit 1 for the month of March 2021

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 NO<sub>x</sub> Emissions

Figure 12: NO<sub>x</sub> daily average emissions against emission limit for unit 2 for the month of March 2021

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 NO<sub>x</sub> Emissions

Figure 13: NO<sub>x</sub> daily average emissions against emission limit for unit 3 for the month of March 2021

**Interpretation:**


All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



Unit 4 NO<sub>x</sub> Emissions

**Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of March 2021**

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

Data from the 23<sup>rd</sup> of March 2021 until the 31<sup>st</sup> of March 2021 was removed and averaged data for the month was used due to a defect on the monitor after calibration on the 23<sup>rd</sup> of March 2021. The monitor was repaired on the 31<sup>st</sup> and emission readings returned to normal.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 5 NO<sub>x</sub> Emissions

Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of March 2021

#### Interpretation:

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

Data from the 23<sup>rd</sup> of March 2021 until the 31<sup>st</sup> of March 2021 was removed and averaged data for the month was used due to a defect on the monitor after calibration on the 23<sup>rd</sup> of March 2021. The monitor was repaired on the 31<sup>st</sup> and emission readings returned to normal.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### Unit 6 NO<sub>x</sub> Emissions

**Interpretation:**

Unit on outage


**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Thursday, 08 April 2021	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <b>blue cells</b> below</p> <p align="center">Choose from a dropdown menu in the <b>green cells</b></p> <p align="center">The total VOC emissions for the month are in the <b>red cells</b></p> <p align="center">IMPORTANT: Do not change <b>any</b> other cells without consulting the AQ CoE</p>		
MONTH:	March	
<b>GENERAL INFORMATION:</b>		
	<b>Data</b>	<b>Unit</b>
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	550,488	tons/month
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
<b>METEROLOGICAL DATA FOR THE MONTH</b>		
	<b>Data</b>	<b>Unit</b>
Daily average ambient temperature	23,67	°C
Daily maximum ambient temperature	30,21	°C
Daily minimum ambient temperature	17,89	°C
Daily ambient temperature range	12,31	°C
Daily total insolation factor	5,08	kWh/m <sup>2</sup> /day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
<b>FINAL OUTPUT:</b>		
	<b>Result</b>	<b>Unit</b>
Breathing losses:	0,55 kg/month	
Working losses:	0,02 kg/month	
<b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>	<b>0,56 kg/month</b>	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Trittech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.4.4 Greenhouse gas (CO<sub>2</sub>) emissions

CO<sub>2</sub> emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, No.R. 994) and are not included in the monthly AEL compliance report.

## 2.5 Daily power generated


**Table 5:** Daily power generated per unit in MWh for the month of March 2021

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2021/03/01	14438,6	14837,9	14910,7	12273	14972,8	0
2021/03/02	14114,2	15055,9	15190,5	10572	15111,5	0
2021/03/03	14333,1	15085,3	15434	13159	15166,8	0
2021/03/04	14748,8	15413,2	15279,6	15536	15759,1	0
2021/03/05	14507,7	15362,9	15889,1	15146	15953,3	0
2021/03/06	14802,9	15396,5	16124,4	14712	13948,8	0
2021/03/07	14920,8	15112,8	15534	14295	14002,4	0
2021/03/08	14824,5	14922,7	15036,3	13656	15640,6	0
2021/03/09	14597,7	15273,9	15621,7	12231	16007,1	0
2021/03/10	14762,9	14904,3	15798,7	13135	15956,1	0
2021/03/11	6518,07	14926,7	15384,2	14598	15205	0
2021/03/12	0	15420,4	16071,6	15557	15932,3	0
2021/03/13	0	15414,1	14856,3	15396	16026,6	0
2021/03/14	10574,1	10316,3	16077,1	15583	15923,3	0
2021/03/15	15049,8	14878,3	14255,3	15647	15856,4	0
2021/03/16	15132,1	14755,6	16209,8	15196	16077,3	0
2021/03/17	15160,3	15072,6	16171	15638	16099,1	0
2021/03/18	15182,8	15358,9	16175,4	15628	15912,7	0
2021/03/19	14923,3	14956,8	13997,5	6898	15718,4	0
2021/03/20	15213,5	15306,3	14995,7	0	16156	0
2021/03/21	14898,8	15395,1	15316,6	5883	16103,8	0
2021/03/22	15018,4	15288,7	12437,5	14170	15975,7	0
2021/03/23	15203,9	15439,1	14852,9	14733	16186,4	0
2021/03/24	15314,6	15400,9	14850,8	14310	16139,3	0
2021/03/25	15298,1	15377,7	14911,5	12346	16111,2	0
2021/03/26	14493,1	15306,8	14933,9	14199	15778,2	0
2021/03/27	14385,7	15250,6	14959,1	14242	15382,3	0
2021/03/28	13866,7	14611,6	13877,7	14140	14215,8	0
2021/03/29	14348,9	15453,8	14961,1	16096	16096,6	0
2021/03/30	15201,7	15454,1	14961,7	16042	16092,5	0
2021/03/31	15157,1	15038,5	14879,7	15168	15410,4	0

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 16: Unit 1 daily generated power in MWh for the month of March 2021**

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 17: Unit 2 daily generated power in MWh for the month of March 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.







Figure 18: Unit 3 daily generated power in MWh for the month of March 2021

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.






**Figure 19: Unit 4 daily generated power in MWh for the month of March 2021**

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 20: Unit 5 daily generated power in MWh for the month of March 2021**

**Note:** Unit 6 is on outage

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.6 Pollutant Tonnages

**Table 6:** Pollutant tonnages for the month of March 2021

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	CO <sub>2</sub> (tons)
Unit 1	38,7	5 488,1	971,5	438 493
Unit 2	44,9	7 447,1	1 011,0	486 454
Unit 3	46,9	7 537,1	1 258,2	441 408
Unit 4	70,5	6 450,9	1 261,0	402 129
Unit 5	50,0	6 308,7	998,4	417 410
Unit 6	0,0	0,0	0,0	0
<b>SUM</b>	251,0	33 232,0	5 500,1	2 185 894

The emitted pollutant tonnages for March 2021 are provided in table 6. Unit 6 was on outage for the whole of March 2021.

## 2.7 Reference values

**Table 7:** Reference values for data provided

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	8,66	7,74	7,34	6,96	7,61	
Moisture	%	5,07	5,42	4,72	3,66	5,73	
Velocity	m/s	30,9	28,3	29,7	25,8	27,2	
Temperature	°C	143,3	131,7	129,9	134,7	128,7	
Pressure	mBar	934,5	900,2	917,9	921,4	933,4	

Table 7 shows the reference values for the emission data provided for the month of March 2021. Unit 6 was on outage for the whole of March 2021.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.8 Continuous Emission Monitors

### 2.8.1 Reliability

**Table 8:** Average percentage (%) availability of monitors for the month of March 2021.

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	CO <sub>2</sub>
Unit 1	100,0	100,0	99,8	100,0
Unit 2	100,0	100,0	100,0	0,0
Unit 3	100,0	100,0	100,0	0,0
Unit 4	100,0	70,4	72,4	99,0
Unit 5	100,0	74,2	74,2	100,0
Unit 6	Outage	Outage	Outage	Outage

SO<sub>x</sub> and NO<sub>x</sub> emission monitors for unit 4 and unit 5 did not achieve 90% reliability as required by the license. Calibrations were done on the gaseous monitors on the 23<sup>rd</sup> of March 2021 and an incorrect setting caused the monitors to give faulty readings. The monitors were repaired on the 31<sup>st</sup> of March 2021.

CO<sub>2</sub> monitors for units 2 and 3 achieved 100% availability however CO<sub>2</sub> data was replaced with Average values from the QAL 2 report due to the raw data being unreliable.

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## **2.8.2 Changes, downtime and repairs**

### **Unit 1**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 2**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 3**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 4**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 5**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 6**

- Unit 6 has been on outage for the whole month of March 2021

## **2.8.3 Sampling dates and times**

Continuous

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.9 Start-up information

**Table 9:** Start-up information

<b>Unit</b>	1	
<b>Fires in</b>	13 March 2021	18h57
<b>Synchronization with Grid</b>	14 March 2021	01h38
<b>Emissions below limit</b>	14 March 2021	09h20
<b>Fires in to synchronization</b>	6,68	HOURS
<b>Synchronization to &lt; Emission limit</b>	7,7	HOURS

<b>Unit</b>	2	
<b>Fires in</b>	14 March 2021	09h49
<b>Synchronization with Grid</b>	14 March 2021	12h08
<b>Emissions below limit</b>	14 March 2021	13h02
<b>Fires in to synchronization</b>	2,32	HOURS
<b>Synchronization to &lt; Emission limit</b>	54	MINUTES

<b>Unit</b>	4	
<b>Fires in</b>	21 March 2021	05h31
<b>Synchronization with Grid</b>	21 March 2021	11h50
<b>Emissions below limit</b>	21 March 2021	15h00
<b>Fires in to synchronization</b>	6,32	HOURS
<b>Synchronization to &lt; Emission limit</b>	3,17	HOURS

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.10 Emergency generation

Table 10: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	510,13	566,01	572,2	522,83	572,2	Unit off
Emergency Hours declared including hours after stand down	516,13	572,02	578,2	528,83	578,2	Unit off
Days over the Limit during Emergency Generation	0	0	0	2	0	Unit off

Unit 4 particulate emissions exceeded the 50mg/Nm<sup>3</sup> emission limit on the 1<sup>st</sup> and 9<sup>th</sup> of March 2021. The exceedances did not exceed the 48-hour grace period. Detailed emission information for unit 4 particulate emissions can be found on figure 4.

## 2.11 Complaints register

Table 11: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

## 2.12 Air quality improvements and social responsibility conducted

### 2.12.1 Air quality improvements

None

### 2.12.2 Social responsibility conducted

None

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.13 Ambient air quality monitoring

Four exceedances of the SO<sub>2</sub> 10-minute limit, two exceedances of the SO<sub>2</sub> hourly limit, two exceedances of the PM<sub>2.5</sub> daily limit and one exceedance of the PM<sub>10</sub> daily limit was noted. No other parameters exceeded the set limits during the monitoring period.

Ambient CO, PM<sub>10</sub> and NO<sub>2</sub> concentrations at Marapong monitoring site show influence of emissions from low-level sources in the area while ambient SO<sub>2</sub>, and PM<sub>2.5</sub> concentrations show influence of emissions from low level sources, tall stack emitters and other industrial activities.

The average data recovery for the period was 87,6% and the station availability was 90,2%.

Detailed results can be found in Attachment 1, "Marapong monthly Report\_March 2021".

## 2.14 Electrostatic precipitator and Sulphur plant status

### Unit 1

- All precipitator fields in service.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 2

- All precipitator fields in service.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 3

- 2 out of 32 precipitator fields is out of service. Repairs will be done during the next opportunity outage.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 4

- All precipitator fields in service.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 5

- All precipitator fields in service.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 6

- Unit 6 has been on outage for the whole month of March 2021

### SO<sub>3</sub> common plant

- No abnormalities on the sulphur storage plant.

CONTROLLED,

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.15 General

Name and reference number of the monitoring method used:

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues

## 3. Attachments

None

## 4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

**CONTROLLED,**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.