



Mrs Mpho Nembilwi
Nkangala District
P O Box 437
MIDDLEBERG
1050
By email nembilwim@nkangaladm.gov.za'

Date
27 October 2021

Enquiries S Chokoe
Tel +27 13 647 6970

Dear Mrs Mpho Nembilwi

Ref Kendal Power Station AEL (17/4/AEL/MP312/11/15)

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF SEPTEMBER 2021.

This is a monthly report required in terms of Section 7.4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Compiled by:

Tshildzi Vilane
ENVIRONMENTAL OFFICER- KENDAL

Date: 27/10/2021

Supported by:

Solly Chokoe
ENVIRONMENTAL MANAGER- KENDAL

Date: 28/10/2021

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTHS OF SEPTEMBER 2021.


Verified by:



Fulufhelo Nganke
BOILER ENGINEERING: SYSTEM ENGINEER- KENDAL

Date: 27/10/2021


Validated by:



Tendani Rasivhetshele
ACTING BOILER ENGINEERING MANAGER-KENDAL

Date 28/10/2021

Supported by:



Malibongwe Mabizela
ENGINEERING MANAGER-KENDAL

Date 29-10-2021.

Approved by:



Lukhanya Ncube
GENERAL MANAGER-KENDAL

Date 08-11-21

KENDAL POWER STATION MONTHLY EMISSIONS REPORT
 Atmospheric Emission License 17/4/AEL/MP312/11/15



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Sep-2021
	Coal	Tons	2 260 000	802 869
Fuel Oil	Tons	5 000	3500.98	

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Sep-2021
	Energy	GWh(MW)	4380	1 539 056.00
	Ash	Tons	770 000	265 348.2
	RE Ash	kg/MWh	not specified	

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	<1 (%)	1.550
Ash Content	%	40 (%)	33.050

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO _x	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMET TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Sep-2021	Technology Type	Utilization Sep-2021
Unit 1	ESP + SO ₁	99.9%	SO ₁	100.0%
Unit 2	ESP + SO ₁	99.9%	SO ₁	99.5%
Unit 3	ESP + SO ₁	99.6%	SO ₁	95.2%
Unit 4	ESP + SO ₁	99.6%	SO ₁	98.5%
Unit 5	ESP + SO ₁	99.2%	SO ₁	0.0%
Unit 6	ESP + SO ₁	Off-line	SO ₁	Off-line

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

Unit 5 unavailability of sulphur utilization readings can be attributed to the server and P1 historian which is still under commission

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	100.0	99.6	95.1	100.0
Unit 2	99.5	100.0	99.9	100.0
Unit 3	99.8	100.0	91.7	99.5
Unit 4	99.6	100.0	97.2	97.1
Unit 5	98.0	100.0	99.3	99.5
Unit 6	Off-line	Off-line	Off-line	Off-line

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of September 2021

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)	CO ₂
Unit 1	8.3	856	232	60148.85
Unit 2	51.5	2 621	983	200138
Unit 3	98.5	2 606	676	221000.7
Unit 4	195.6	2 444	926	171546.2
Unit 5	481.1	2 347	743	236560.1
Unit 6	Off-line	Off-line	Off-line	Off-line
SUM	835.17	10 874	3 560	889 394

Table 6.2: Operating days in compliance to PM AEL Limit - September 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contraven-tion	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	6	0	0	0	0	21.6
Unit 2	25	2	0	0	2	48.6
Unit 3	22	3	0	3	6	65.5
Unit 4	11	6	0	8	16	146.1
Unit 5	6	7	9	7	0	259.8
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	72	20	9	18	24	

Table 6.3: Operating days in compliance to SO_x AEL Limit - September 2021



Associated Unit/Stack	Normal	Grace	Section 30	Contraven-tion	Total Exceedance	Average SO _x (mg/Nm ³)
Unit 1	6	0	0	0	0	2 920.7
Unit 2	26	0	0	0	0	2 267.7
Unit 3	25	0	0	0	0	2 009.6
Unit 4	26	0	0	0	0	2 064.9
Unit 5	30	0	0	0	0	2 085.3
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	124	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - September 2021


Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm³)
Unit 1	6	0	0	1	1	861.9
Unit 2	26	0	0	0	0	839.8
Unit 3	29	0	0	0	0	511.7
Unit 4	26	0	0	0	0	768.4
Unit 5	30	0	0	0	0	661.6
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	123	0	0	1	1	

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contra-vention	Red	Emissions above ELV but outside grace or S30 incident conditions




The high emissions can be attributed to left hand draught group tripping, S03 plant trip and precp chain conveyor 12 kept on tripping.




High PM emissions can be attributed to SO3 plant tripping on burner outlet temperature high and Dust Handling Plant tripped due to compartment levels false high alarm

The high PM emissions can be attributed to 4 precip fields that kept on tripping on CE rapper fault & UV, Dust Handling Plant tripping due to high compartment level, SO3 plant tripping on burner outlet temperature high, precip conveyors 23 to 24 tripping.



High PM emissions can be attributed to light up conditions

High PM emissions can be attributed to ash backlogs as a result of tripped DHP due to full compartment levels, DHP off due to both streams not in service, precip conveyor 12&13 tripping, knife gates checked in, streams tripping, SO3 plant on hold mode due to sulphur flow low,



High PM emissions can be attributed to Electrostatic precipitators fields tripping due to wires breakages and fields misalignment, SCADA challenges and delayed fields optimisation as well as ash backlogs due to unavailability of the Dust handling plant





Figure 7: Kendal Unit 1 SOx Emissions - September 2021



Unit 1 SOx emissions on the 02nd an average was taken because the values from the monitor were frozen

Figure 8: Kendal Unit 2 SOx Emissions - September 2021














Figure 9: Kendal Unit 3 SOx Emissions - September 2021





Unit 1 NOx emissions exceedance investigation still in progress



7 COMPLAINTS

There were no complaints for this month

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

ADDENDUM TO MONTHLY EMISSIONS REPORT

Abatement Technology Table 4

In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as

- ☑ Coal ash content (%) and burnt rate mass
- ☑ Fly Coarse ash ratio of 80/20 80% of fly ash mass obtained from burnt coal goes to ESP
- ☑ Measurement of dust emission by Dust Monitor over a period of time (monthly)

Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \frac{(\text{Dust Emission from AQR Report Dust Monitor (tons)} \times 100)}{(\text{Coal Burnt (tons)} \times \% \text{Ash Content} \times 80\%)}$$

Monitor Reliability Table 5

In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average

The monitor reliability refers to data reliability because the assumed value of 98% reliability is compared to the dust concentration signal. If the dust concentration signal is above 98% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g. 24 hours.

The formula is as follows

$$= (1 - (\text{count hours above 98\%/24hours})) \times 100$$

Emissions Performance

- ✓ Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2, 3, 4 & 5 due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- ✓ Average emissions for Unit 2 & Unit 3 pressure was used from the QAL2 parallel report due to defective analysers
- ✓ Unit 6 was still offload during this month for repairs to address emissions issues

Unit 2

Findings The high emissions can be attributed to left hand draught group tripping, SO3 plant trip and precip chain conveyor 12 kept on tripping

Resolution SO3 plant was restored back to service

Unit 3

Findings High PM emissions can be attributed to SO3 plant tripping on burner outlet temperature high and Dust Handling Plant tripped due to compartment levels false high alarm. Four precip fields that kept on tripping on CE rapper fault & UV, Dust Handling Plant tripping due to high compartment level, SO3 plant tripping on burner outlet temperature high, precip conveyors 21 to 24 tripping

Resolution The plant was repaired

Unit 4

Findings High PM emissions can be attributed to ash backlogs as a result of tripped DHP due to full compartment levels, DHP off due to both streams not in service, precip conveyor 12&13 tripping, knife gates checked in, streams tripping, SO3 plant on hold mode due to sulphur flow low

Resolution The plant was repaired

Unit 5

Findings High PM emissions can be attributed to Electrostatic precipitators fields tripping due to wires breakages and fields misalignment, SCADA challenges and delayed fields optimisation as well as ash backlogs due to Unavailability of the Dust handling plant