



Mrs Mpho Nembilwi
Nkangala District
P O Box 437
MIDDLEBERG
1050
By email nembilwim@nkangaladm.gov.za'

Date
29 September 2021

Enquiries S Chokoe
Tel +27 13 647 6970

Dear Mrs Mpho Nembilwi

Ref Kendal Power Station AEL (17/4/AEL/MP312/11/15)

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF AUGUST 2021.

This is a monthly report required in terms of Section 7 4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Compiled by:

Tshilidzi Vilane
ENVIRONMENTAL OFFICER- KENDAL

Date: 29/09/2021

Supported by:

Solly Chokoe
ACTING ENVIRONMENTAL MANAGER- KENDAL

Date: 30/09/2021

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTHS OF AUGUST 2021.


Verified by:



Fulufhelo Nganke
BOILER ENGINEERING: SYSTEM ENGINEER- KENDAL

Date: 29/09/2021

Validated by:



Tendani Rasivhetshela
ACTING BOILER ENGINEERING MANAGER-KENDAL

Date 30/09/2021

Supported by:



Malibongwe Mabizela
ACTING ENGINEERING MANAGER-KENDAL

Date 30/09/2021

Approved by:



Yangaphe Ngcashu
GENERAL MANAGER-KENDAL

Date 30/09/2021

KENDAL POWER STATION MONTHLY EMISSIONS REPORT
 Atmospheric Emission License 17/4/AEL/MP312/11/15



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Aug-2021
	Coal	Tons	2 260 000	966 888
Fuel Oil	Tons	5 000	2465.04	

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Aug-2021
	Energy	GWh(MW)	4380	1 539 056.00
	Ash	Tons	770 000	313 658.5
RE Ash	kg/MWh	not specified	0.560	

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	<1 (%)	0.960
Ash Content	%	40 (%)	32.440

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO _x	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMET TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Aug-2021	Technology Type	Utilization Aug-2021
Unit 1	ESP + SO ₂	99.9%	SO ₂	87.5%
Unit 2	ESP + SO ₂	99.9%	SO ₂	97.7%
Unit 3	ESP + SO ₂	99.7%	SO ₂	46.0%
Unit 4	ESP + SO ₂	99.8%	SO ₂	94.8%
Unit 6	ESP + SO ₂	Off-line	SO ₂	Off-line

Unit 3 low sulphur utilisation can be attributed to SO₃ plant that was tripping because of high burner outlet temperatures that went above 730 degree celcius because of high ESP inlet temperature operating at 135 degree celcius

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

Note: Unit 5 PM and gaseous emissions are not included in the report because Unit 5 was still under commission and correlations and parallel tests were still being done. Parallel tests were completed on the 11 September 2021 and correlations were completed on 23 September 2021. Awaiting results for both tests.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	100.0	100.0	100.0	100.0
Unit 2	100.0	100.0	98.6	100.0
Unit 3	99.7	100.0	100.0	100.0
Unit 4	100.0	100.0	99.9	99.7
Unit 5	63.6	28.8	28.8	86.7
Unit 6	Off-line	Off-line	Off-line	Off-line

Note: Monitor reliability for unit 5 was low due to defective monitors

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of August 2021

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	38.4	4 455	1 295
Unit 2	61.1	3 333	1 230
Unit 3	162.6	3 686	1 119
Unit 4	79.7	2 797	1 006
Unit 6	Off-line	Off-line	Off-line
SUM	341.72	14 271	4 651

Table 6.2: Operating days in compliance to PM AEL Limit - August 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	31	0	0	0	0	19.0
Unit 2	27	2	0	0	2	55.3
Unit 3	17	7	0	7	14	104.6
Unit 4	25	3	0	0	3	52.0
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	100	12	0	7	19	

Table 6.3: Operating days in compliance to SO_x AEL Limit - August 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average SO _x (mg/Nm ³)
Unit 1	30	0	0	1	1	2 838.9
Unit 2	31	0	0	0	0	2 299.6
Unit 3	31	0	0	0	0	1 985.0
Unit 4	29	0	0	0	0	2 038.5
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	121	0	0	1	1	

Table 6.4: Operating days in compliance to NOx AEL Limit - August 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm ³)
Unit 1	31	0	0	0	0	832.2
Unit 2	31	0	0	0	0	830.8
Unit 3	31	0	0	0	0	600.1
Unit 4	29	0	0	0	0	736.8
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	122	0	0	0	0	

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contra-vention	Red	Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Kendal Unit 1 PM Emissions - August 2021






Figure 2: Kendal Unit 2 PM Emissions - August 2021






The high PM emissions can be attributed to Dust Handling Plant unavailability (Vacuum very low, precip conveyors choking, high compartment levels)

High PM emissions can be attributed to precip conveyor 12, 13, 14 & 22 that tripped, DHP tripped due to full compartment 30, High ash backlogs.

The high PM emissions can be attributed to precip conveyor 12, 13 and 22 that tripped, DHP tripped due full bunkers. SO3 plant was tripping because of outlet temperatures that went above 730 degree celsius, the root cause was ESP inlet temperatures were too high operating above 135 degree celsius



High PM emissions can be attributed to precip conveyors 22 out of service, SO3 plant tripping.

High PM emissions can be attributed to SO3 plant trip, SO3 plant on hold mode due to burner temp low





Figure 7: Kendal Unit 1 SOx Emissions - August 2021



Unit 1 high SOx emissions can be attributed to high coal sulphur content

Figure 8: Kendal Unit 2 SOx Emissions - August 2021





Figure 9: Kendal Unit 3 SOx Emissions - August 2021








Figure 14: Kendal Unit 2 NOx Emissions - August 2021




Figure 15: Kendal Unit 3 NOx Emissions - August 2021




Figure 16: Kendal Unit 4 NOx Emissions - August 2021





Figure 17: Kendal Unit 6 NOx Emissions - August 2021



7 COMPLAINTS

There were no complaints for this months

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

ADDENDUM TO MONTHLY EMISSIONS REPORT

Abatement Technology-Table 4

In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as

- ☑ Coal ash content (%) and burnt rate mass
- ☑ Fly Coarse ash ratio of 80-20 - 80% of fly-ash mass obtained from burnt coal goes to ESP
- ☑ Measurement of dust emission by Dust Monitor over a period of time (monthly)

Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \frac{(\text{Dust Emission From AQR Report} / \text{Dust Monitor (tons)})}{(\text{Coal Burnt (tons)} \times \% \text{Ash Content} \times 80\%)} \times 100$$

Monitor Reliability Table 5

In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average. The monitor reliability refers to data reliability because the assumed value of 98% reliability is compared to the dust concentration signal. If the dust concentration signal is above 98% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g. 24 hours.

The formula is as follows:

$$= (1 - (\text{count hours above 98\%}/24\text{hours})) \times 100$$

Emissions Performance

- Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2, 3, 4 due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- Average emissions for Unit 1 & Unit 3 pressure was used from the QAL2 parallel report due to defective analysers
- Unit 1 high SOx emissions can be attributed to high coal sulphur content
- Unit 6 was still offload during this month for repairs to address emissions issues

Unit 2

Findings: The high emissions can be attributed to SO3 plant air heater tripping and unit trip on the
Resolution: SO3 plant was restored back to service

Unit 3

Findings: The high PM emissions can be attributed to Dust Handling Plant (DHP) i.e. unavailability (Vacuum very low, precip conveyors choking, high compartment levels.)
Resolution: The DHP was returned back to service after repairs

Unit 4

Findings: High PM emissions can be attributed to precip conveyor 22 out of service, SO3 plant tripping
Resolution: The plant was repaired

Unit 5

Note: Unit 5 PM and gaseous emissions are not included in the report because Unit 5 was still under commission and correlations and parallel tests were still being done. Parallel tests were completed on the 11 September 2021 and correlations were completed on 23 September 2021. Awaiting results for both tests. Once the test results are received and implemented, the reports will be resubmitted with unit 5 emissions.