	<b>Matimba Power Station Emissions report</b>	<b>Matimba Power Station</b>
---	---	------------------------------

Title: **Matimba Power Station October 2021 emissions report**

Document Identifier: **RP/247/014**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **41**

Report Date: **October 2021**

Disclosure Classification: **Controlled**

---

**Compiled by**

**Functional Responsibility**

**Authorized by**





**WC Mocke**  
**Environmental Officer**

**MC Mamabolo**  
**Environmental Manager**

**JL Janse van Rensburg**  
**General Manager**

Date: 2021/12/09

Date: 15/12/2021

Date: 2021-12-15

## Content

	Page
1. Report Summary .....	4
2. Emission information .....	5
2.1 Raw materials and products.....	5
2.2 Abatement technology.....	5
2.3 Energy source characteristics .....	6
2.4 Emissions reporting.....	6
2.4.1 Particulate Matter Emissions .....	6
2.4.2 Gaseous Emissions .....	12
2.4.3 Total Volatile Organic Compounds .....	24
2.4.4 Greenhouse gas (CO <sub>2</sub> ) emissions .....	25
2.5 Daily power generated .....	25
2.6 Pollutant Tonnages .....	32
2.7 Reference values .....	32
2.8 Continuous Emission Monitors.....	33
2.8.1 Reliability.....	33
2.8.2 Changes, downtime and repairs .....	34
2.8.3 Sampling dates and times.....	34
2.9 Units Start-up information .....	35
2.10 Emergency generation .....	38
2.11 Complaints register .....	38
2.12 Air quality improvements and social responsibility conducted .....	38
2.12.1 Air quality improvements.....	38
2.12.2 Social responsibility conducted.....	38
2.13 Ambient air quality monitoring.....	39
2.14 Electrostatic precipitator and Sulphur plant status .....	40
2.15 General.....	41
3. Attachments.....	41
4. Report Conclusion .....	41
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	5
Table 2: Abatement Equipment Control Technology Utilised.....	5
Table 3: Energy Source Material Characteristics. ....	6
Table 4: Total volatile compound estimates .....	24
Table 5: Daily power generated per unit in MWh for the month of October 2021 .....	25
Table 6: Pollutant tonnages for the month of October 2021.....	32
Table 7: Reference values for data provided, October 2021.....	32
Table 8: Average percentage (%) availability of monitors for the month of October 2021.....	33
Table 9: Start-up information .....	35

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Emergency generation .....	38
Table 11: Complaints.....	38

## Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 2 for the month of October 2021 .....	7
Figure 2: Particulate matter daily average emissions against emission limit for unit 3 for the month of October 2021 .....	8
Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of October 2021 .....	9
Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of October 2021 .....	10
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of October 2021 .....	11
Figure 6: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of October 2021 .....	13
Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of October 2021 .....	14
Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 4 for the month of October 2021 .....	15
Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 5 for the month of October 2021 .....	16
Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 6 for the month of October 2021 .....	17
Figure 11: NO <sub>x</sub> daily average emissions against emission limit for unit 2 for the month of October 2021 .....	19
Figure 12: NO <sub>x</sub> daily average emissions against emission limit for unit 3 for the month of October 2021 .....	20
Figure 13: NO <sub>x</sub> daily average emissions against emission limit for unit 4 for the month of October 2021 .....	21
Figure 14: NO <sub>x</sub> daily average emissions against emission limit for unit 5 for the month of October 2021 .....	22
Figure 15: NO <sub>x</sub> daily average emissions against emission limit for unit 6 for the month of October 2021 .....	23
Figure 16: Unit 1 daily generated power in MWh for the month of October 2021 .....	26
Figure 17: Unit 2 daily generated power in MWh for the month of October 2021 .....	27
Figure 18: Unit 3 daily generated power in MWh for the month of October 2021 .....	28
Figure 19: Unit 4 daily generated power in MWh for the month of October 2021 .....	29
Figure 20: Unit 5 daily generated power in MWh for the month of October 2021 .....	30
Figure 21: Unit 6 daily generated power in MWh for the month of October 2021 .....	31

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (12/4/12L-W4/A4) in March 2020. Condition 7.7.1 of the License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in condition 7.7.1 for October 2021.



During the period under review, Matimba experienced 22 exceedances of the daily particulate matter emission limit ( $50\text{mg}/\text{Nm}^3$ ) all these exceedances remained within the 48 hour grace period. No exceedances of the monthly  $\text{SO}_x$  limit ( $3500\text{mg}/\text{Nm}^3$ ) or the daily  $\text{NO}_x$  limit ( $750\text{ mg}/\text{Nm}^3$ ) occurred.

Issues mentioned above are discussed further under the respective sections within the report.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2. Emission information

### 2.1 Raw materials and products

**Table 1:** Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	972 196
	Fuel Oil	Tons/month	1 200	1165,837
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	GWh	4 212.6	1 765,934

The coal and fuel oil consumptions rates for the month of October 2021 were within the permitted maximum limit. An increased amount of fuel oil was used due to multiple unit trips and start-ups.

### 2.2 Abatement technology

**Table 2:** Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	Unit on Outage
Unit 2	Electrostatic Precipitator	100%	99,87%
Unit 3	Electrostatic Precipitator	100%	99,87%
Unit 4	Electrostatic Precipitator	100%	99,88%
Unit 5	Electrostatic Precipitator	100%	99,91%
Unit 6	Electrostatic Precipitator	100%	99,87%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO <sub>3</sub> Plant	100%	Unit on Outage
Unit 2	SO <sub>3</sub> Plant	100%	93,55%
Unit 3	SO <sub>3</sub> Plant	100%	100%
Unit 4	SO <sub>3</sub> Plant	100%	100%
Unit 5	SO <sub>3</sub> Plant	100%	100%
Unit 6	SO <sub>3</sub> Plant	100%	93,55%

Fluegas conditioning plant availability was below the required 100% for unit 2 and unit 6 due to unexpected breakdowns.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.3 Energy source characteristics

**Table 3:** Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	0.8-1.6%	1,22%
	Ash Content	30-40%	34,813%

Energy source characteristics remained within the ranges stipulated in the license.

## 2.4 Emissions reporting

### 2.4.1 Particulate Matter Emissions

#### Unit 1 Particulate Emissions

##### Interpretation:


Unit 1 was on outage for the whole duration of October 2021.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 2 Particulate Emissions



**Figure 1: Particulate matter daily average emissions against emission limit for unit 2 for the month of October 2021**

#### Interpretation:


Unit 2 exceeded the 50mg/Nm<sup>3</sup> emission limit on 6, 7, 9, 10, 29 and 30 October 2021. The exceedances that occurred from 6-10 October 2021 were due to unexpected failures that occurred on the dust handling plant. The exceedances that occurred on 29 and 30 October 2021 was due to maintenance activities that occurred within the dust handling plant. These breakdowns and maintenance activities caused ash build-up in the flue gas cleaning system. This reduced the efficiency of the particulate matter abatement technology. The plant was repaired and emissions returned to below the limit. All exceedances remained within the 48 hour grace period.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 3 Particulate Emissions



**Figure 2: Particulate matter daily average emissions against emission limit for unit 3 for the month of October 2021**

**Interpretation:**

Unit 3 exceeded the daily limit of 50mg/Nm<sup>3</sup> on 6, 9 and 16 October 2021. The exceedances were due to damage that was incurred on the precipitator plant from increased ash in the flue gas cleaning system. The ash build-up was due to unplanned breakdowns on the dust handling and ash conveyancing plants. The unit was shut down on 27 November 2021 in order to do necessary repairs on the precipitator plant. The exceedances did not exceed the 48 hour grace period.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## Unit 4 Particulate Emissions



**Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of October 2021**

#### Interpretation:


Unit 4 exceeded the daily limit of 50mg/Nm<sup>3</sup> on 10, 16, 20 and 21 October 2021. The exceedances were due to unexpected failures that occurred on the dust handling plant which caused ash build-up in the flue gas cleaning system. This reduced the efficiency of the particulate matter abatement technology. The plant was repaired and emissions returned to below the limit. All exceedances remained within the 48 hour grace period.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 5 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of October 2021**

#### Interpretation:


Unit 5 exceeded the daily limit of 50mg/Nm<sup>3</sup> on 9 and 10 October 2021. The exceedances were due to unexpected failures that occurred on the dust handling plant which caused ash build-up in the flue gas cleaning system. This reduced the efficiency of the particulate matter abatement technology. The plant was repaired and emissions returned to below the limit. All exceedances remained within the 48 hour grace period.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 6 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of October 2021**

#### Interpretation:

Unit 6 exceeded the daily limit of 50mg/Nm<sup>3</sup> on 2, 3, 5, 9, 10, 14 and 25 October 2021. The exceedances that occurred on 2, 3, 5, and 25 October 2021 were due to unexpected failures that occurred on the dust handling plant which caused ash build-up in the flue gas cleaning system. The exceedances that occurred on 9, 10, and 14 October 2021 were due to breakdowns that occurred on the Sulphur plant. This reduced the efficiency of the particulate matter abatement technology. The plant was repaired and emissions returned to below the limit. All exceedances remained within the 48 hour grace period.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## **2.4.2 Gaseous Emissions**

### **Unit 1 SO<sub>2</sub> Emissions**


#### **Interpretation:**

Unit 1 was on outage for the whole duration of October 2021.

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 2 SO<sub>2</sub> Emissions**

**Figure 6: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of October 2021**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 SO<sub>2</sub> Emissions

**Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of October 2021**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 4 SO<sub>2</sub> Emissions**

**Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 4 for the month of October 2021**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 SO<sub>2</sub> Emissions

**Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of October 2021**

**Interpretation:**


All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Unit 6 SO<sub>2</sub> Emissions**

**Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 6 for the month of October 2021**

**Interpretation:**

All daily averages remained below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 1 NO<sub>x</sub> Emissions**


**Interpretation:**

Unit 1 was on outage for the whole duration of October 2021.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO<sub>x</sub> Emissions

**Figure 11: NO<sub>x</sub> daily average emissions against emission limit for unit 2 for the month of October 2021**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 NO<sub>x</sub> Emissions

**Figure 12: NO<sub>x</sub> daily average emissions against emission limit for unit 3 for the month of October 2021**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 NO<sub>x</sub> Emissions

**Figure 13: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of October 2021**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO<sub>x</sub> Emissions

**Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of October 2021**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 6 NO<sub>x</sub> Emissions**

**Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 6 for the month of October 2021**

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
<b>CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*</b>		
<b>Date:</b>	Monday, 29 November 2021	
<b>Station:</b>	Matimba Power Station	
<b>Province:</b>	Limpopo Province	
<b>Tank no.</b>	1-4	
<b>Description:</b>	Outdoor fuel oil storage tank	
<b>Tank Type:</b>	Vertical fixed roof (vented to atmosphere)	
<b>Material stored:</b>	Fuel Oil 150	
<p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <u>blue cells</u> below</p> <p align="center">Choose from a dropdown menu in the <u>green cells</u></p> <p align="center">The total VOC emissions for the month are in the <u>red cells</u></p> <p align="center">IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE</p>		
<b>MONTH:</b>	October	
<b>GENERAL INFORMATION:</b>	<b>Data</b>	<b>Unit</b>
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	1165,837	
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
<b>METEOROLOGICAL DATA FOR THE MONTH</b>	<b>Data</b>	<b>Unit</b>
Daily average ambient temperature	26,19	°C
Daily maximum ambient temperature	33,65	°C
Daily minimum ambient temperature	19,11	°C
Daily ambient temperature range	14,54	°C
Daily total insolation factor	5,81	kWh/m²/day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
<b>FINAL OUTPUT:</b>	<b>Result</b>	<b>Unit</b>
Breathing losses:	0,60 kg/month	
Working losses:	0,03 kg/month	
<b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>	<b>0,63 kg/month</b>	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



#### 2.4.4 Greenhouse gas (CO<sub>2</sub>) emissions

CO<sub>2</sub> emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

### 2.5 Daily power generated


**Table 5:** Daily power generated per unit in MWh for the month of October 2021

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2021/10/01	0	14442	12178	14561	12381	14716
2021/10/02	0	12705	11897	13455	11755	13101
2021/10/03	0	12386	11662	13385	8135	12316
2021/10/04	0	14774	11311	14302	11890	11152
2021/10/05	0	14525	11276	14484	15064	14255
2021/10/06	0	13728	11307	14499	14615	14443
2021/10/07	0	12085	11390	14563	14189	14954
2021/10/08	0	11291	11392	14192	13686	14331
2021/10/09	0	9650	11258	12608	11773	12607
2021/10/10	0	12267	11153	14117	12672	12953
2021/10/11	0	13607	11282	14810	14404	13002
2021/10/12	0	12950	10874	14404	14289	14750
2021/10/13	0	12713	11158	13131	12687	13372
2021/10/14	0	11789	11121	12433	11666	12901
2021/10/15	0	11217	11016	12274	10750	13279
2021/10/16	0	10446	10973	2364	0	12993
2021/10/17	0	11213	11029	8748	7537	12808
2021/10/18	0	14338	11122	14366	12931	15102
2021/10/19	0	14954	11121	15297	15260	15320
2021/10/20	0	15025	10965	14343	15081	13906
2021/10/21	0	14396	10900	11881	14305	14239
2021/10/22	0	12578	10901	11019	12029	13384
2021/10/23	0	10583	10625	9393	10238	11953
2021/10/24	0	11183	10432	10102	11074	12625
2021/10/25	0	14799	10430	12634	10074	14320
2021/10/26	0	14184	10748	11956	12556	14154
2021/10/27	0	14137	10962	11247	13375	14547
2021/10/28	0	13936	11271	11922	13424	14321
2021/10/29	0	12883	11398	11302	12500	14155
2021/10/30	0	12161	11193	11816	10890	12942
2021/10/31	0	12732	11229	12013	11798	13705

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 16: Unit 1 daily generated power in MWh for the month of October 2021**

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 17: Unit 2 daily generated power in MWh for the month of October 2021**

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 18: Unit 3 daily generated power in MWh for the month of October 2021**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 19: Unit 4 daily generated power in MWh for the month of October 2021**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 20: Unit 5 daily generated power in MWh for the month of October 2021**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 21: Unit 6 daily generated power in MWh for the month of October 2021**

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.6 Pollutant Tonnages

The emitted pollutant tonnages for October 2021 are provided in table 6. Averaged Quality Assurance level 2 (QAL 2) values were used for unit 2 CO<sub>2</sub> data, CO<sub>2</sub> data for unit 3 and unit 5 was calculated by balance with oxygen readings and averaged values for CO<sub>2</sub> was used in particular days for unit 4 (9 October 2021, 14 to 17 October 2021 and 21 to 31 October 2021) and unit 6 (4 October 2021, 10 October 2021, 14 to 16 October 2021 and 29 to 31 October 2021). These averages and calculated values were used due to the data received from the monitor being unreliable and not a true reflection of the emissions within the specified times.

**Table 6:** Pollutant tonnages for the month of October 2021

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	CO <sub>2</sub> (tons)
Unit 1	0,0	0,0	0,0	0
Unit 2	80,1	5 681,1	904,5	567 610
Unit 3	71,6	4 991,0	971,0	418 923
Unit 4	72,7	4 578,4	1 189,2	356 989
Unit 5	51,2	3 071,5	615,2	417 841
Unit 6	90,6	4 698,2	912,6	423 527
<b>SUM</b>	366,2	23 020,2	4 592,5	2 184 890

## 2.7 Reference values

**Table 7:** Reference values for data provided, October 2021

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%		6,77	8,10	8,02	7,55	7,56
Moisture	%		3,80	4,30	3,20	4,52	3,40
Velocity	m/s		26,3	24,8	25,0	24,0	27,3
Temperature	°C		130,3	135,1	135,2	122,5	173,5
Pressure	mBar		1 114,3	917,7	919,8	931,3	920,8

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.8 Continuous Emission Monitors

### 2.8.1 Reliability

CO<sub>2</sub> monitor reliability for units 1, 2, 3, 4, 5 and 6 performed below the required 80% reliability as per the AEL. The monitors were 100% available for October 2021 however the data received were removed and replaced with calculated values and averaged values due to values received from the monitors not being reliable.

Averaged Quality Assurance level 2 (QAL 2) values were used for unit 2 CO<sub>2</sub> data, CO<sub>2</sub> data for unit 3 and unit 5 was calculated by balance with oxygen readings and averaged values for CO<sub>2</sub> was used in particular days for unit 4 (9 October 2021, 14 to 17 October 2021 and 21 to 31 October 2021) and unit 6 (4 October 2021, 10 October 2021, 14 to 16 October 2021 and 29 to 31 October 2021).

**Table 8:** Average percentage (%) availability of monitors for the month of October 2021.

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	CO <sub>2</sub>
Unit 1				
Unit 2	100,0	95,8	89,9	0,0
Unit 3	100,0	99,7	99,7	0,0
Unit 4	99,9	100,0	100,0	48,4
Unit 5	96,4	100,0	100,0	0,0
Unit 6	100,0	100,0	100,0	74,2

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## **2.8.2 Changes, downtime and repairs**

### **Unit 1**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 2**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 3**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 4**

- Unit 4 gaseous emission monitor was repaired on 21 October 2021.
- No downtime or repairs done on the particulate monitors

### **Unit 5**

- Unit 5 gaseous emission monitor was repaired on 21 October 2021.
- No downtime or repairs done on the particulate monitors

### **Unit 6**

- Unit 6 gaseous emission monitor was repaired on 21 October 2021.
- No downtime or repairs done on the particulate monitors

## **2.8.3 Sampling dates and times**

Continuous

### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.9 Units Start-up information

**Table 9:** Start-up information

<b>Unit</b>	4	
<b>Fires in</b>	16-10-2021	05h00
<b>Synchronization with Grid</b>	16-10-2021	22h29
<b>Emissions below limit</b>	17-10-2021	07h01
<b>Fires in to synchronization</b>	17,48	HOURS
<b>Synchronization to &lt; Emission limit</b>	8,53	HOURS

<b>Unit</b>	4	
<b>Fires in</b>	17-10-2021	00h17
<b>Synchronization with Grid</b>	17-10-2021	04h29
<b>Emissions below limit</b>	17-10-2021	07h01
<b>Fires in to synchronization</b>	4,2	HOURS
<b>Synchronization to &lt; Emission limit</b>	2,53	HOURS

<b>Unit</b>	4	
<b>Fires in</b>	21-10-2021	14h38
<b>Synchronization with Grid</b>	21-10-2021	16h02
<b>Emissions below limit</b>	21-10-2021	16h46
<b>Fires in to synchronization</b>	1,4	HOURS
<b>Synchronization to &lt; Emission limit</b>	0,73	HOURS

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	5	
<b>Fires in</b>	03-10-2021	16h14
<b>Synchronization with Grid</b>	03-10-2021	17h44
<b>Emissions below limit</b>	03-10-2021	17h44
<b>Fires in to synchronization</b>	1,5	HOURS
<b>Synchronization to &lt; Emission limit</b>	0	HOURS

<b>Unit</b>	5	
<b>Fires in</b>	03-10-2021	20h25
<b>Synchronization with Grid</b>	03-10-2021	23h55
<b>Emissions below limit</b>	04-10-2021	03h03
<b>Fires in to synchronization</b>	3,5	HOURS
<b>Synchronization to &lt; Emission limit</b>	3,13	HOURS

<b>Unit</b>	5	
<b>Fires in</b>	17-10-2021	01h48
<b>Synchronization with Grid</b>	17-10-2021	05h44
<b>Emissions below limit</b>	17-10-2021	08h44
<b>Fires in to synchronization</b>	3,93	HOURS
<b>Synchronization to &lt; Emission limit</b>	3	HOURS

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	5	
<b>Fires in</b>	25-10-2021	21h36
<b>Synchronization with Grid</b>	26-10-2021	00h40
<b>Emissions below limit</b>	26-10-2021	08h02
<b>Fires in to synchronization</b>	3,07	HOURS
<b>Synchronization to &lt; Emission limit</b>	7,37	HOURS

<b>Unit</b>	6	
<b>Fires in</b>	13-10-2021	16h34
<b>Synchronization with Grid</b>	13-10-2021	17h38
<b>Emissions below limit</b>	13-10-2021	17h38
<b>Fires in to synchronization</b>	1,07	HOURS
<b>Synchronization to &lt; Emission limit</b>	0	HOURS

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.10 Emergency generation

**Table 10:** Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
<b>Emergency Generation hours declared by national Control</b>	0	382	382	382	382	382
<b>Emergency Hours declared including hours after stand down</b>	0	389	389	389	389	389
<b>Days over the Limit during Emergency Generation</b>	0	0	0	2	0	1

Unit 4 exceeded the 50mg/Nm<sup>3</sup> limit during emergency generation on the 20 and 21 October 2021. Unit 6 exceeded the 50mg/Nm<sup>3</sup> limit during emergency generation on 2 October 2021. Full details for exceedances are provided in section 2.4.1.

## 2.11 Complaints register

**Table 11:** Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

## 2.12 Air quality improvements and social responsibility conducted

### 2.12.1 Air quality improvements

None

### 2.12.2 Social responsibility conducted

None

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## **2.13 Ambient air quality monitoring**

One exceedances of the SO<sub>2</sub> 10-minute limit, six exceedances of the PM<sub>2.5</sub> daily limit and ten exceedances of the PM<sub>10</sub> daily limit were noted. No other parameters exceeded the set limits during the monitoring period.

Ambient CO, PM<sub>2.5</sub>, PM<sub>10</sub> and NO<sub>2</sub> concentrations at Marapong monitoring site show influence of emissions from low level sources in the area while ambient Hg show influence of emissions from low level sources, tall stack emitters and other industrial activities. Ambient SO<sub>2</sub> concentrations show influence of emissions from tall stack emitters and other industrial activities.

The average data recovery for the period was 51% and the station availability was 64,5%.

Detailed results can be found in Attachment 1, "Marapong Monthly Report\_October 2021".

### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## **2.14 Electrostatic precipitator and Sulphur plant status**

### **Unit 1**

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **Unit 2**

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **Unit 3**

- 2 out of 32 precipitator fields is out of service. Repairs will be done during the next opportunity outage.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **Unit 4**

- 6 out of 32 precipitator fields is out of service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **Unit 5**

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **Unit 6**

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### **SO3 common plant**

- No abnormalities on the sulphur storage plant.

## **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.15 General

Name and reference number of the monitoring method used:

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues

## 3. Attachments

None

## 4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.