

	Matimba Power Station Emissions report	Matimba Power Station
---	---	------------------------------

Title: Matimba Power Station November 2021 emissions report **Document Identifier: RP/247/015**
Plant Location: Emission management
Area of Applicability: Matimba Power Station
Functional Area Applicability: Environment
Revision: 1
Total Pages: 44
Report Date: November 2021
Disclosure Classification: Controlled

Compiled by



WC Mocke
Environmental Officer

Date: 2021/12/23

Functional Responsibility



MC Mamabolo
Environmental Manager

Date: 23/12/2021

Authorized by



JL Janse van Rensburg
General Manager

Date: 2021-12-23

Content

	Page
1. Report Summary	4
2. Emission information	5
2.1 Raw materials and products.....	5
2.2 Abatement technology.....	5
2.3 Energy source characteristics	6
2.4 Emissions reporting.....	6
2.4.1 Particulate Matter Emissions	6
2.4.2 Gaseous Emissions	12
2.4.3 Total Volatile Organic Compounds	24
2.4.4 Greenhouse gas (CO ₂) emissions	25
2.5 Daily power generated	25
2.6 Pollutant Tonnages	32
2.7 Reference values	32
2.8 Continuous Emission Monitors.....	33
2.8.1 Reliability.....	33
2.8.2 Changes, downtime and repairs	34
2.8.3 Sampling dates and times.....	34
2.9 Units Start-up information	35
2.10 Emergency generation	42
2.11 Complaints register	42
2.12 Air quality improvements and social responsibility conducted	42
2.12.1 Air quality improvements.....	42
2.12.2 Social responsibility conducted.....	42
2.13 Ambient air quality monitoring.....	43
2.14 Electrostatic precipitator and Sulphur plant status	43
2.15 General.....	44
3. Attachments.....	44
4. Report Conclusion	44
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	5
Table 2: Abatement Equipment Control Technology Utilised.....	5
Table 3: Energy Source Material Characteristics.	6
Table 4: Total volatile compound estimates	24
Table 5: Daily power generated per unit in MWh for the month of November 2021	25
Table 6: Pollutant tonnages for the month of November 2021	32
Table 7: Reference values for data provided, November 2021	32
Table 8: Average percentage (%) availability of monitors for the month of November 2021	33
Table 9: Start-up information	35

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Emergency generation	42
Table 11: Complaints.....	42

Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 2 for the month of November 2021	7
Figure 2: Particulate matter daily average emissions against emission limit for unit 3 for the month of November 2021	8
Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of November 2021	9
Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of November 2021	10
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of November 2021	11
Figure 6: SO ₂ daily average emissions against emission limit for unit 2 for the month of November 2021	13
Figure 7: SO ₂ daily average emissions against emission limit for unit 3 for the month of November 2021	14
Figure 8: SO ₂ daily average emissions against emission limit for unit 4 for the month of November 2021	15
Figure 9: SO ₂ daily average emissions against emission limit for unit 5 for the month of November 2021	16
Figure 10: SO ₂ daily average emissions against emission limit for unit 6 for the month of November 2021.....	17
Figure 11: NO _x daily average emissions against emission limit for unit 2 for the month of November 2021.....	19
Figure 12: NO _x daily average emissions against emission limit for unit 3 for the month of November 2021.....	20
Figure 13: NO _x daily average emissions against emission limit for unit 4 for the month of November 2021.....	21
Figure 14: NO _x daily average emissions against emission limit for unit 5 for the month of November 2021.....	22
Figure 15: NO _x daily average emissions against emission limit for unit 6 for the month of November 2021.....	23
Figure 16: Unit 1 daily generated power in MWh for the month of November 2021	26
Figure 17: Unit 2 daily generated power in MWh for the month of November 2021	27
Figure 18: Unit 3 daily generated power in MWh for the month of November 2021	28
Figure 19: Unit 4 daily generated power in MWh for the month of November 2021	29
Figure 20: Unit 5 daily generated power in MWh for the month of November 2021	30
Figure 21: Unit 6 daily generated power in MWh for the month of November 2021	31

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (12/4/12L-W4/A4) in March 2020. Condition 7.7.1 of the License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in condition 7.7.1 for November 2021.



During the period under review, Matimba experienced 35 exceedances of the daily particulate matter emission limit ($50\text{mg}/\text{Nm}^3$) 6 of these exceedances occurred outside of the 48 hour grace period and were reported as section 30 incidents. No exceedances of the monthly SO_x limit ($3500\text{mg}/\text{Nm}^3$) or the daily NO_x limit ($750\text{ mg}/\text{Nm}^3$) occurred.

The monthly fuel oil usage limit of 1200 tons/month was exceeded with a monthly consumption rate of 3 473,2 tons for November 2021. The exceedance was due to multiple unit start-ups on units 1 to 6.

Issues mentioned above are discussed further under the respective sections within the report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	952 980
	Fuel Oil	Tons/month	1 200	3 473,2
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	GWh	4 212.6	1 673,644

The coal consumption rate for the month of November 2021 were within the permitted maximum limit. Fuel oil usage exceeded the maximum permitted consumption rate in November 2021. The exceedance was due to multiple units start-up across all the 6 units and the mill performance challenges experienced during light-up of unit 1.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99,87%
Unit 2	Electrostatic Precipitator	100%	99,9%
Unit 3	Electrostatic Precipitator	100%	99,81%
Unit 4	Electrostatic Precipitator	100%	99,89%
Unit 5	Electrostatic Precipitator	100%	99,93%
Unit 6	Electrostatic Precipitator	100%	99,93%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO ₃ Plant	100%	96,67%
Unit 2	SO ₃ Plant	100%	100%
Unit 3	SO ₃ Plant	100%	93,33%
Unit 4	SO ₃ Plant	100%	100%
Unit 5	SO ₃ Plant	100%	100%
Unit 6	SO ₃ Plant	100%	100%

Fluegas conditioning plant availability was below the required 100% for unit 1 and unit 3 due to unexpected breakdowns.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3 Energy source characteristics

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1,24%
	Ash Content	40%	34,96%

Energy source characteristics remained within the ranges stipulated in the license.

2.4 Emissions reporting

2.4.1 Particulate Matter Emissions

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of November 2021

Interpretation:

Unit 1 exceeded the 50mg/Nm³ emission limit on 4,5,6,7,8,10,12,13,17 and 27 November 2021. The exceedances that occurred from 4-8 November 2021 and 27 November 2021 were due to the unavailability of the flue gas conditioning plant due to low load conditions and unexpected breakdowns. The exceedances that occurred on 10, 12, 13 and 17 November 2021 occurred due to ash build-up within the flue gas stream after a breakdown on the dust handling plant occurred. The 48 hour grace period was exceeded on 06 November 2021 and a section 30 incident was reported. All other exceedances remained within the 48 hour grace period

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of November 2021

Interpretation:

Unit 2 exceeded the 50mg/Nm³ emission limit on 10, 19, 21, 22, 24 and 26 November 2021. The exceedances that occurred on 10 and 24 November 2021 was due to breakdowns experienced within the dust handling plant, and exceedances that occurred on 21, 22 and 26 November 2021 occurred due to breakdowns experienced on the ash conveyancing system. These breakdowns led to ash build-up within the flue gas cleaning stream which reduced the efficiency of the precipitator fields. The exceedance that occurred on 10 November 2021 was due to the unavailability of the Sulphur plant due to operating at low loads. All exceedances remained within the 48 hour grace period.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of November 2021

Interpretation:

Unit 3 exceeded the daily limit of 50mg/Nm³ on 1, 2, 5-7, 9, 10, 12-15, 17, 18 and 25-27 November 2021. The exceedances were due to failure of multiple precipitator fields due to damage incurred from increased ash in the flue gas cleaning system. The ash build-up was due to unplanned breakdowns on the dust handling and ash conveyancing plants. The unit was shut down on 27 November 2021 in order to do necessary repairs on the precipitator plant. The 48 hour grace period was exceeded on 14 November 2021 and 27 November 2021, section 30 notices were submitted for these incidents.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of November 2021

Interpretation:

Unit 4 exceeded the daily limit of 50mg/Nm³ on 7 and 21 November 2021. The exceedances were due to damaged precipitator fields. The damages occurred due to increased ash build-up after unexpected breakdowns on the dust handling and ash conveyancing plants. All exceedances remained within the 48 hour grace period.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of November 2021

Interpretation:

All daily averages below particulate emission limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 Particulate Emissions




Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of November 2021

Interpretation:

Unit 6 exceeded the daily limit of 50mg/Nm³ on 7 November 2021. The exceedance was due to damaged precipitator fields. The damages occurred due to increased ash build-up after unexpected breakdowns on the dust handling and ash conveyancing plants. The exceedance remained within the 48 hour grace period.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.2 Gaseous Emissions

Unit 1 SO₂ Emissions




Figure 7: SO₂ daily average emissions against emission limit for unit 1 for the month of November 2021

Interpretation:

Unit 1 was returned from outage on 3 November 2021. After the unit was lit up it was determined that the gaseous monitor power supply was defective as well as a communication module which sends the SO_x emission data to the servers from where it is extracted. The power supply was repaired on 17 November 2021 and the communication module was repaired on 09 December 2021. Averaged emission data from the Unit 1 QAL 2 report was used for reporting purposes.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO₂ Emissions




Figure 8: SO₂ daily average emissions against emission limit for unit 2 for the month of November 2021

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 SO₂ Emissions




Figure 9: SO₂ daily average emissions against emission limit for unit 3 for the month of November 2021

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO₂ Emissions




Figure 10: SO₂ daily average emissions against emission limit for unit 4 for the month of November 2021

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 SO₂ Emissions




Figure 11: SO₂ daily average emissions against emission limit for unit 5 for the month of November 2021

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 SO₂ Emissions




Figure 12: SO₂ daily average emissions against emission limit for unit 6 for the month of November 2021

Interpretation:

All daily averages remained below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 NO_x Emissions




Figure 13: Figure 14: NO_x daily average emissions against emission limit for unit 1 for the month of November 2021

Interpretation:

Unit 1 was returned from outage on 3 November 2021. After the unit was lit up it was determined that the gaseous monitor power supply was defective. The power supply was repaired on 17 November 2021. Averaged emission data was used for NO_x emission data for 3 to 17 November 2021.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO_x Emissions




Figure 15: NO_x daily average emissions against emission limit for unit 2 for the month of November 2021

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 NO_x Emissions




Figure 16: NO_x daily average emissions against emission limit for unit 3 for the month of November 2021

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 NO_x Emissions




Figure 17: NO_x daily average emissions against emission limit for unit 4 for the month of November 2021

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO_x Emissions




Figure 18: NO_x daily average emissions against emission limit for unit 5 for the month of November 2021

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 NO_x Emissions




Figure 19: NO_x daily average emissions against emission limit for unit 6 for the month of November 2021

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Tuesday, 21 December 2021	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.:	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
MONTHLY INPUT DATA FOR THE STATION Please only insert relevant monthly data inputs into the blue cells below Choose from a dropdown menu in the green cells The total VOC emissions for the month are in the red cells IMPORTANT: Do not change any other cells without consulting the AQ CoE		
MONTH:	November	
GENERAL INFORMATION:		Data
Total number of fuel oil tanks:	4	Unit
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	3473,179	
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
METEOROLOGICAL DATA FOR THE MONTH		Data
Daily average ambient temperature	26,22	°C
Daily maximum ambient temperature	32,63	°C
Daily minimum ambient temperature	20,19	°C
Daily ambient temperature range	12,44	°C
Daily total insolation factor	6,14	kWh/m ² /day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
FINAL OUTPUT:		Result
Breathing losses:	0,59 kg/month	
Working losses:	0,10 kg/month	
TOTAL LOSSES (Total TVOC Emissions for the month):	0,69 kg/month	
*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Trittech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

2.5 Daily power generated

Table 5: Daily power generated per unit in MWh for the month of November 2021

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2021/11/01	0	11979	11169	12186	11466	13572
2021/11/02	1,733	9590	10833	10631	8897	11262
2021/11/03	3705	11413	10666	12485	10865	12856
2021/11/04	8600	11731	2741	12730	11477	12779
2021/11/05	7876	9333	9539	12668	11035	12798
2021/11/06	9274	9218	12608	12389	9767	10470
2021/11/07	7471	10012	11599	12731	9977	12234
2021/11/08	5455	11244	12899	13500	10701	12818
2021/11/09	8254	9754	12856	11707	9871	10573
2021/11/10	11172	9026	12141	12822	11709	12143
2021/11/11	11155	11456	12035	11632	11121	12123
2021/11/12	11023	10416	12660	12238	10894	12495
2021/11/13	11021	9916	12415	12353	10707	12651
2021/11/14	10893	9722	11767	12060	10813	12626
2021/11/15	11869	11064	12479	12321	10791	12571
2021/11/16	10660	9592	12568	11651	8891	11526
2021/11/17	7708	4580	9042	11725	9617	11353
2021/11/18	7478	3973	12568	12131	10381	10223
2021/11/19	10550	11191	13010	12376	12030	10485
2021/11/20	7831	12109	11980	11515	13259	10924
2021/11/21	7835	13206	12228	1384	13539	9937
2021/11/22	7827	11892	12170	2051	12206	10768
2021/11/23	5054	9694	11659	11448	9268	9155
2021/11/24	7679	11211	11496	12243	11415	9568
2021/11/25	7832	11547	11554	12783	13085	0
2021/11/26	7843	12297	11437	14411	12716	2256
2021/11/27	10708	12593	10721	14068	13544	9382
2021/11/28	8729	12644	0	13102	4272	9428
2021/11/29	7841	11511	0	11328	11184	5280
2021/11/30	8009	12038	0	12429	12443	0

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 1 daily generated power in MWh for the month of November 2021

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 21: Unit 2 daily generated power in MWh for the month of November 2021

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 22: Unit 3 daily generated power in MWh for the month of November 2021

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 23: Unit 4 daily generated power in MWh for the month of November 2021

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 24: Unit 5 daily generated power in MWh for the month of November 2021

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 25: Unit 6 daily generated power in MWh for the month of November 2021

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.6 Pollutant Tonnages

The emitted pollutant tonnages for November 2021 are provided in table 6. Averaged Quality Assurance level 2 (QAL 2) values were used for CO₂ data for Unit 2, Unit 3, Unit 4, Unit 5, and Unit 6 due to the monitor providing unreliable values. Matimba is currently in the process of implementing recommended changes on this monitor in order to improve the reliability of the data. The expected completion date for these changes is 30 January 2021. Averaged QAL 2 values were also used for Unit 1 for the following dates and pollutants: 1-30 November 2021 for SO_x emissions due to a defective power supply and a defective communication module, 1-17 November 2021 for NO_x and CO₂ data due to a defective power supply. The Power supply was repaired on 17 November 2021 and the defective communication module was repaired 09 December 2021.

Table 6: Pollutant tonnages for the month of November 2021

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	56,6	3 367,6	440,7
Unit 2	51,7	5 694,7	828,3
Unit 3	90,2	4 503,8	906,3
Unit 4	58,5	5 148,0	1 044,9
Unit 5	36,0	3 377,3	582,1
Unit 6	37,2	4 166,9	676,8
SUM	330,2	26 258,2	4 479,1

2.7 Reference values

Table 7: Reference values for data provided, November 2021

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	8,50	8,14	9,07	6,45	8,12	7,62
Moisture	%	4,42	3,18	4,94	3,17	4,69	3,16
Velocity	m/s	17,5	24,9	27,3	24,5	22,9	24,9
Temperature	°C	121,7	122,9	130,5	134,8	121,1	172,8
Pressure	mBar	933,4	1 185,0	911,6	918,2	929,6	919,2

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8 Continuous Emission Monitors

2.8.1 Reliability

CO₂ monitor reliability for units 1, 2, 3, 4, 5 and 6 performed below the required 80% reliability as per the AEL. The monitors for unit 2, 3, 4, 5 and 6 were 100% available for November 2021 however the data received were removed and replaced with calculated values and averaged values due to values received from the monitors not being reliable. The monitor for unit 1 was not available from 1 to 17 November 2021 due to a defective power supply which was repaired on 17 November 2021. Unit 1 SO_x monitor also performed below the required 80% availability due to a defective communication module which was repaired on 09 December 2021.

Averaged Quality Assurance level 2 (QAL 2) values were used for Unit 1 SO_x data, Unit 2 CO₂ data and Unit 3 CO₂ data. CO₂ data for Unit 4, Unit 5 and Unit 6 was calculated by balance with oxygen readings.

Table 8: Average percentage (%) availability of monitors for the month of November 2021.

Associated Unit/Stack	PM	SO ₂	NO	CO ₂
Unit 1	93,8	0,0	44,0	44,0
Unit 2	100,0	100,0	88,9	0,0
Unit 3	100,0	99,9	99,9	0,0
Unit 4	100,0	100,0	100,0	0,0
Unit 5	100,0	100,0	100,0	0,0
Unit 6	100,0	100,0	100,0	0,0

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8.2 Changes, downtime and repairs

Unit 1

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 2

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 3

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 4

- Unit 4 gaseous emission monitor was repaired on 21 November 2021.
- No downtime or repairs done on the particulate monitors

Unit 5

- Unit 5 gaseous emission monitor was repaired on 21 November 2021.
- No downtime or repairs done on the particulate monitors

Unit 6

- Unit 6 gaseous emission monitor was repaired on 21 November 2021.
- No downtime or repairs done on the particulate monitors

2.8.3 Sampling dates and times

Continuous

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.9 Units Start-up information

Table 9: Start-up information

Unit	1	
Fires in	2021-11-02	21h38
Synchronization with Grid	2021-11-03	09h30
Emissions below limit	2021-11-03	18h51
Fires in to synchronization	11,87	HOURS
Synchronization to < Emission limit	9,35	HOURS

Unit	1	
Fires in	2021-11-05	10h54
Synchronization with Grid	2021-11-05	13h30
Emissions below limit	2021-11-05	15h51
Fires in to synchronization	2,6	HOURS
Synchronization to < Emission limit	2,35	HOURS

Unit	1	
Fires in	2021-11-07	20h18
Synchronization with Grid	2021-11-08	06h01
Emissions below limit	2021-11-08	10h42
Fires in to synchronization	9,71	HOURS
Synchronization to < Emission limit	4,68	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	1	
Fires in	2021-11-08	21h31
Synchronization with Grid	2021-11-09	02h33
Emissions below limit	2021-11-10	11h34
Fires in to synchronization	5,03	HOURS
Synchronization to < Emission limit	33,02	HOURS

Unit	1	
Fires in	2021-11-17	11h39
Synchronization with Grid	2021-11-17	18h46
Emissions below limit	2021-11-17	22h17
Fires in to synchronization	7,12	HOURS
Synchronization to < Emission limit	3,52	HOURS

Unit	1	
Fires in	2021-11-18	19h36
Synchronization with Grid	2021-11-19	01h52
Emissions below limit	2021-11-19	05h08
Fires in to synchronization	6,27	HOURS
Synchronization to < Emission limit	3,27	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	1	
Fires in	2021-11-19	01h54
Synchronization with Grid	2021-11-19	02h35
Emissions below limit	2021-11-19	05h08
Fires in to synchronization	0,68	HOURS
Synchronization to < Emission limit	2,55	HOURS

Unit	1	
Fires in	2021-11-23	20h03
Synchronization with Grid	2021-11-23	23h22
Emissions below limit	2021-11-24	06h00
Fires in to synchronization	3,32	HOURS
Synchronization to < Emission limit	6,63	HOURS

Unit	2	
Fires in	2021-11-05	17h16
Synchronization with Grid	2021-11-05	20h09
Emissions below limit	2021-11-05	20h09
Fires in to synchronization	2,88	HOURS
Synchronization to < Emission limit	0	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	2	
Fires in	2021-11-10	15h10
Synchronization with Grid	2021-11-10	17h30
Emissions below limit	2021-11-10	19h08
Fires in to synchronization	2,33	HOURS
Synchronization to < Emission limit	1,63	HOURS

Unit	2	
Fires in	2021-11-18	07h23
Synchronization with Grid	2021-11-18	09h35
Emissions below limit	2021-11-18	10h00
Fires in to synchronization	2,2	HOURS
Synchronization to < Emission limit	0,42	HOURS

Unit	2	
Fires in	2021-11-18	15h15
Synchronization with Grid	2021-11-18	18h46
Emissions below limit	2021-11-18	20h08
Fires in to synchronization	3,52	HOURS
Synchronization to < Emission limit	1,37	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	3	
Fires in	2021-11-04	16h05
Synchronization with Grid	2021-11-04	19h56
Emissions below limit	2021-11-04	23h08
Fires in to synchronization	3,85	HOURS
Synchronization to < Emission limit	3,2	HOURS

Unit	3	
Fires in	2021-11-17	15h00
Synchronization with Grid	2021-11-17	18h17
Emissions below limit	2021-11-17	22h17
Fires in to synchronization	3,28	HOURS
Synchronization to < Emission limit	4	HOURS

Unit	4	
Fires in	2021-11-20	00h39
Synchronization with Grid	2021-11-20	03h20
Emissions below limit	2021-11-20	09h25
Fires in to synchronization	2,68	HOURS
Synchronization to < Emission limit	6,08	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	4	
Fires in	2021-11-22	12h29
Synchronization with Grid	2021-11-22	19h05
Emissions below limit	2021-11-23	08h08
Fires in to synchronization	6,6	HOURS
Synchronization to < Emission limit	13,05	HOURS

Unit	5	
Fires in	2021-11-16	12h55
Synchronization with Grid	2021-11-16	15h54
Emissions below limit	2021-11-16	15h54
Fires in to synchronization	2,98	HOURS
Synchronization to < Emission limit	0	HOURS

Unit	5	
Fires in	2021-11-28	13h07
Synchronization with Grid	2021-11-28	16h59
Emissions below limit	2021-11-28	19h17
Fires in to synchronization	3,87	HOURS
Synchronization to < Emission limit	2,3	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	6	
Fires in	2021-11-06	20h28
Synchronization with Grid	2021-11-06	23h38
Emissions below limit	2021-11-06	23h38
Fires in to synchronization	3,17	HOURS
Synchronization to < Emission limit	0	HOURS

Unit	6	
Fires in	2021-11-26	08h50
Synchronization with Grid	2021-11-26	16h58
Emissions below limit	2021-11-26	16h58
Fires in to synchronization	8,13	HOURS
Synchronization to < Emission limit	0	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10 Emergency generation

Table 10: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	447	514	453	505	531	468
Emergency Hours declared including hours after stand down	457	524	463	515	541	478
Days over the Limit during Emergency Generation	10	5	16	2	0	1

Unit 1 exceeded the 50mg/Nm³ limit during emergency generation 10 times in November 2021. Unit 2 exceeded the 50mg/Nm³ limit during emergency generation 5 times in November 2021. Unit 3 exceeded the 50mg/Nm³ limit during emergency generation 16 times in November 2021. Unit 4 exceeded the 50mg/Nm³ limit during emergency generation 2 times in November 2021. Unit 6 exceeded the 50mg/Nm³ limit during emergency generation 1 time in November 2021. Full details for exceedances are provided in section 2.4.1.

2.11 Complaints register

Table 11: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

2.12 Air quality improvements and social responsibility conducted

2.12.1 Air quality improvements

None

2.12.2 Social responsibility conducted

None

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.13 Ambient air quality monitoring

There were no exceedances recorded in the reporting period.

Ambient PM2.5, PM10 and NO2 concentrations at Marapong monitoring site show influence of emissions from low level sources in the area while ambient SO2 show influence of emissions from tall stack emitters and other industrial activities.

The average data recovery for the period was 67,8% and the station availability was 62,5%.

Detailed results can be found in Attachment 1, "Marapong Monthly Report_October 2021".

2.14 Electrostatic precipitator and Sulphur plant status

Unit 1

- 2 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 2

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 3

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 4

- 1 field out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 5

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 6

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

SO3 common plant

- No abnormalities on the sulphur storage plant.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.15 General

Name and reference number of the monitoring method used:

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. Eskom internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

None

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.