	<b>Matimba Power Station Emissions report</b>	<b>Matimba Power Station</b>
---	---	------------------------------

Title: **Matimba Power Station December 2021 emissions report**

Document Identifier: **RP/247/016**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **44**

Report Date: **December 2021**

Disclosure Classification: **Controlled**

**Compiled by**



**WC Mocke**  
**Environmental Officer**

Date: 2022/01/27

**Functional Responsibility**



**MC Mamabolo**  
**Environmental Manager**

Date: 27/01/2022

**Authorized by**



**JL Janse van Rensburg**  
**General Manager**

Date: 2022-01-28

## Content

	Page
1. Report Summary .....	4
2. Emission information .....	5
2.1 Raw materials and products.....	5
2.2 Abatement technology.....	5
2.3 Energy source characteristics .....	6
2.4 Emissions reporting.....	6
2.4.1 Particulate Matter Emissions .....	6
2.4.2 Gaseous Emissions .....	12
2.4.3 Total Volatile Organic Compounds .....	24
2.4.4 Greenhouse gas (CO <sub>2</sub> ) emissions .....	25
2.5 Daily power generated .....	25
2.6 Pollutant Tonnages .....	32
2.7 Reference values .....	32
2.8 Continuous Emission Monitors.....	33
2.8.1 Reliability.....	33
2.8.2 Changes, downtime and repairs .....	34
2.8.3 Sampling dates and times.....	34
2.9 Units Start-up information .....	35
2.10 Emergency generation .....	37
2.11 Complaints register .....	38
2.12 Air quality improvements and social responsibility conducted .....	38
2.12.1 Air quality improvements.....	38
2.12.2 Social responsibility conducted.....	38
2.13 Ambient air quality monitoring.....	38
2.14 Electrostatic precipitator and Sulphur plant status .....	38
2.15 General.....	39
3. Attachments.....	40
4. Report Conclusion .....	40
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	5
Table 2: Abatement Equipment Control Technology Utilised.....	5
Table 3: Energy Source Material Characteristics. ....	6
Table 4: Total volatile compound estimates .....	24
Table 5: Daily power generated per unit in MWh for the month of December 2021 .....	25
Table 6: Pollutant tonnages for the month of December 2021.....	32
Table 7: Reference values for data provided, December 2021.....	32
Table 8: Average percentage (%) availability of monitors for the month of December 2021.....	33
Table 9: Start-up information .....	35

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Emergency generation .....	37
Table 11: Complaints.....	38

## Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 2 for the month of December 2021 .....	7
Figure 2: Particulate matter daily average emissions against emission limit for unit 3 for the month of December 2021 .....	8
Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of December 2021 .....	9
Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of December 2021 .....	10
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of December 2021 .....	11
Figure 6: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of December 2021 ....	13
Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of December 2021 ....	14
Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 4 for the month of December 2021 ....	15
Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 5 for the month of December 2021 ....	16
Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 6 for the month of December 2021.....	17
Figure 11: NO <sub>x</sub> daily average emissions against emission limit for unit 2 for the month of December 2021.....	19
Figure 12: NO <sub>x</sub> daily average emissions against emission limit for unit 3 for the month of December 2021.....	20
Figure 13: NO <sub>x</sub> daily average emissions against emission limit for unit 4 for the month of December 2021.....	21
Figure 14: NO <sub>x</sub> daily average emissions against emission limit for unit 5 for the month of December 2021.....	22
Figure 15: NO <sub>x</sub> daily average emissions against emission limit for unit 6 for the month of December 2021.....	23
Figure 16: Unit 1 daily generated power in MWh for the month of December 2021 .....	26
Figure 17: Unit 2 daily generated power in MWh for the month of December 2021 .....	27
Figure 18: Unit 3 daily generated power in MWh for the month of December 2021 .....	28
Figure 19: Unit 4 daily generated power in MWh for the month of December 2021 .....	29
Figure 20: Unit 5 daily generated power in MWh for the month of December 2021 .....	30
Figure 21: Unit 6 daily generated power in MWh for the month of December 2021 .....	31

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (12/4/12L-W4/A4) in March 2020. Condition 7.7.1 of the License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in condition 7.7.1 for December 2021.



During the period under review, Matimba experienced 12 exceedances of the daily particulate matter emission limit ( $50\text{mg}/\text{Nm}^3$ ) 1 of these exceedances occurred outside of the 48 hour grace period and were reported as a section 30 incident. No exceedances of the monthly  $\text{SO}_x$  limit ( $3500\text{mg}/\text{Nm}^3$ ) or the daily  $\text{NO}_x$  limit ( $750\text{ mg}/\text{Nm}^3$ ) occurred.

The monthly fuel oil usage limit of 1200 tons/month was exceeded with a monthly consumption rate of 1416 tons for December 2021. The exceedance was due to multiple unit start-ups on units 1, 2, 3 and 6.

Issues mentioned above are discussed further under the respective sections within the report.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2. Emission information

### 2.1 Raw materials and products

**Table 1:** Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	1 093 074
	Fuel Oil	Tons/month	1 200	1415,887
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	GWh	4 212.6	1 869,052

The coal consumption rate for the month of December 2021 was within the permitted maximum limit. Fuel oil usage exceeded the maximum permitted consumption rate in December 2021. The exceedance was due to multiple unit start-ups on unit 1, unit 2, unit 3 and unit 6 during the reporting period.

### 2.2 Abatement technology

**Table 2:** Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99,858%
Unit 2	Electrostatic Precipitator	100%	99,900%
Unit 3	Electrostatic Precipitator	100%	99,935%
Unit 4	Electrostatic Precipitator	100%	99,890%
Unit 5	Electrostatic Precipitator	100%	99,894%
Unit 6	Electrostatic Precipitator	100%	99,921%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO <sub>3</sub> Plant	100%	100%
Unit 2	SO <sub>3</sub> Plant	100%	96,7%
Unit 3	SO <sub>3</sub> Plant	100%	100%
Unit 4	SO <sub>3</sub> Plant	100%	100%
Unit 5	SO <sub>3</sub> Plant	100%	100%
Unit 6	SO <sub>3</sub> Plant	100%	100%

Fluegas conditioning plant availability was below the required 100% for unit 2 due to unexpected breakdowns.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.3 Energy source characteristics

**Table 3:** Energy Source Material Characteristics.


	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1,29%
	Ash Content	40%	34,97%

Energy source characteristics remained within the ranges stipulated in the license.

## 2.4 Emissions reporting

### 2.4.1 Particulate Matter Emissions

#### Unit 1 Particulate Emissions



**Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of December 2021**

#### Interpretation:


Unit 1 exceeded the 50mg/Nm<sup>3</sup> emission limit on 8, 17 and 27-31 December 2021. The exceedances were due to unexpected breakdowns that occurred on the ash conveying plant which led to ash build-up within the flue gas stream and reduced the efficiency of the electrostatic precipitator field. The 48 hour grace period was exceeded on 31 December 2021 and a section 30 incident was reported. All other exceedances remained within the 48 hour grace period. The plant was repaired on 31 December 2021 and emissions normalised on 01 January 2022.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 2 Particulate Emissions



**Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of December 2021**

#### Interpretation:


Unit 2 exceeded the 50mg/Nm<sup>3</sup> emission limit on 6 and 28 December 2021. The exceedance that occurred on 06 December 2021 was due to breakdowns experienced within the dust handling plant, and the exceedances that occurred on 28 December 2021 occurred due to breakdowns experienced on the ash conveyancing system. These breakdowns led to ash build-up within the flue gas cleaning stream which reduced the efficiency of the precipitator fields. All exceedances remained within the 48 hour grace period.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 3 Particulate Emissions



**Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of December 2021**

**Interpretation:**

All daily averages below particulate emission limit of 50 mg/Nm<sup>3</sup>.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## Unit 4 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of December 2021**

#### Interpretation:


Unit 4 exceeded the daily limit of 50mg/Nm<sup>3</sup> on 27 and 28 December 2021. The exceedances occurred due to breakdowns on the ash conveyancing system. These breakdowns led to ash build-up within the flue gas cleaning stream which reduced the efficiency of the precipitator fields. All exceedances remained within the 48 hour grace period.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 5 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of December 2021**

**Interpretation:**


Unit 5 exceeded the daily limit of 50mg/Nm<sup>3</sup> on 28 December 2021. The exceedance occurred due to breakdowns on the ash conveyancing system. These breakdowns led to ash build-up within the flue gas cleaning stream which reduced the efficiency of the precipitator fields. All exceedances remained within the 48 hour grace period

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 6 Particulate Emissions



**Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of December 2021**

**Interpretation:**

All daily averages below particulate emission limit of 50 mg/Nm<sup>3</sup>.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.4.2 Gaseous Emissions

### Unit 1 SO<sub>2</sub> Emissions



**Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 1 for the month of December 2021**


#### Interpretation:

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO<sub>2</sub> Emissions

**Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of December 2021**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 SO<sub>2</sub> Emissions

**Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of December 2021**


#### Interpretation:

Monthly average was 2 824 mg/Nm<sup>3</sup> which is below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>. SO<sub>x</sub> emissions increased during the period of 10 December 2021 until 21 December 2021. This was due to an increase in in the oxygen readings during this time in conjunction with occasional increases in the sulphur content of the coal used for electricity generation. The increase in emissions were investigated and required repairs were made.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 4 SO<sub>2</sub> Emissions**

**Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 4 for the month of December 2021**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 5 SO<sub>2</sub> Emissions**

**Figure 11: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of December 2021**

**Interpretation:**


All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



Unit 6 SO<sub>2</sub> Emissions

**Figure 12: SO<sub>2</sub> daily average emissions against emission limit for unit 6 for the month of December 2021**


**Interpretation:**

All daily averages remained below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 NO<sub>x</sub> Emissions

**Figure 13: Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 1 for the month of December 2021**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO<sub>x</sub> Emissions

**Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 2 for the month of December 2021**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 NO<sub>x</sub> Emissions

**Figure 16: NO<sub>x</sub> daily average emissions against emission limit for unit 3 for the month of December 2021**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 NO<sub>x</sub> Emissions

**Figure 17: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of December 2021**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO<sub>x</sub> Emissions

**Figure 18: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of December 2021**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 NO<sub>x</sub> Emissions

**Figure 19: NO<sub>x</sub> daily average emissions against emission limit for unit 6 for the month of December 2021**

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Friday, 14 January 2022	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <u>blue cells</u> below</p> <p align="center">Choose from a dropdown menu in the <u>green cells</u></p> <p align="center">The total VOC emissions for the month are in the <u>red cells</u></p> <p align="center">IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE</p>		
MONTH:	December	
<b>GENERAL INFORMATION:</b>		<b>Data Unit</b>
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	1415,887	
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
<b>METEROLOGICAL DATA FOR THE MONTH</b>		<b>Data Unit</b>
Daily average ambient temperature	27,35	°C
Daily maximum ambient temperature	33,26	°C
Daily minimum ambient temperature	21,97	°C
Daily ambient temperature range	11,30	°C
Daily total insolation factor	6,12	kWh/m²/day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
<b>FINAL OUTPUT:</b>		<b>Result Unit</b>
Breathing losses:	0,57 kg/month	
Working losses:	0,04 kg/month	
<b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>	<b>0,61 kg/month</b>	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.4.4 Greenhouse gas (CO<sub>2</sub>) emissions

CO<sub>2</sub> emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

## 2.5 Daily power generated


**Table 5:** Daily power generated per unit in MWh for the month of December 2021

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2021/12/01	11662	11468	8427	12212	12374	0
2021/12/02	9946	11618	13847	12476	12689	0
2021/12/03	0	10505	13543	12075	12276	10199
2021/12/04	0	11657	13681	13563	12912	13011
2021/12/05	0	12223	13398	13718	13864	13228
2021/12/06	0	11970	14116	13684	14150	13290
2021/12/07	6819	11110	13307	12897	12204	12271
2021/12/08	11779	12377	13607	13943	13150	13052
2021/12/09	13252	12676	14140	14480	13978	14001
2021/12/10	12763	12553	13785	12629	13618	12848
2021/12/11	12931	12088	13141	12384	12747	12085
2021/12/12	13860	345,9	13742	14108	13611	12915
2021/12/13	14132	0	13587	14266	13365	12748
2021/12/14	13568	0	13374	13564	13457	12917
2021/12/15	11948	0	12246	12199	11765	12085
2021/12/16	12693	0	12883	13252	13429	12827
2021/12/17	11642	0	12191	12240	12515	12150
2021/12/18	13934	0	12909	13187	13590	11325
2021/12/19	15450	0	13891	14354	14350	11274
2021/12/20	13366	0	12702	12903	13253	11262
2021/12/21	14119	0	13438	12535	13517	11249
2021/12/22	14073	0	7191	13327	14235	11264
2021/12/23	13806	0	11471	12742	14100	11276
2021/12/24	11537	0	11093	10756	13483	10710
2021/12/25	11731	7730	11223	11413	11987	8609
2021/12/26	6949	11447	11149	11602	11897	11645
2021/12/27	10942	11345	11106	11320	12307	12224
2021/12/28	10506	7513	10804	11061	12444	11979
2021/12/29	11528	11159	10560	10823	12394	12054
2021/12/30	10844	10704	10546	10963	12565	11421
2021/12/31	10710	10568	10387	11146	12834	11165

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 20: Unit 1 daily generated power in MWh for the month of December 2021**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 21: Unit 2 daily generated power in MWh for the month of December 2021**

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 22: Unit 3 daily generated power in MWh for the month of December 2021**

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 23: Unit 4 daily generated power in MWh for the month of December 2021**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 24: Unit 5 daily generated power in MWh for the month of December 2021**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 25: Unit 6 daily generated power in MWh for the month of December 2021**

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.6 Pollutant Tonnages

The emitted pollutant tonnages for December 2021 are provided in table 6. Averaged Quality Assurance level 2 (QAL 2) values were used for O<sub>2</sub> data for Unit 1 and CO<sub>2</sub> data for Unit 2 and Unit 6. CO<sub>2</sub> Values for unit 4 and 5 was calculated as per balance based on the O<sub>2</sub> values. These values were used due to the monitor providing unreliable values. Matimba is currently in the process of implementing recommended changes on this monitor in order to improve the reliability of the data.

**Table 6:** Pollutant tonnages for the month of December 2021

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)
Unit 1	78,5	3 870,9	684,7
Unit 2	34,0	3 605,9	551,0
Unit 3	42,2	5 735,6	1 082,0
Unit 4	70,2	5 672,5	1 196,7
Unit 5	71,7	4 043,1	691,0
Unit 6	46,5	4 779,4	766,4
<b>SUM</b>	343,0	27 707,4	4 971,8

## 2.7 Reference values

**Table 7:** Reference values for data provided, December 2021

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	8,77	8,52	8,91	6,31	7,79	8,57
Moisture	%	5,36	3,76	5,48	3,55	5,49	3,28
Velocity	m/s	23,1	26,0	28,2	25,0	25,4	26,7
Temperature	°C	133,9	127,0	131,4	133,2	124,6	170,1
Pressure	mBar	933,5	1 152,5	914,0	920,7	931,3	922,4

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.8 Continuous Emission Monitors

### 2.8.1 Reliability

CO<sub>2</sub> monitor reliability for units 1, 2, 3, 4, 5 and 6 performed below the required 80% reliability as per the AEL. The monitors for these units were 100% available for December 2021 however the data received were removed and replaced with calculated values and averaged values due to values received from the monitors not being reliable.

Averaged Quality Assurance level 2 (QAL 2) values were used for O<sub>2</sub> data for Unit 1 and CO<sub>2</sub> data for Unit 2 and Unit 6. CO<sub>2</sub> Values for unit 4 and 5 was calculated as per balance based on the O<sub>2</sub> values.

**Table 8:** Average percentage (%) availability of monitors for the month of December 2021.

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	CO <sub>2</sub>
Unit 1	99,7	82,9	97,9	0,0
Unit 2	99,8	100,0	95,0	0,0
Unit 3	100,0	99,9	99,9	70,8
Unit 4	100,0	100,0	99,2	0,0
Unit 5	100,0	99,9	99,9	0,0
Unit 6	100,0	100,0	100,0	0,0

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## **2.8.2 Changes, downtime and repairs**

### **Unit 1**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 2**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 3**

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### **Unit 4**

- Unit 4 gaseous emission monitor was repaired on 21 December 2021.
- No downtime or repairs done on the particulate monitors

### **Unit 5**

- Unit 5 gaseous emission monitor was repaired on 21 December 2021.
- No downtime or repairs done on the particulate monitors

### **Unit 6**

- Unit 6 gaseous emission monitor was repaired on 21 December 2021.
- No downtime or repairs done on the particulate monitors

## **2.8.3 Sampling dates and times**

Continuous

### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.9 Units Start-up information

**Table 9:** Start-up information

<b>Unit</b>	1	
<b>Fires in</b>	2021-12-06	19h51
<b>Synchronization with Grid</b>	2021-12-07	02h04
<b>Emissions below limit</b>	2021-12-07	13h42
<b>Fires in to synchronization</b>	6,22	HOURS
<b>Synchronization to &lt; Emission limit</b>	11,63	HOURS

<b>Unit</b>	1	
<b>Fires in</b>	2021-12-26	09h01
<b>Synchronization with Grid</b>	2021-12-26	13h38
<b>Emissions below limit</b>	2021-12-26	15h52
<b>Fires in to synchronization</b>	4,62	HOURS
<b>Synchronization to &lt; Emission limit</b>	2,23	HOURS

<b>Unit</b>	2	
<b>Fires in</b>	2021-12-24	02h12
<b>Synchronization with Grid</b>	2021-12-25	05h57
<b>Emissions below limit</b>	2021-12-25	10h18
<b>Fires in to synchronization</b>	27,75	HOURS
<b>Synchronization to &lt; Emission limit</b>	4,35	HOURS

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	2	
<b>Fires in</b>	2021-12-28	14h20
<b>Synchronization with Grid</b>	2021-12-28	17h20
<b>Emissions below limit</b>	2021-12-28	19h21
<b>Fires in to synchronization</b>	3	HOURS
<b>Synchronization to &lt; Emission limit</b>	2,02	HOURS

<b>Unit</b>	3	
<b>Fires in</b>	2021-11-30	16h44
<b>Synchronization with Grid</b>	2021-12-01	06h45
<b>Emissions below limit</b>	2021-12-01	06h45
<b>Fires in to synchronization</b>	14,02	HOURS
<b>Synchronization to &lt; Emission limit</b>	0	HOURS

<b>Unit</b>	3	
<b>Fires in</b>	2021-12-22	05h45
<b>Synchronization with Grid</b>	2021-12-22	10h26
<b>Emissions below limit</b>	2021-12-22	12h27
<b>Fires in to synchronization</b>	4,68	HOURS
<b>Synchronization to &lt; Emission limit</b>	2,02	HOURS

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	6	
<b>Fires in</b>	2021-12-02	20h56
<b>Synchronization with Grid</b>	2021-12-03	01h32
<b>Emissions below limit</b>	2021-12-03	01h44
<b>Fires in to synchronization</b>	4,6	HOURS
<b>Synchronization to &lt; Emission limit</b>	0,2	HOURS

## 2.10 Emergency generation

**Table 10:** Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
<b>Emergency Generation hours declared by national Control</b>	447	514	453	505	531	468
<b>Emergency Hours declared including hours after stand down</b>	237	53	221	237	237	152
<b>Days over the Limit during Emergency Generation</b>	251	55	235	251	251	166

Unit 1 exceeded the 50mg/Nm<sup>3</sup> limit during emergency generation 5 times in December 2021. Unit 2 exceeded the 50mg/Nm<sup>3</sup> limit during emergency generation 1 time in December 2021. Unit 4 exceeded the 50mg/Nm<sup>3</sup> limit during emergency generation 2 times in December 2021. Unit 5 exceeded the 50mg/Nm<sup>3</sup> limit during emergency generation 1 time in December 2021. Full details for exceedances are provided in section 2.4.1.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.11 Complaints register

**Table 11:** Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

## 2.12 Air quality improvements and social responsibility conducted

### 2.12.1 Air quality improvements

None

### 2.12.2 Social responsibility conducted

None

## 2.13 Ambient air quality monitoring

The ambient air quality report was not available at the time of publishing this report.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.14 Electrostatic precipitator and Sulphur plant status

### Unit 1

- 2 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 2

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 3

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 4

- 1 field out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 5

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 6

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### SO3 common plant

- No abnormalities on the sulphur storage plant.

## 2.15 General

Name and reference number of the monitoring method used:

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

- b. Gas:
  - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
- c. Stack height
  - i. 250 meter consist of 3 flues

### 3. Attachments

None

### 4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.