

Mrs Mpho Nembilwi
Nkangala District
P O Box 437
MIDDLEBERG
1050
By email nembilwim@nkangaladm.gov.za'

Date
26 January 2022

Enquiries S Chokoe
Tel +27 13 647 6970

Dear Mrs Mpho Nembilwi

Ref Kendal Power Station AEL (17/4/AEL/MP312/11/15)

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF NOVEMBER 2021.

This is a monthly report required in terms of Section 7 4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Compiled by:



Tshilidzi Vilane
ENVIRONMENTAL OFFICER- KENDAL

Date: 26/01/2022

Supported by:



Solly Chokoe
ENVIRONMENTAL MANAGER- KENDAL

Date: 26/01/2026

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTHS OF NOVEMBER 2021.


Verified by:



Fulufhelo Nganke
BOILER ENGINEERING: SYSTEM ENGINEER- KENDAL

Date: 27/01/2022

Validated by:



Tendani Rasivhetshela
ACTING BOILER ENGINEERING MANAGER-KENDAL

Date 27/01/2022

Supported by:



Malibongwe Mabizela
ENGINEERING MANAGER-KENDAL

Date 28/01/2022

Approved by:



Lukhanyo Ndube
GENERAL MANAGER-KENDAL

Date 31/01/2022

KENDAL POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/15


1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Nov-2021
	Coal	Tons	2 260 000	629 468
	Fuel Oil	Tons	5 000	2481.18

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Nov-2021
	Energy	GWh(MW)	4380	1 539 056.00
	Ash	Tons	770 000	205 143.6
	RE Ash	kg/MWh	not specified	0.610

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	<1 (%)	1.020
Ash Content	%	40 (%)	32.590

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO _x	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMET TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Nov-2021	Technology Type	Utilization Nov-2021
Unit 1	ESP + SO ₂	Off-line	SO ₂	Off-line
Unit 2	ESP + SO ₂	99.7%	SO ₂	0.0%
Unit 3	ESP + SO ₂	99.7%	SO ₂	47.3%
Unit 4	ESP + SO ₂	99.8%	SO ₂	0.0%
Unit 5	ESP + SO ₂	99.3%	SO ₂	0.0%
Unit 6	ESP + SO ₂	Off-line	SO ₂	Off-line

Unit 2,3,4 & 5 sulphur utilization was low because KEPDATA04 and KEPDATA05 failed.

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	Off-line	Off-line	Off-line	Off-line
Unit 2	89.7	90.5	90.5	29.0
Unit 3	99.6	99.2	99.7	99.9
Unit 4	91.0	91.9	91.1	93.2
Unit 5	88.7	95.1	95.1	97.7
Unit 6	Off-line	Off-line	Off-line	Off-line

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂

Note: Unit O₂ monitor was defective

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of November 2021

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)	CO ₂
Unit 1	Off-line	Off-line	Off-line	Off-line
Unit 2	98.3	2 920	1 118	204 839
Unit 3	142.0	0	0	0
Unit 4	103.3	1 656	583	103 797
Unit 5	237.8	2 092	746	227 674
Unit 6	Off-line	Off-line	Off-line	Off-line
SUM	581.38	6 668	2 447	536 310

Table 6.2: Operating days in compliance to PM AEL Limit - November 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
Unit 2	23	4	0	0	5	91.2
Unit 3	23	7	0	0	7	93.1
Unit 4	20	4	0	0	4	83.9
Unit 5	12	1	0	0	4	285.9
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	78	16	0	0	16	

Table 6.3: Operating days in compliance to SOx AEL Limit - November 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average SOx (mg/Nm ³)
Unit 1	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
Unit 2	29	0	0	0	0	3 131.2
Unit 3	30	0	0	0	0	2 066.3
Unit 4	27	0	0	0	0	2 158.7
Unit 5	19	0	0	0	0	2 071.5
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	105	0	0	0	0	



Table 6.4: Operating days in compliance to NOx AEL Limit - November 2021

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm ³)
Unit 1	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
Unit 2	29	0	0	0	0	787.7
Unit 3	30	0	0	0	0	537.3
Unit 4	27	0	0	0	0	746.1
Unit 5	19	0	0	0	0	740.3
Unit 6	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
SUM	105	0	0	0	0	

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂


Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contra-vention	Red	Emissions above ELV but outside grace or S30 incident conditions



Unit 2 dust emissions can be attributed PA heater leakage. PI servers 1 & 2 were offline from the 23rd to 26th.


Figure 3: Kendal Unit 3 PM Emissions - November 2021



High PM emissions can be attributed to 8 precip fields were out of service.

The high PM emissions can attributed to damaged air heater packs, on the 02nd & 03rd can be attributed to So3 plant tripping on Burner outlet temperature high-injection setpoint reduced to 11 ppm. On the 03rd the dust emission monitor lenses cleaned- Dust emission dropped from 200 to 54 mg/Nm3 on the pims system. On the 06th & 07th Precip conveyor 11 tripped, Stream 1 dust handling plant tripped on compartment 10 level High, precip fields were optimised. on 15th, 52 MW load loss due to high emissions were taken and on the 19th SO3 plant tripped.


Figure 4: Kendal Unit 4 PM Emissions - November 2021



High PM emissions for the 07th and for the 26th can be attributed to light up conditions

High PM emissions can be attributed to precip fields poor performance. Precip conveyor 21,22&23 knife gates checked in.

Figure 5: Kendal Unit 5 PM Emissions - November 2021



High PM emissions can be attributed to Electrostatic precipitators fields tripping due to wires breakages and fields misalignment, SCADA challenges and delayed fields optimisation .So3 plant off due to no sulphur flow, precip 13 conveyor choked.

Figure 6: Kendal Unit 6 PM Emissions - November 2021




Figure 7: Kendal Unit 1 SOx Emissions - November 2021




Figure 8: Kendal Unit 2 SOx Emissions - November 2021




Figure 9: Kendal Unit 3 SOx Emissions - November 2021




Figure 10: Kendal Unit 4 SOx Emissions - November 2021




Figure 11: Kendal Unit 5 SOx Emissions - November 2021




Figure 12: Kendal Unit 6 SOx Emissions - November 2021










Figure 13: Kendal Unit 1 NOx Emissions - November 2021







7 COMPLAINTS

There were no complaints for this months

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

ADDENDUM TO MONTHLY EMISSIONS REPORT

Abatement Technology Table 4

In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as

- ☐ Coal ash content (%) and burnt rate mass
- ☐ Fly Coarse ash ratio of 80 20 - 80% of fly ash mass obtained from burnt coal goes to ESP
- ☐ Measurement of dust emission by Dust Monitor over a period of time (monthly)

Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \frac{(\text{Dust Emission from AQR Report Dust Monitor (tons)} \times 100)}{(\text{Coal Burnt (tons)} \times \% \text{Ash Content} \times 80\%)}$$

Monitor Reliability-Table 5

In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average

The monitor reliability refers to data reliability because the assumed value of 98% reliability is compared to the dust concentration signal. If the dust concentration signal is above 98% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g. 24 hours

The formula is as follows

$$= (1 - (\text{count hours above 98\%/24hours})) \times 100$$

Emissions Performance

- Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2, 3, 4 due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- Average emissions for Unit 2 O2 was used from the QAL2 parallel report because the monitor was out of calibration and average emissions available for the month were used for the SOx and NOx emissions from 23rd until 26th due to monitor failure
- Average emissions for Unit 3 pressure was used from the QAL2 parallel report due to defective analysers
- Average emissions for Unit 5 CO2 average was used from QAL2 parallel report due to defective monitor
- Unit 1 and 6 were offload

Unit 2

Findings Unit 2 dust emissions can be attributed Primary Air heater leakage PI servers 1 & 2 were offline from the 23rd to 26th

Resolution Primary Air heater leakage to be fixed during GO

Unit 3

Findings High PM emissions on the 29th can be attributed to 8 precip fields were out of service. The high PM emissions can be attributed to damaged air heater packs on the 02nd & 03rd can be attributed to SO3 plant tripping on Burner outlet temperature high - Injection setpoint reduced to 12 ppm. On the 03rd the dust emission monitor lenses cleaned - Dust emission dropped from 200 to 54 mg/Nm3 on the pims system. On the 06th & 07th Precip conveyor 11 tripped, Stream 1 dust handling plant tripped on compartment 10 level high, precip fields were optimised on 15th 52 MW load loss due to high emissions were taken and on the 19th SO3 plant tripped. On the 29th to 8 precip fields were out of service

Resolution The DHP and SO3 plant was returned back to service after repairs

Unit 4

Findings High PM emissions can be attributed to precip fields poor performance. Precip conveyor 21,22&23 knife gates checked in

Resolution The plant was repaired

Note Unit 4 correlations test were done in November 2021, awaiting report. Report to be received in January. November report will be resent after implementation of the new correlation curves

Unit 5

Findings High PM emissions can be attributed to Electrostatic precipitators fields tripping due to wires breakages and fields misalignment, SCADA challenges and delayed fields optimisation. SO3 plant off due to no sulphur flow. Precip 13 conveyor choked

Resolution The unit was shut down for repairs