

Lukhanyo Mgadle
 Chief Air Quality Officer Buffalo City Metropolitan Municipality
 2 Beaconsfield Road North End
 East London
 5201

Date:
 1 March 2022

Enquiries: Hilton Westman
 (021) 9415856

Ref: PRX/2022/02

Dear Mr Mgadle

ESKOM PORT REX POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF FEBRUARY 2022

Atmospheric Emissions License: ECBC_000603

This serves as the monthly report and the information is applicable for the month of February 2022.

1. Raw Materials and Products (Licence 6.1)

Quantity of Raw Materials and Products used/produced for the month

Element	Performance	Reporting Unit
Fuel type : Diesel		
Total Fuel Consumption	53.544	Tons
Electricity Produced	170	MWh
Average Fuel Consumption	0.314	Tons / MWh
Maximum fuel consumption rate	13 907	Kg per hour

2. Operating times of units (Licence 5.4)

a. Total Hours

	Hours operated	Total Fuel Consumption	Energy Production
	Hours and minutes	Litres	MWh
Unit One	1hr 17min	62 457	57
Unit Two	1hr 17min		59
Unit Three	1hr 17min		54

Peaking

Port Rex Power Station
 9 Wells Road Woodbrook East London
 PO Box 1281 East London 5201
 Tel +27 043 703 5771

b. Detailed operating times

See Annexure 1

3. Complaints Register (Licence 7.6)

No complaints were registered for the month of February 2022.

4. General

Port Rex was requested to generate for the grid to supplement power availability and minimise national load shedding.

We trust that the above information complies with your requirements.

Yours sincerely



Pamela Mrubata

Plant Manager

PORT REX POWER STATION

Annexure 1. Port Rex Hours of operation

	Unit One			Unit two			Unit 3		
Date	Start	Finish	Total Hours	Start	Finish	Total Hours	Start	Finish	Total Hours
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12	19: 12:00	20:29:00	01:17:00	19: 12:00	20:29:00	01:17:00	19: 12:00	20:29:00	01:17:00
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									

Load factor
0.19 %