

	Matimba Power Station Emissions report	Matimba Power Station
---	---	------------------------------

Title: **Matimba Power Station March 2022 emissions report** Document Identifier: **RP/247/019**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **39**

Report Date: **March 2022**

Disclosure Classification: **Controlled**

Compiled by



WC Mocke
Environmental Officer

Date: 2022/04/28

Functional Responsibility



MC Mamabolo
Environmental Manager

Date: 06/05/2022

Authorized by



Obakeng Mabotja
General Manager

Date: 2022/05/10

Content

	Page
1. Report Summary	4
2. Emission information	5
2.1 Raw materials and products.....	5
2.2 Abatement technology.....	5
2.3 Energy source characteristics	6
2.4 Emissions reporting.....	6
2.4.1 Particulate Matter Emissions	6
2.4.2 Gaseous Emissions	12
2.4.3 Total Volatile Organic Compounds	24
2.4.4 Greenhouse gas (CO ₂) emissions	25
2.5 Daily power generated	25
2.6 Pollutant Tonnages	32
2.7 Reference values	32
2.8 Continuous Emission Monitors.....	33
2.8.1 Reliability.....	33
2.8.2 Changes, downtime and repairs	34
2.8.3 Sampling dates and times.....	34
2.9 Units Start-up information	35
2.10 Emergency generation	36
2.11 Complaints register	37
2.12 Air quality improvements and social responsibility conducted	37
2.12.1 Air quality improvements.....	37
2.12.2 Social responsibility conducted.....	38
2.13 Ambient air quality monitoring.....	38
2.14 Electrostatic precipitator and Sulphur plant status	38
2.15 General.....	38
3. Attachments.....	39
4. Report Conclusion	39
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	5
Table 2: Abatement Equipment Control Technology Utilised.....	5
Table 3: Energy Source Material Characteristics.	6
Table 4: Total volatile compound estimates	24
Table 5: Daily power generated per unit in MWh for the month of March 2022.....	25
Table 6: Pollutant tonnages for the month of March 2022	32
Table 7: Reference values for data provided, March 2022	32
Table 8: Average percentage (%) availability of monitors for the month of March 2022.	33
Table 9: Start-up information	35

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Emergency generation	36
Table 11: Complaints.....	37

Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 2 for the month of March 2022	7
Figure 2: Particulate matter daily average emissions against emission limit for unit 3 for the month of March 2022	8
Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of March 2022	9
Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of March 2022	10
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of March 2022	11
Figure 6: SO ₂ daily average emissions against emission limit for unit 2 for the month of March 2022.....	13
Figure 7: SO ₂ daily average emissions against emission limit for unit 3 for the month of March 2022.....	14
Figure 8: SO ₂ daily average emissions against emission limit for unit 4 for the month of March 2022.....	15
Figure 9: SO ₂ daily average emissions against emission limit for unit 5 for the month of March 2022.....	16
Figure 10: SO ₂ daily average emissions against emission limit for unit 6 for the month of March 2022.....	17
Figure 11: NO _x daily average emissions against emission limit for unit 2 for the month of March 2022.....	19
Figure 12: NO _x daily average emissions against emission limit for unit 3 for the month of March 2022.....	20
Figure 13: NO _x daily average emissions against emission limit for unit 4 for the month of March 2022.....	21
Figure 14: NO _x daily average emissions against emission limit for unit 5 for the month of March 2022.....	22
Figure 15: NO _x daily average emissions against emission limit for unit 6 for the month of March 2022.....	23
Figure 16: Unit 1 daily generated power in MWh for the month of March 2022.....	26
Figure 17: Unit 2 daily generated power in MWh for the month of March 2022.....	27
Figure 18: Unit 3 daily generated power in MWh for the month of March 2022.....	28
Figure 19: Unit 4 daily generated power in MWh for the month of March 2022.....	29
Figure 20: Unit 5 daily generated power in MWh for the month of March 2022.....	30
Figure 21: Unit 6 daily generated power in MWh for the month of March 2022.....	31

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in November 2021. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for March 2022.



During the period under review, no exceedances of the daily particulate matter emission limit ($50\text{mg}/\text{Nm}^3$), monthly SO_x limit ($3500\text{mg}/\text{Nm}^3$) or the daily NO_x emission limit ($750\text{mg}/\text{Nm}^3$) occurred.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	1 055 874
	Fuel Oil	Tons/month	1 200	744,655
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	GWh	4 212.6	1 887,649

The consumption rates for the month of March 2022 were within the permitted maximum limit.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99,9%
Unit 2	Electrostatic Precipitator	100%	99,9%
Unit 3	Electrostatic Precipitator	100%	99,9%
Unit 4	Electrostatic Precipitator	100%	99,9%
Unit 5	Electrostatic Precipitator	100%	99,9%
Unit 6	Electrostatic Precipitator	100%	99,9%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO ₃ Plant	100%	80,65%
Unit 2	SO ₃ Plant	100%	96,77%
Unit 3	SO ₃ Plant	100%	96,77%
Unit 4	SO ₃ Plant	100%	96,77%
Unit 5	SO ₃ Plant	100%	100%
Unit 6	SO ₃ Plant	100%	100%

Flue gas conditioning plant availability was below the required 100% for unit 1, unit 2, unit 3 and unit 4 due to unexpected breakdowns and low loads. The defects were addressed, and the plants are operational.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3 Energy source characteristics

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1,369
	Ash Content	40%	34,953

Energy source characteristics remained within the ranges stipulated in the license.

2.4 Emissions reporting

2.4.1 Particulate Matter Emissions

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of March 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of March 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of March 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of March 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³. Unit 4 was off for maintenance from 28 February 2022, the unit was back on load on 24 March 2022.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of March 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 Particulate Emissions




Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of March 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.2 Gaseous Emissions

Unit 1 SO₂ Emissions




Figure 7: SO₂ daily average emissions against emission limit for unit 1 for the month of March 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO₂ Emissions




Figure 8: SO₂ daily average emissions against emission limit for unit 2 for the month of March 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 SO₂ Emissions




Figure 9: SO₂ daily average emissions against emission limit for unit 3 for the month of March 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO₂ Emissions




Figure 10: SO₂ daily average emissions against emission limit for unit 4 for the month of March 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 SO₂ Emissions




Figure 11: SO₂ daily average emissions against emission limit for unit 5 for the month of March 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 SO₂ Emissions




Figure 12: SO₂ daily average emissions against emission limit for unit 6 for the month of March 2022

Interpretation:

All daily averages remained below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 NO_x Emissions




Figure 13: Figure 14: NOx daily average emissions against emission limit for unit 1 for the month of March 2022

Interpretation:

All daily averages below NOx emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO_x Emissions




Figure 15: NO_x daily average emissions against emission limit for unit 2 for the month of March 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 NO_x Emissions




Figure 16: NO_x daily average emissions against emission limit for unit 3 for the month of March 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 NO_x Emissions




Figure 17: NO_x daily average emissions against emission limit for unit 4 for the month of March 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO_x Emissions




Figure 18: NO_x daily average emissions against emission limit for unit 5 for the month of March 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 NO_x Emissions




Figure 19: NO_x daily average emissions against emission limit for unit 6 for the month of March 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Wednesday, 13 April 2022	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
MONTHLY INPUT DATA FOR THE STATION Please only insert relevant monthly data inputs into the blue cells below Choose from a dropdown menu in the green cells The total VOC emissions for the month are in the red cells IMPORTANT: Do not change any other cells without consulting the AQ CoE		
MONTH:	March	
GENERAL INFORMATION:	Data	Unit
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	744,655	
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
METEROLOGICAL DATA FOR THE MONTH	Data	Unit
Daily average ambient temperature	23,67	°C
Daily maximum ambient temperature	30,21	°C
Daily minimum ambient temperature	17,89	°C
Daily ambient temperature range	12,31	°C
Daily total insolation factor	5,08	kWh/m ² /day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
FINAL OUTPUT:	Result	Unit
Breathing losses:	0,55 kg/month	
Working losses:	0,02 kg/month	
TOTAL LOSSES (Total TVOC Emissions for the month):	0,57 kg/month	
*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Trittech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

2.5 Daily power generated

Table 5: Daily power generated per unit in MWh for the month of March 2022

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2022/03/01	7725	13226	14854	0	10111	13223
2022/03/02	7752	13990	14858	0	14041	12973
2022/03/03	13267	13714	14953	0	14341	12778
2022/03/04	12178	12837	14878	0	14079	12926
2022/03/05	13057	13487	14811	0	12506	13188
2022/03/06	13160	12194	15056	0	12479	13286
2022/03/07	12592	13193	13997	0	4272	13121
2022/03/08	12641	13252	14474	0	0	13177
2022/03/09	12958	12656	14399	0	0	13261
2022/03/10	10108	13012	14120	0	0	13012
2022/03/11	11886	13714	14626	0	3657	13394
2022/03/12	13301	14054	13995	0	12202	12750
2022/03/13	11769	11808	12085	0	12043	11903
2022/03/14	12369	13674	13250	0	13981	12824
2022/03/15	12476	13096	14271	0	15038	13266
2022/03/16	14023	14132	13758	0	14229	12857
2022/03/17	15149	14264	15491	0	14210	13212
2022/03/18	14991	14755	14425	0	14313	13139
2022/03/19	14645	14858	14832	0	15468	12009
2022/03/20	13149	13171	13340	0	13558	12146
2022/03/21	14004	14311	11570	0	15258	12305
2022/03/22	13369	14276	14496	0	14786	11988
2022/03/23	13690	14163	14778	0	15164	12491
2022/03/24	11931	12707	13854	3401	13377	12476
2022/03/25	11912	12385	12986	11945	13701	12655
2022/03/26	12533	12440	12333	12048	12414	12045
2022/03/27	12679	13533	12469	13152	13143	10974
2022/03/28	12689	13708	12829	12695	12830	12510
2022/03/29	12594	13559	13629	13211	13641	12658
2022/03/30	13273	13602	14801	14426	14998	12778
2022/03/31	13833	14006	14983	14241	15224	12130

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 1 daily generated power in MWh for the month of March 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 21: Unit 2 daily generated power in MWh for the month of March 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 22: Unit 3 daily generated power in MWh for the month of March 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 23: Unit 4 daily generated power in MWh for the month of March 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 24: Unit 5 daily generated power in MWh for the month of March 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 25: Unit 6 daily generated power in MWh for the month of March 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.6 Pollutant Tonnages

The emitted pollutant tonnages for March 2022 are provided in table 6. Averaged Quality Assurance level 2 (QAL 2) values were used for CO₂ data for Unit 1, averaged data was used for oxygen data for 1 to 3 March 2022 due to the monitor readings being unreliable. Averaged Quality Assurance level 2 (QAL 2) values were used for CO₂ and oxygen data for Unit 2 and Oxygen data for unit 3. CO₂ Values for unit 4 and unit 5 was calculated as per balance based on the O₂ values. These values were used due to the monitor providing unreliable values. Matimba is currently in the process of implementing recommended changes on this monitor to improve the reliability of the data.

Table 6: Pollutant tonnages for the month of March 2022

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	66,4	4 360,4	713,7
Unit 2	38,2	9 937,5	1 714,3
Unit 3	52,5	6 298,8	1 208,8
Unit 4	17,0	1 336,1	293,2
Unit 5	36,1	3 700,3	619,5
Unit 6	38,9	5 917,8	963,0
SUM	249,2	31 551,0	5 512,5

2.7 Reference values

Table 7: Reference values for data provided, March 2022

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	9,78	7,70	7,72	6,12	8,24	8,14
Moisture	%	4,78	4,87	5,19	3,73	5,29	3,21
Velocity	m/s	23,3	34,7	29,8	24,0	26,5	27,9
Temperature	°C	133,9	132,2	131,9	133,9	122,0	124,9
Pressure	mBar	933,3	1 191,1	914,6	919,7	934,2	921,7

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8 Continuous Emission Monitors

2.8.1 Reliability

CO₂ monitor reliability for units 1, 2, 4, 5 and 6 performed below the required 80% reliability as per the AEL. The monitors for these units were 100% available for March 2022 however the data received were removed and replaced with calculated values and averaged values due to values received from the monitors not being reliable.

Averaged Quality Assurance level 2 (QAL 2) values were used for CO₂ data for Unit 1, averaged data was used for oxygen data for 1 to 3 March 2022 due to the monitor readings being unreliable. Averaged Quality Assurance level 2 (QAL 2) values were used for CO₂ and oxygen data for Unit 2 and Oxygen data for unit 3. CO₂ Values for unit 4 and unit 5 was calculated as per balance based on the O₂ values.

Table 8: Average percentage (%) availability of monitors for the month of March 2022.

Associated Unit/Stack	PM	SO ₂	NO	CO ₂
Unit 1	100,0	100,0	99,3	0,0
Unit 2	100,0	99,6	99,7	0,0
Unit 3	100,0	100,0	100,0	100,0
Unit 4	100,0	100,0	100,0	0,0
Unit 5	100,0	100,0	100,0	0,0
Unit 6	100,0	100,0	100,0	100,0

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8.2 Changes, downtime and repairs

Unit 1

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 2

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 3

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 4

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 5

- U No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 6

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

2.8.3 Sampling dates and times

Continuous

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.9 Units Start-up information

Table 9: Start-up information

Unit	4	
Fires in	2022/03/23	15H54
Synchronization with Grid	2022/03/24	02H56
Emissions below limit	2022/03/24	07H27
Fires in to synchronization	11,03	HOURS
Synchronization to < Emission limit	4,52	HOURS

Unit	4	
Fires in	2022/03/24	10H34
Synchronization with Grid	2022/03/24	15H18
Emissions below limit	2022/03/24	17H12
Fires in to synchronization	4,73	HOURS
Synchronization to < Emission limit	1,9	HOURS

Unit	5	
Fires in	2022/03/11	07H21
Synchronization with Grid	2022/03/11	12H34
Emissions below limit	2022/03/11	14H52
Fires in to synchronization	5,22	HOURS
Synchronization to < Emission limit	2,3	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10 Emergency generation

Table 10: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	308	308	308	41	208	308
Emergency Hours declared including hours after stand down	329	329	329	47	229	329
Days over the Limit during Emergency Generation	0	0	0	0	0	0

No exceedances occurred in March 2022.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.11 Complaints register

Table 11: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
Pieter Pieterse	Normal ash dump operations were altered as a result of ash disposal space constraints	Average fugitive dust fallout from March to December 2021 in direction of property where complaint originated from: 494 mg/m ² /day	N/A	Acquire additional resources to manage dust suppression system.	Completed
				Connect additional dust suppression equipment (pipeline)	31 March 2022
Manketti Lodge	Dumping and storage of ash at the emergency ash offloading area and increased particulate matter emissions from stacks.	Average fugitive dust fallout from November 2021 to February 2022 in direction of property where complaint originated from: 933 mg/m ² /day and 728 mg/m ² /day	N/A	Investigate feasibility of installing dust suppression system at the emergency ash offloading facility.	13 July 2022

2.12 Air quality improvements and social responsibility conducted

2.12.1 Air quality improvements

None

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.12.2 Social responsibility conducted

None

2.13 Ambient air quality monitoring

There were no exceedances recorded in the reporting period.

Ambient NO₂ concentrations at Marapong monitoring site show influence of emissions from low level sources in the area and ambient SO₂, PM_{2.5} and PM₁₀ concentrations are contributed to by emissions from both low level and high-level sources.

The average data recovery for the period was 81.6% and the station availability was 100%.

Detailed results can be found in Attachment 1, "Marapong Monthly Report_March 2022".

2.14 Electrostatic precipitator and Sulphur plant status

Unit 1

- 3 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

Unit 2

- All precipitator fields in service.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

Unit 3

- All precipitator fields in service.
- Unit 3 Variable speed drive failed and was replaced.

Unit 4

- 1 field out of service, will be inspected next opportunity.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

Unit 5

- 1 field out of service, will be inspected next opportunity.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

Unit 6

- All precipitator fields in service.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

SO₃ common plant

- No abnormalities on the sulphur storage plant.

2.15 General

Name and reference number of the monitoring method used:

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

N/A

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



Obakeng Mabotja
GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.