

KOMATI POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP313/12/12



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Mar-2022
	Coal	Tons	460 000	43 794
	Fuel Oil	Tons	5 000	101
Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Mar-2022
	Energy	GWh	707	69
	Ash	Tons	160 000	17
	RE PM	kg/MWh	0.29	0.24

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	16-24	22.990
Sulphur Content	%	<= 1.2	0.600
Ash Content	%	<= 33	20.841

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SOx	NOx
East	100	3500	1300
West	100	3500	1300

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Mar-2022	Technology Type	Utilisation Mar-2022
Unit 1	Electro Static Precipitators (ESP)	Unit Off-line	SO ₃ Plant Utilisation	Unit Off-line
Unit 2	Electro Static Precipitators (ESP)	Unit Off-line	SO ₃ Plant Utilisation	Unit Off-line
Unit 3	Electro Static Precipitators (ESP)	Unit Off-line	SO ₃ Plant Utilisation	Unit Off-line
Unit 4	Electro Static Precipitators (ESP)	Unit Off-line	SO ₃ Plant Utilisation	Unit Off-line
Unit 5	Electro Static Precipitators (ESP)	Unit Off-line	SO ₃ Plant Utilisation	Unit Off-line
Unit 6	Electro Static Precipitators (ESP)	Unit Off-line	SO ₃ Plant Utilisation	Unit Off-line
Unit 7	Electro Static Precipitators (ESP)	Unit Off-line	SO ₃ Plant Utilisation	Unit Off-line
Unit 8	Electro Static Precipitators (ESP)	Unit Off-line	SO ₃ Plant Utilisation	Unit Off-line
Unit 9	Electro Static Precipitators (ESP)	99.8%	SO ₃ Plant Utilisation	0.0

*Note: The ESP plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	CO ₂	O ₂	Temp
East						
West	100.0	93.6	97.4	93.4	93.6	99.9

6 EMISSION PERFORMANCE

Table 4: Monthly tonnages for the month of March-2022

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO ₂ (tons)	CO ₂ (tons)
1	0.0	0.0	0.0	0
2	0.0	0.0	0.0	0
3	0.0	0.0	0.0	0
4	0.0	0.0	0.0	0
5	0.0	0.0	0.0	0
6	0.0	0.0	0.0	0
7	0.0	0.0	0.0	0
8	0.0	0.0	0.0	0
9	16.7	440.1	616.5	88 719
SUM	16.7	440.1	616.5	88 719

Table 6.2: Operating days in compliance to PM AEL Limit - March 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
East	0	0	0	0	0	
West	26	1	0	0	1	36.8
SUM	26	1	0	0	1	

Table 6.3: Operating days in compliance to SOx AEL Limit - March 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm ³)
East	0	0	0	0	0	
West	30	0	0	0	0	888.4
SUM	30	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - March 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm ³)
East	0	0	0	0	0	
West	28	0	0	2	2	1 209.7
SUM	28	0	0	2	2	

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contravention	Red	Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Komati East Stack PM Emissions - March 2022




Figure 2: Komati West Stack PM Emissions - March 2022




Figure 3: Komati East Stack SOx Emissions - March 2022




Figure 4: Komati West Stack SOx Emissions - March 2022




Figure 5: Komati East Stack NOx Emissions - March 2022





Figure 6: Komati West Stack NOx Emissions - March 2022



7 SHUT DOWN AND LIGHT UP INFORMATION

Table 6.1. PM Start-up information for the month of March-2022

East Stack	<i>Event 1</i>		<i>Event 2</i>		<i>Event 3</i>		<i>Event 4</i>	
Unit No.	<i>no event</i>		<i>no event</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

East Stack ...continued	<i>Event 5</i>		<i>Event 6</i>		<i>Event 7</i>		<i>Event 8</i>	
Unit No.	<i>no event</i>		<i>no event</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

West Stack	<i>Event 1</i>		<i>Event 2</i>		<i>Event 3</i>		<i>Event 4</i>	
Unit No.	<i>Unit 9</i>		<i>Unit 9</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)	<i>11:45 PM</i>	<i>2022/03/22</i>	<i>5:55 AM</i>	<i>2022/03/30</i>	<i>12:35 AM</i>	<i>2022/03/23</i>		
Draught Group (DG) Shut Down (SD)	<i>12:05 AM</i>	<i>2022/03/23</i>	<i>9:25 PM</i>	<i>2022/03/30</i>	<i>2:05 AM</i>	<i>2022/03/23</i>		
BO to DG SD (duration)	<i>00:00:20</i>	DD:HH:MM	<i>00:15:30</i>	DD:HH:MM	<i>00:01:30</i>	DD:HH:MM		DD:HH:MM
Fires in time	<i>12:50 PM</i>	<i>2022/02/27</i>	<i>2:10 AM</i>	<i>2022/03/23</i>				
Synch. to Grid (or BC)	<i>3:15 AM</i>	<i>2022/03/01</i>	<i>5:40 AM</i>	<i>2022/03/24</i>				
Fires in to BC (duration)	<i>01:14:25</i>	DD:HH:MM	<i>01:03:30</i>	DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>				
Emissions below limit from BC (duration)	<i>n/a</i>	DD:HH:MM	<i>n/a</i>	DD:HH:MM		DD:HH:MM		DD:HH:MM

West Stack ...continued	<i>Event 5</i>		<i>Event 6</i>		<i>Event 7</i>		<i>Event 8</i>	
Unit No.	<i>no event</i>		<i>no event</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

7.2: Point Source emissions released during start-up (fires-in) and Shut-down (SD) for the month of March-2022 in mg/Nm³

[Include reference to once off test showing typical emissions rates during fires in and SD]

Remember to add attachments here; see ReportAddendum Tab

Reserved for Addendum XXXX

