

| | | |
|---|---|------------------------------|
|  | Matimba Power Station Emissions report | Matimba Power Station |
|---|---|------------------------------|

Title: **Matimba Power Station April 2022 emissions report**

Document Identifier: **RP/247/021**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **38**

Report Date: **April 2022**


Disclosure Classification: **Controlled**

Compiled by

Functional Responsibility

Authorized by





pp

WC Mocke
Environmental Officer

MC Mamabolo
Environmental Manager

Obakeng Mabotja
General Manager

Date: 2022/05/31

Date: 03/06/2022

Date: 2022/06/03

Content

| | Page |
|--|------|
| 1. Report Summary | 4 |
| 2. Emission information | 5 |
| 2.1 Raw materials and products..... | 5 |
| 2.2 Abatement technology..... | 5 |
| 2.3 Energy source characteristics | 6 |
| 2.4 Emissions reporting..... | 6 |
| 2.4.1 Particulate Matter Emissions | 6 |
| 2.4.2 Gaseous Emissions | 12 |
| 2.4.3 Total Volatile Organic Compounds | 24 |
| 2.4.4 Greenhouse gas (CO ₂) emissions | 25 |
| 2.5 Daily power generated | 25 |
| 2.6 Pollutant Tonnages | 32 |
| 2.7 Reference values | 32 |
| 2.8 Continuous Emission Monitors..... | 33 |
| 2.8.1 Reliability..... | 33 |
| 2.8.2 Changes, downtime and repairs | 34 |
| 2.8.3 Sampling dates and times..... | 34 |
| 2.9 Units Start-up information | 35 |
| 2.10 Emergency generation | 36 |
| 2.11 Complaints register | 36 |
| 2.12 Air quality improvements and social responsibility conducted | 37 |
| 2.12.1 Air quality improvements..... | 37 |
| 2.12.2 Social responsibility conducted..... | 37 |
| 2.13 Ambient air quality monitoring..... | 37 |
| 2.14 Electrostatic precipitator and Sulphur plant status | 37 |
| 2.15 General..... | 38 |
| 3. Attachments..... | 38 |
| 4. Report Conclusion | 38 |
| Table 1: Quantity of Raw Materials and Products used/produced for the month..... | 5 |
| Table 2: Abatement Equipment Control Technology Utilised..... | 5 |
| Table 3: Energy Source Material Characteristics. | 6 |
| Table 4: Total volatile compound estimates | 24 |
| Table 5: Daily power generated per unit in MWh for the month of April 2022..... | 25 |
| Table 6: Pollutant tonnages for the month of April 2022 | 32 |
| Table 7: Reference values for data provided, April 2022 | 32 |
| Table 8: Average percentage (%) availability of monitors for the month of April 2022. | 33 |
| Table 9: Start-up information | 35 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

| | |
|--------------------------------------|----|
| Table 10: Emergency generation | 36 |
| Table 11: Complaints..... | 36 |

Figures

| | |
|--|----|
| Figure 1: Particulate matter daily average emissions against emission limit for unit 2 for the month of April 2022 | 7 |
| Figure 2: Particulate matter daily average emissions against emission limit for unit 3 for the month of April 2022 | 8 |
| Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of April 2022 | 9 |
| Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of April 2022 | 10 |
| Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of April 2022 | 11 |
| Figure 6: SO ₂ daily average emissions against emission limit for unit 2 for the month of April 2022..... | 13 |
| Figure 7: SO ₂ daily average emissions against emission limit for unit 3 for the month of April 2022..... | 14 |
| Figure 8: SO ₂ daily average emissions against emission limit for unit 4 for the month of April 2022..... | 15 |
| Figure 9: SO ₂ daily average emissions against emission limit for unit 5 for the month of April 2022..... | 16 |
| Figure 10: SO ₂ daily average emissions against emission limit for unit 6 for the month of April 2022..... | 17 |
| Figure 11: NO _x daily average emissions against emission limit for unit 2 for the month of April 2022..... | 19 |
| Figure 12: NO _x daily average emissions against emission limit for unit 3 for the month of April 2022..... | 20 |
| Figure 13: NO _x daily average emissions against emission limit for unit 4 for the month of April 2022..... | 21 |
| Figure 14: NO _x daily average emissions against emission limit for unit 5 for the month of April 2022..... | 22 |
| Figure 15: NO _x daily average emissions against emission limit for unit 6 for the month of April 2022..... | 23 |
| Figure 16: Unit 1 daily generated power in MWh for the month of April 2022..... | 26 |
| Figure 17: Unit 2 daily generated power in MWh for the month of April 2022..... | 27 |
| Figure 18: Unit 3 daily generated power in MWh for the month of April 2022..... | 28 |
| Figure 19: Unit 4 daily generated power in MWh for the month of April 2022..... | 29 |
| Figure 20: Unit 5 daily generated power in MWh for the month of April 2022..... | 30 |
| Figure 21: Unit 6 daily generated power in MWh for the month of April 2022..... | 31 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in November 2021. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for April 2022.



During the period under review, two exceedances of the daily particulate matter emission limit ($50\text{mg}/\text{Nm}^3$) occurred. No exceedances of the monthly SO_x limit ($3500\text{mg}/\text{Nm}^3$) or the daily NO_x emission limit ($750\text{mg}/\text{Nm}^3$) occurred.

The ambient air quality monitoring station has been experiencing power failures due to cable and electricity theft from the local community. This led to low availability of the monitoring station.

More information regarding above mentioned issues is provided in the relevant sections within the report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month

| Raw Materials and Products used | Raw Material Type | Unit | Maximum Permitted Consumption Rate (Quantity) | Consumption Rate |
|---------------------------------|--------------------------|------------|--|------------------|
| | Coal | Tons/month | 1 500 000 | 1 194 453 |
| | Fuel Oil | Tons/month | 1 200 | 582,998 |
| Production Rates | Product/ By-Product Name | Unit | Maximum Production Capacity Permitted (Quantity) | Production Rate |
| | Energy | GWh | 4 212.6 | 2 089,159 |
| | | | | |

The consumption rates for the month of April 2022 were within the permitted maximum limit.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

| Associated Unit | Technology Type | Minimum utilisation (%) | Efficiency (%) |
|-----------------|----------------------------|-------------------------|------------------------|
| Unit 1 | Electrostatic Precipitator | 100% | 99,89% |
| Unit 2 | Electrostatic Precipitator | 100% | 99,93% |
| Unit 3 | Electrostatic Precipitator | 100% | 99,91% |
| Unit 4 | Electrostatic Precipitator | 100% | 99,89% |
| Unit 5 | Electrostatic Precipitator | 100% | 99,93% |
| Unit 6 | Electrostatic Precipitator | 100% | 99,93% |
| Associated Unit | Technology Type | Minimum utilisation (%) | Actual Utilisation (%) |
| Unit 1 | SO ₃ Plant | 100% | 96,45% |
| Unit 2 | SO ₃ Plant | 100% | 99,85% |
| Unit 3 | SO ₃ Plant | 100% | 99,23% |
| Unit 4 | SO ₃ Plant | 100% | 93,76% |
| Unit 5 | SO ₃ Plant | 100% | 92,78% |
| Unit 6 | SO ₃ Plant | 100% | 95,68% |

Flue gas conditioning plant availability was below the required 100% for unit 1, unit 4, unit 5 and unit 6 due to unexpected breakdowns and low loads. The defects were addressed, and the plants are operational.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3 Energy source characteristics

Table 3: Energy Source Material Characteristics.

| | Characteristic | Stipulated Range (Unit) | Monthly Average Content |
|-------------|-----------------|-------------------------|-------------------------|
| Coal burned | Sulphur Content | 1.6% | 1,196 |
| | Ash Content | 40% | 32,332 |

Energy source characteristics remained within the ranges stipulated in the license.

2.4 Emissions reporting

2.4.1 Particulate Matter Emissions

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of April 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of April 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of April 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of April 2022

Interpretation:

Unit 4 exceeded the 50 mg/Nm³ limit on 19 April 2022 and 30 April 2022. The exceedance on 19 April 2022 was due to breakdowns on the ash handling plant causing ash backlogs within the flue gas stream, reducing the efficiency of the Electrostatic Precipitators. The exceedance on 30 April 2022 was due to extended light-up conditions that occurred during light-up after the unit tripped on 23 April 2022. Both of these exceedances remained within the 48 hour grace period.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of April 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 Particulate Emissions




Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of April 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.2 Gaseous Emissions

Unit 1 SO₂ Emissions




Figure 7: SO₂ daily average emissions against emission limit for unit 1 for the month of April 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 SO₂ Emissions

Figure 8: SO₂ daily average emissions against emission limit for unit 2 for the month of April 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 SO₂ Emissions

Figure 9: SO₂ daily average emissions against emission limit for unit 3 for the month of April 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 SO₂ Emissions

Figure 10: SO₂ daily average emissions against emission limit for unit 4 for the month of April 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 5 SO₂ Emissions

Figure 11: SO₂ daily average emissions against emission limit for unit 5 for the month of April 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 SO₂ Emissions

Figure 12: SO₂ daily average emissions against emission limit for unit 6 for the month of April 2022

Interpretation:

All daily averages remained below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 1 NO_x Emissions

Figure 13: Figure 14: NO_x daily average emissions against emission limit for unit 1 for the month of April 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 NO_x Emissions

Figure 15: NO_x daily average emissions against emission limit for unit 2 for the month of April 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 NO_x Emissions

Figure 16: NO_x daily average emissions against emission limit for unit 3 for the month of April 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 NO_x Emissions

Figure 17: NO_x daily average emissions against emission limit for unit 4 for the month of April 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 5 NO_x Emissions

Figure 18: NO_x daily average emissions against emission limit for unit 5 for the month of April 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 NO_x Emissions

Figure 19: NO_x daily average emissions against emission limit for unit 6 for the month of April 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

| | | |
|--|--|-------------|
|  | | |
| CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS* | | |
| Date: | Wednesday, 25 May 2022 | |
| Station: | Matimba Power Station | |
| Province: | Limpopo Province | |
| Tank no. | 1-4 | |
| Description: | Outdoor fuel oil storage tank | |
| Tank Type: | Vertical fixed roof (vented to atmosphere) | |
| Material stored: | Fuel Oil 150 | |
| <p align="center">MONTHLY INPUT DATA FOR THE STATION</p> <p align="center">Please only insert relevant monthly data inputs into the <u>blue cells</u> below</p> <p align="center">Choose from a dropdown menu in the <u>green cells</u></p> <p align="center">The total VOC emissions for the month are in the <u>red cells</u></p> <p align="center">IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE</p> | | |
| MONTH: | April | |
| GENERAL INFORMATION: | Data | Unit |
| Total number of fuel oil tanks: | 4 | NA |
| Height of tank: | 13,34 | m |
| Diameter of tank: | 9,53 | m |
| Net fuel oil throughput for the month: | 582,998 | |
| Molecular weight of the fuel oil: | 166,00 | Lb/lb-mole |
| METEOROLOGICAL DATA FOR THE MONTH | Data | Unit |
| Daily average ambient temperature | 20,60 | °C |
| Daily maximum ambient temperature | 27,37 | °C |
| Daily minimum ambient temperature | 13,11 | °C |
| Daily ambient temperature range | 10,46 | °C |
| Daily total insolation factor | 3,84 | kWh/m²/day |
| Tank paint colour | Grey/medium | NA |
| Tank paint solar absorbance | 0,68 | NA |
| FINAL OUTPUT: | Result | Unit |
| Breathing losses: | 0,48 kg/month | |
| Working losses: | 0,02 kg/month | |
| TOTAL LOSSES (Total TVOC Emissions for the month): | 0,50 kg/month | |
| <p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p> | | |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

2.5 Daily power generated

Table 5: Daily power generated per unit in MWh for the month of April 2022

| Date | Unit 1 | Unit 2 | Unit 3 | Unit 4 | Unit 5 | Unit 6 |
|------------|--------|--------|--------|--------|--------|--------|
| 2022/04/01 | 13957 | 14212 | 14510 | 14241 | 15327 | 13226 |
| 2022/04/02 | 12724 | 13453 | 12999 | 12660 | 13078 | 12660 |
| 2022/04/03 | 12904 | 13712 | 13842 | 13237 | 14045 | 12837 |
| 2022/04/04 | 14281 | 14325 | 13818 | 14517 | 14610 | 12500 |
| 2022/04/05 | 12878 | 12593 | 13322 | 13108 | 13404 | 12168 |
| 2022/04/06 | 13093 | 12669 | 13501 | 12741 | 13867 | 11938 |
| 2022/04/07 | 13198 | 13521 | 13932 | 12627 | 14152 | 12778 |
| 2022/04/08 | 13390 | 14223 | 13586 | 13455 | 12364 | 12506 |
| 2022/04/09 | 12358 | 14383 | 13640 | 13549 | 13682 | 12606 |
| 2022/04/10 | 13335 | 14741 | 13770 | 11999 | 13937 | 12532 |
| 2022/04/11 | 14577 | 14277 | 12760 | 12239 | 14797 | 13089 |
| 2022/04/12 | 14542 | 14441 | 14789 | 12438 | 14762 | 13083 |
| 2022/04/13 | 13682 | 13815 | 14448 | 11827 | 14419 | 12351 |
| 2022/04/14 | 14141 | 13216 | 14868 | 12520 | 15080 | 12084 |
| 2022/04/15 | 11708 | 12306 | 13529 | 12134 | 12359 | 11504 |
| 2022/04/16 | 13696 | 11966 | 14383 | 12076 | 0 | 11170 |
| 2022/04/17 | 14454 | 12274 | 15331 | 11992 | 0 | 11088 |
| 2022/04/18 | 12302 | 14008 | 15374 | 14096 | 0 | 11873 |
| 2022/04/19 | 11858 | 15259 | 15479 | 15013 | 0 | 11025 |
| 2022/04/20 | 11949 | 15552 | 15550 | 15217 | 273,6 | 9948 |
| 2022/04/21 | 11963 | 15000 | 15074 | 14629 | 13071 | 10873 |
| 2022/04/22 | 10181 | 15188 | 15177 | 15098 | 11963 | 13223 |
| 2022/04/23 | 15106 | 15716 | 15305 | 9594 | 14077 | 13759 |
| 2022/04/24 | 13293 | 15487 | 15065 | 295 | 15564 | 13753 |
| 2022/04/25 | 13165 | 15293 | 14161 | 0 | 14658 | 12902 |
| 2022/04/26 | 14087 | 15047 | 14110 | 0 | 14659 | 13163 |
| 2022/04/27 | 14323 | 15396 | 14157 | 0 | 14752 | 13343 |
| 2022/04/28 | 13571 | 15041 | 14236 | 0 | 14379 | 13206 |
| 2022/04/29 | 13563 | 14608 | 14373 | 2434 | 14392 | 13103 |
| 2022/04/30 | 11752 | 11867 | 14303 | 14365 | 12902 | 12295 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 1 daily generated power in MWh for the month of April 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 21: Unit 2 daily generated power in MWh for the month of April 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 22: Unit 3 daily generated power in MWh for the month of April 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 23: Unit 4 daily generated power in MWh for the month of April 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 24: Unit 5 daily generated power in MWh for the month of April 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 25: Unit 6 daily generated power in MWh for the month of April 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.6 Pollutant Tonnages

The emitted pollutant tonnages for April 2022 are provided in table 6. Averaged values were used for O₂ data for Unit 1 from 1 to 12 April 2022 due to the oxygen monitor being defective and providing unreliable data. Averaged values were used for CO₂ data for Unit 2 from 1 to 8 April 2022, 12 to 16 April 2022 and 22 to 27 April 2022 due to unreliable data from the monitor. Averaged Quality Assurance level 2 (QAL 2) values were used for CO₂ data for Unit 3 and unit 4 due to the monitor providing unreliable values. Averaged values were used for CO₂ data for Unit 6 from 8, 9, 16, 18, 19, 20 and 21 April 2022 due to unreliable data from the monitor. Matimba is currently in the process of implementing recommended changes on this monitor to improve the reliability of the data.

Table 6: Pollutant tonnages for the month of April 2022

| Associated Unit/Stack | PM (tons) | SO ₂ (tons) | NO _x (tons) |
|-----------------------|-----------|------------------------|------------------------|
| Unit 1 | 67,2 | 4 099,6 | 688,7 |
| Unit 2 | 44,4 | 9 609,3 | 1 692,8 |
| Unit 3 | 60,7 | 5 940,1 | 1 140,6 |
| Unit 4 | 54,3 | 4 007,8 | 946,7 |
| Unit 5 | 37,2 | 3 483,9 | 595,8 |
| Unit 6 | 41,0 | 5 405,8 | 929,2 |
| SUM | 304,9 | 32 546,6 | 5 993,8 |

2.7 Reference values

Table 7: Reference values for data provided, April 2022

| Compound / Parameter | Units of Measure | Unit 1 | Unit 2 | Unit 3 | Unit 4 | Unit 5 | Unit 6 |
|----------------------|------------------|--------|---------|--------|--------|--------|--------|
| Oxygen | % | 5,47 | 9,50 | 5,91 | 6,53 | 8,56 | 8,98 |
| Moisture | % | 5,02 | 4,98 | 5,47 | 3,97 | 5,69 | 3,22 |
| Velocity | m/s | 24,5 | 35,5 | 29,8 | 23,9 | 25,9 | 27,8 |
| Temperature | °C | 134,8 | 131,1 | 130,1 | 133,9 | 120,6 | 124,3 |
| Pressure | mBar | 933,6 | 1 192,6 | 916,8 | 920,4 | 925,5 | 923,6 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8 Continuous Emission Monitors

2.8.1 Reliability

CO₂ monitor reliability for units 1, 2, 4, 5 and 6 performed below the required 80% reliability as per the AEL. The monitors for these units were 100% available for April 2022 however the data received were removed and replaced with calculated values and averaged values due to values received from the monitors not being reliable.

Averaged Quality Assurance level 2 (QAL 2) values were used for CO₂ data for Unit 1, averaged data was used for oxygen data for 1 to 3 April 2022 due to the monitor readings being unreliable. Averaged Quality Assurance level 2 (QAL 2) values were used for CO₂ and oxygen data for Unit 2 and Oxygen data for unit 3. CO₂ Values for unit 4 and unit 5 was calculated as per balance based on the O₂ values.

Table 8: Average percentage (%) availability of monitors for the month of April 2022.

| Associated Unit/Stack | PM | SO ₂ | NO | CO ₂ |
|-----------------------|-------|-----------------|-------|-----------------|
| Unit 1 | 100,0 | 99,9 | 99,7 | 99,9 |
| Unit 2 | 99,9 | 92,1 | 92,1 | 42,1 |
| Unit 3 | 100,0 | 99,9 | 99,9 | 0,0 |
| Unit 4 | 100,0 | 99,8 | 99,8 | 0,0 |
| Unit 5 | 100,0 | 100,0 | 100,0 | 99,7 |
| Unit 6 | 100,0 | 100,0 | 100,0 | 76,7 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8.2 Changes, downtime and repairs

Unit 1

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 2

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 3

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 4

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 5

- U No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 6

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

2.8.3 Sampling dates and times

Continuous

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.9 Units Start-up information

Table 9: Start-up information

| | | |
|---|------------|-------|
| Unit | 4 | |
| Fires in | 2022/04/23 | 12h45 |
| Synchronization with Grid | 2022/04/23 | 16h27 |
| Emissions below limit | 2022/04/23 | 17H00 |
| Fires in to synchronization | 3,7 | HOURS |
| Synchronization to < Emission limit | 0,55 | HOURS |

| | | |
|---|------------|-------|
| Unit | 4 | |
| Fires in | 2022/04/24 | 16H20 |
| Synchronization with Grid | 2022/04/24 | 19H45 |
| Emissions below limit | 2022/04/24 | 19H45 |
| Fires in to synchronization | 3,42 | HOURS |
| Synchronization to < Emission limit | 0 | HOURS |

| | | |
|---|------------|-------|
| Unit | 4 | |
| Fires in | 2022/04/29 | 04H33 |
| Synchronization with Grid | 2022/04/29 | 18H18 |
| Emissions below limit | 2022/04/29 | 18H18 |
| Fires in to synchronization | 13,75 | HOURS |
| Synchronization to < Emission limit | 0 | HOURS |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

| | | |
|---|------------|-------|
| Unit | 5 | |
| Fires in | 2022/04/20 | 17H16 |
| Synchronization with Grid | 2022/04/20 | 22H17 |
| Emissions below limit | 2022/04/21 | 00H00 |
| Fires in to synchronization | 5,02 | HOURS |
| Synchronization to < Emission limit | 1,72 | HOURS |

2.10 Emergency generation

Table 10: Emergency generation

| | Unit 1 | Unit 2 | Unit 3 | Unit 4 | Unit 5 | Unit 6 |
|--|---------------|---------------|---------------|---------------|---------------|---------------|
| Emergency Generation hours declared by national Control | 460,85 | 460,85 | 460,85 | 430,15 | 230,2 | 460,85 |
| Emergency Hours declared including hours after stand down | 481,85 | 481,85 | 481,85 | 446,15 | 249,2 | 481,85 |
| Days over the Limit during Emergency Generation | 0 | 0 | 0 | 1 | 0 | 0 |

Unit 4 exceeded the 50mg/Nm³ limit for one day during emergency generation, on 30 April 2022.

2.11 Complaints register

Table 11: Complaints

| Source Code/ Name | Root Cause Analysis | Calculation of Impacts/ emissions associated with the incident | Dispersion modelling of pollutants where applicable | Measures implemented to prevent reoccurrence | Date by which measure will be implemented |
|------------------------------|--------------------------------|---|--|---|--|
| N/A | | | | | |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.12 Air quality improvements and social responsibility conducted

2.12.1 Air quality improvements

None

2.12.2 Social responsibility conducted

None

2.13 Ambient air quality monitoring

There were two exceedances recorded for the PM_{2.5} daily limit and five exceedances for the PM₁₀ daily limit during the period under review. There were no other exceedances recorded for all other parameters monitored.

Ambient NO₂ concentrations at Marapong monitoring site show influence of emissions from low level sources in the area and ambient SO₂, PM_{2.5} and PM₁₀ concentrations are contributed to by emissions from both low level and high-level sources.

The average data recovery for the period was 50,1% and the station availability was 58,3%. Low availability was due to cable theft that occurred during the month. The local municipal authorities have been contacted for intervention.

Detailed results can be found in Attachment 1, "Marapong Monthly Report_April 2022".

2.14 Electrostatic precipitator and Sulphur plant status

Unit 1

- 3 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

Unit 2

- All precipitator fields in service.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

Unit 3

- All precipitator fields in service.
- Unit 3 Variable speed drive failed and was replaced.

Unit 4

- 1 field out of service, will be inspected next opportunity.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

Unit 5

- 1 field out of service, will be inspected next opportunity.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

Unit 6

- All precipitator fields in service.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

SO₃ common plant

- No abnormalities on the sulphur storage plant.

2.15 General

Name and reference number of the monitoring method used:

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

N/A


4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



pp

GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.