

Mr. Vusi Mahlangu Air Quality Officer DEDET Private bag X11215 NELSPRUIT 1200 Date: 20 June 2022

Enquiries: Mariam Joseph Tel +27 13 297 9

Tel +27 13 297 9828 Fax + 27 86 661 7663

Dear Mr. Mahlangu

# ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL 2022

This serves as the monthly report required in terms of Section 6 in Arnot Power Station's Atmospheric Emission License. The emissions are for the month of April 2022, verified emissions of particulates; SO<sub>2</sub> and NO<sub>x</sub> (as NO<sub>2</sub>) are also included.

### **Raw Materials and Products**

Table1: Quantity of Raw Materials and Products used/produced for the Month of April 2022

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption/ Rate in Month of April 2022
	Coal	Tons/month	1 050 330	295 852 .24
	Fuel Oil	Tons/month	10 000	3 659.92
	Product/ By- Product Name	Unit	Maximum Production	Production Rate in Month of April
Production Rates	Product Name		Capacity Permitted (Quantity)	2022
Production Rates	Energy	GWh	•	•
Production Rates		GWh Tons/month	(Quantity)	2022

## **Abatement Technology**

Table 2: Abatement Equipment Control Technology for month of April 2022

Associated Unit/Stack	Technology Type	Actual Utilisation (%) for the month of April 2022
North Stack	Fabric Filter Bags	100%
South Stack	Fabric Filter Bags	100%

Table 2.1 Efficiency of Fabric Filter Bags for Month of April 2022

Associated Unit/Stack	Technology Type	Actual Efficiency (%) for the month of April 2022
North Stack	Fabric Filter Bags	99.8%
South Stack	Fabric Filter Bags	99.85

## **Energy Source Characteristics**

Table 3: Energy Source Material Characteristics for the month of April 2022

Characteristic	Stipulated Range (Unit)	Monthly Average Content
Sulphur Content	0.5 to < 1 (%)	0.668
Ash Content	17 to < 40 (%)	24.03

Table 4 Operating days in compliance to PM AEL Limit –April 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm³)
North	30	0	0	0	0	13.6
South	30	0	0	0	0	38.4
SUM	60	0	0	0	0	

Table 5 Operating days in compliance to SOx AEL Limit - April 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm³)
North	30	0	0	0	0	1226.1
South	30	0	0	0	0	
SUM	60	0	0	0	0	

Table 6: Operating days in compliance to Nox AEL Limit –April 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
North	30	0	0	0	0	534.8
South	30	0	0	0	0	
SUM	60	0	0	0	0	

## **Emissions Reporting**




Figure 1: PM emissions (daily averages) for the month of April 2022 against emission limit for the North Stack




Figure 2: PM emissions (daily averages) for the month of April 2022 against emission limit for the South Stack




Figure 3: SO<sub>2</sub> emissions (daily averages) for the month of April 2022 against emission limit for the North Stack




Figure 4: SO<sub>2</sub> emissions (daily averages) for the month of April 2022 against emission limit for the South Stack




Figure 5: NO<sub>2</sub> emissions (daily averages) for the month of April 2022 against emission limit for the North Stack




Figure 6: NO<sub>2</sub> emissions (daily averages) for the month of April 2022 against emission limit for the South Stack

Table 4: Monthly tonnages for the month of April 2021

Unit	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>2</sub> (tons)
Total Tons (North & South Stack)	59.2	852.5	3 78.8

Table 5: Monitor Availability

Unit	PM (%)	SO <sub>2</sub> (%)	NO <sub>2</sub> (%)
North Stack	100.0	97.8	97.8
South Stack	100.0	98.2	99.0

Table 6: Each unit and respective days operating under normal operation, days in grace period, and section 30 days respectively

Unit	Days operating under normal operation	Days operating in grace period	Days operating under S 30	
1	30	0	0	
2	30	0	0	
3	30	0	0	
4	30	0	0	
5	30	0	0	
6	30	0	0	

### Light up information

Continuous reporting is being done even during start-ups, emissions were not affected.

## **Complaints Register**

Table 7. Complaints for the month of April 2022

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implement ed
None					

#### General

New O2 analyzer was installed and still need QAL2 test to be done. Once this is done, the new correction factors shall be back fitted from expiry date of 12 April 2021 and new figures shall be included on the coming monthly report.

Arnot Power station is experiencing unreliability of monitor which affect the South Stack (NOx gaseous emissions) Investigation is currently taking place.

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission reports sent to your office.

Hoping the above will meet your satisfaction.

Compiled by

Lawrence Machebe Date: 20/06/2022

**ENVIRONMENTAL OFFICER: ARNOT POWER STATION** 

Verified by

Jan-Louis Human 24-06-2022
Date:

**SYSTEM ENGINEER: ARNOT POWER STATION** 

Supported by

HOW Kouhas

Rofhiwa Tshikovha Date: 2022.06.20

SENIOR ENVIRONMENTAL ADVISOR: ARNOT POWER STATION

Yours sincerely

Marcus Nematodzi Date: 4 July 2022

**GENERAL MANAGER: ARNOT POWER STATION**