

**KENDAL POWER STATION MONTHLY EMISSIONS REPORT**

Atmospheric Emission License 17/4/AEL/MP312/11/15



**1 RAW MATERIALS AND PRODUCTS**

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate May-2022
	Coal	Tons	2 260 000	955 276
	Fuel Oil	Tons	5 000	1958,78

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate May-2022
	Energy	MWh(MW)	3 153,600 (4380)	3 043 334,00
	Ash	Tons	770 000	313 999,2
	RE Ash	kg/MWh	not specified	0,260

**2 ENERGY SOURCE CHARACTERISTICS**

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	<1 (%)	0,800
Ash Content	%	40 (%)	32,870

**3 EMISSION LIMITS (mg/Nm<sup>3</sup>)**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO <sub>x</sub>
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

#### 4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency May-2022	Technology Type	Utilization May-2022
Unit 1	ESP + SO <sub>2</sub>	99,8%	SO <sub>2</sub>	0,0%
Unit 2	ESP + SO <sub>2</sub>	Off-line	SO <sub>2</sub>	Off-line
Unit 3	ESP + SO <sub>2</sub>	99,9%	SO <sub>2</sub>	0,0%
Unit 4	ESP + SO <sub>2</sub>	99,4%	SO <sub>2</sub>	0,0%
Unit 5	ESP + SO <sub>2</sub>	99,5%	SO <sub>2</sub>	0,0%
Unit 6	ESP + SO <sub>2</sub>	99,7%	SO <sub>2</sub>	0,0%

Unit 1, 2,3,4,5 & 6 sulphur utilization readings not available because KEPDATA04 and KEPDATA05 failed. The hardware is being replaced

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

#### 5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	O <sub>2</sub>
Unit 1	99,4	99,7	99,2	100,0
Unit 2	Off-line	Off-line	Off-line	Off-line
Unit 3	98,7	100,0	100,0	96,5
Unit 4	99,5	99,1	97,2	70,6
Unit 5	99,7	100,0	100,0	99,7
Unit 6	90,1	99,9	100,0	73,0

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO<sub>2</sub>

Unit 3 and 6 O<sub>2</sub> monitor reliability low due to defective monitors

#### 6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of May 2022

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	CO <sub>2</sub>
Unit 1	91,4	0	0	0
Unit 2	Off-line	Off-line	Off-line	Off-line
Unit 3	50,3	2 840	1 052	256 777
Unit 4	228,8	3 924	992	223 751
Unit 5	267,8	4 438	1 620	478 214
Unit 6	148,5	3 601	1 490	292 020
SUM	786,84	14 803	5 154	1 250 763

Table 6.2: Operating days in compliance to PM AEL Limit - May 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm <sup>3</sup> )
Unit 1	25	4	0	0	4	59,9
Unit 2	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
Unit 3	28	3	0	0	3	40,5
Unit 4	25	2	0	4	6	167,3
Unit 5	24	4	0	3	7	137,5
Unit 6	26	3	0	2	5	73,4
SUM	128	16	0	9	25	

Table 6.3: Operating days in compliance to SO<sub>2</sub> AEL Limit - May 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO <sub>x</sub> (mg/Nm <sup>3</sup> )
Unit 1	29	0	0	0	0	-40,3
Unit 2	Off-line	Off-line	Off-line	Off-line	Off-line	Off-line
Unit 3	31	0	0	0	0	1 984,8
Unit 4	31	0	0	0	0	2 381,7
Unit 5	31	0	0	0	0	2 024,2
Unit 6	31	0	0	0	0	2 346,5
SUM	153	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - May 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm <sup>3</sup> )
Unit 1	29	0	0	0	0	-12,6
Unit 2	0	Off-line	Off-line	Off-line	Off-line	Off-line
Unit 3	31	0	0	0	0	734,4
Unit 4	31	0	0	0	0	597,0
Unit 5	31	0	0	0	0	731,5
Unit 6	30	0	0	1	1	971,4
<b>SUM</b>	<b>152</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>1</b>	

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO<sub>2</sub>

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contra-vention	Red	Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Kendal Unit 1 PM Emissions - May 2022





Figure 2: Kendal Unit 2 PM Emissions - May 2022









Figure 7: Kendal Unit 1 SO<sub>2</sub> Emissions - May 2022




Figure 8: Kendal Unit 2 SO<sub>2</sub> Emissions - May 2022




Figure 9: Kendal Unit 3 SO<sub>2</sub> Emissions - May 2022




Figure 10: Kendal Unit 4 SO<sub>2</sub> Emissions - May 2022




Figure 11: Kendal Unit 5 SO<sub>2</sub> Emissions - May 2022




Figure 12: Kendal Unit 6 SO<sub>2</sub> Emissions - May 2022




Figure 13: Kendal Unit 1 NO<sub>x</sub> Emissions - May 2022




Figure 14: Kendal Unit 2 NOx Emissions - May 2022




Figure 15: Kendal Unit 3 NOx Emissions - May 2022




Figure 16: Kendal Unit 4 NOx Emissions - May 2022






Figure 17: Kendal Unit 5 NOx Emissions - May 2022





Unit 6 high NOx emissions can be attributed to burner tils and dampers which were not in correct position and defective O<sub>2</sub> monitor.

**7 COMPLAINTS**

There were no complaints for this months

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

**ADDENDUM TO MONTHLY EMISSIONS REPORT**

**Abatement Technology-Table 4**

In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as

- ☑ Coal ash content (%) and burnt rate mass
- ☑ Fly : Coarse ash ratio of 80:20 - 80% of fly-ash mass obtained from burnt coal goes to ESP
- ☑ Measurement of dust emission by Dust Monitor over a period of time (monthly)

Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \frac{(\text{Dust Emission From AQR Report Dust Monitor (tons)}) \times 100}{(\text{Coal Burnt (tons)} \times \% \text{Ash Content} \times 80\%)}$$

**Monitor Reliability-Table 5**

In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average. The **monitor reliability** refers to **data reliability** because the assumed value of 98% reliability is compared to the dust concentration signal. If the dust concentration signal is above 98% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g 24 hours

The formula is as follows:  
 $= (1 - (\text{count hours above 98\%}/24\text{hours})) \times 100$

**Emissions Performance:**

- Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2, 3, 4 due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- Average emissions for Unit 3 and 6 SO<sub>2</sub>, NO<sub>x</sub>, CO<sub>2</sub>, moisture and Unit 6 flow was used from the QAL2 parallel report due to defective monitors.
- Average emissions for Unit 4 on the 15th and 16th SO<sub>x</sub> and NO<sub>x</sub> was used from QAL2 and flow from the 2020 Correlation report.
- Unit 6 high NO<sub>x</sub> emissions can be attributed to burner tils and dampers are not in correct position.
- Unit 2 was still offload during this month for Genera Overhaul (GO).

**Unit 1**

**Findings:** The high emissions can be attributed to on the light up conditions.  
**Resolution:**

**Unit 3**

**Findings:** The high emissions can be attributed to Unit hot start-up, ash back logs Dust Handling Plant out of service, due to compartment levels high.  
**Resolution:** The DHP was returned back to service after repairs

**Unit 4**

**Findings:** High PM emissions can be attributed to DHP out of service due to compartment levels and SO<sub>3</sub> plant out of service due to water leak on the sulphur line to the units.  
**Resolution:** The plant was repaired

**Unit 5**

**Findings:** High PM emissions can be attributed to DHP standing due to compartments that were full, SO<sub>3</sub> plant out of service due to water leak on the sulphur line to the units, precip field 11 kept on tripping, on the 8th & 9th precip knife gages 1-7 were closed due to DHP top bunker lever high.  
**Resolution:** The DHP was returned back to service after repairs

**Unit 6**

**Findings:** High PM emissions on the 1st can be attributed to precip fields 11-14, 21-25 and 31-34, 41-44 dripped. On the 12th can be attributed to SO<sub>3</sub> plant not running because of burner outlet temperature reading low, and no sulphur flow. On the 18th can be attributed to SO<sub>3</sub> plant on hold mode due to water leak on the sulphur line to the units.  
**Resolutions:** Plant was repaired



