

Ms Mpho Nembilwi

Nkangala District Municipality PO BOX 437 MIDDLEBURG 1050 Date: 5 July 2022

Enquiries:

Livhuwani Tshilate 017 615 2317

Ref: 17/4/AEL/MP312/11/09

Dear Ms Nembilwi

KRIEL POWER STATION'S MONTHLY STACK EMISSIONS REPORT FOR THE MONTH OF APRIL 2022

This serves as the monthly report required in terms of Section 7.4 in Kriel Power Station's Atmospheric Emission License 17/4/AEL/MP312/11/09. The emissions are for the month of April 2022. Verified emissions of particulates matter, SO_2 and NO_x (as NO_2) are also included.

Raw Materials and Products

Table 1: Quantity of Raw Materials and Products used/produced for the month of April 2022

Raw Materials and Products used	Raw Material Type	Units	Maximum Permitted Consumption / Rate (Quantity)	Consumption / Rate in Month of April 2022
uscu	Coal	Tons/month	1 227 600	526 563
	Fuel Oil	Tons/month	5 000	2 042
Production Rates	Product/ By- Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of April 2022
	Ash	Tons/month	not specified	323
	RE PM	kg/MWh	not specified	0.41

1/...

Abatement Technology

Table 2: Abatement Equipment Control Technology for April 2022.

		Actual Efficiency (%)	Utilisation
		April 2022	April 2022
Associated Unit/Stack	Technology Type		
Unit 1	ESP	99.86%	96.3%
Unit 2	ESP	99.84%	33.6%
Unit 3	ESP	99.85%	96.8%
Unit 4	ESP	100.00%	96.8%
Unit 5	ESP	100.00%	5.1%
Unit 6	ESP	Outage	Outage

Energy Source Characteristics

Table 3: Energy Source Material Characteristics for the month of April 2022

Characteristic	Stipulated Range (Unit)	Monthly Average Content
Sulphur Content	0.6-1.2 (%)	0.86
Ash Content	21-36 (%)	24.71

Monthly Monitor Reliability

Associated Unit/Stack	PM (%)	SOx (%)	NOx (%)
North	98.89	0.00	0.00
South	97.92	99.99	100.00

Emissions Reporting

Table 6.5: Graph Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions




Figure 1: PM emissions for the month of April 2022 against emission limit for the North Stack. Monthly average was 32.4 mg/Nm3




Figure 2: PM emissions for the month of April 2022 against emission limit for the South Stack. Monthly average was 120.1 mg/Nm3




Figure 3. SO₂ emissions for the month of April 2022 against emission limit for the North Stack. The SOx Limit is 3500mg/Nm3.




Figure 4. SO₂ emissions for the month of April 2022 against emission limit for the South Stack. The SOx Limit is 3500mg/Nm3.




Figure 5. NO₂ emissions for the month of April 2022 against emission limit for the North Stack. The NOx Limit is 1600mg/Nm3.




Figure 6. NO₂ emissions for the month of April 2022 against emission limit for the South Stack. The NOx Limit is 1600mg/Nm3.

Table 4: Monthly tonnages for the month April 2022

Unit	PM (tons)	SO ₂ (tons)	NO ₂ (tons)	
SUM	323	4 381.0	658.5	

Table 5: Each unit and respective days operating under normal operation and section 30 days respectively

Table 5.1: Operating days in compliance to PM AEL Limit – April 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Monthly Limit Exceedance	Average PM (mg/Nm³)
North	30	0	0	0	0	32.4
South	22	8	0	0	8	120.1

Table 5.2: Operating days in compliance to SOx AEL Limit - April 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm³)
North	30	0	0	0	0	1 209.5
South	30	0	0	0	0	1 501.6

Table 5.3: Operating days in compliance to NOx AEL Limit – April 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
North	30	0	0	0	0	178.5
South	30	0	0	0	0	762.7

Light up information

Table 6: PM Start-up information for the month of April 2022

North Stack		Event 1	
Unit No.	Unit		
Breaker Open (BO)	10:10 AM	2022/04/11	
Draught Group (DG) Shut Down (SD)	8:35 AM	2022/04/12	
BO to DG SD (duration)	00:22:25	DD:HH:MM	
Fires in time			
Synch. to Grid (or BC)			
Fires in to BC (duration)		DD:HH:MM	
Emissions below limit from BC (end date)			
Emissions below limit from BC (duration)		DD:HH:MM	

South Stack	Ev	rent 1	Е	vent 2	Ev	ent 3	Ev	ent 4
Unit No.	ι	Jnit		Unit	U	nit 5	U	nit 4
Breaker Open (BO)	11:45 PM	2022/04/14	1:50 PM	2022/04/19	7:45 PM	2022/04/22	12:55 PM	2022/04/27
Draught Group (DG) Shut Down (SD)	11:45 PM	2022/04/17	11:45 PM	2022/04/21	11:45 PM	2022/04/23	12:50 AM	2022/04/28
BO to DG SD (duration)	03:00:00	DD:HH:MM	02:09:55	DD:HH:MM	01:04:00	DD:HH:MM	00:11:55	DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

South Stack	E	vent 5		Event 6	
Unit No.	L	Init 5	Unit 5u		
Breaker Open (BO)	1:50 PM	2022/04/02	4:05 PM	2022/04/02	
Draught Group (DG) Shut Down (SD)	3:10 AM	2022/04/03	10:45 PM	2022/04/02	
BO to DG SD (duration)	00:13:20	DD:HH:MM	00:06:40	DD:HH:MM	
Fires in time					
Synch. to Grid (or BC)					
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM	
Emissions below limit from BC (end date)					
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM	

Complaints Register

Table 9: Complaints for the month of April 2022.

Sourc e Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrenc e	Date by which measure will be implemented			
There was no complaint related to air quality received during the month of April 2022.								

General

The particulate matter (PM10) emissions on the North and South Common Stacks were within the **monthly limit**; North stack recorded the monthly PM10 average emissions figure of **32.4 mg/Nm3** and the South Stack recorded PM10 monthly average figure of **120.1 mg/Nm3**. The gaseous (NOx & SOx) emissions on the north and south common stacks were also within the **daily limit** during the month of April 2022; refer to graphs above. However The North Common Stack gasous monitors are defected.

NB: The rest of the information demonstrating compliance with the emissions license conditions is supplied in the annual emission reports sent to your office.

Kriel Power Station's List of NEMA Section 30 Incidents for 2022/2023 Financial Year

Month	Description of Section30 Incidents - including the reference number	Root Cause (s)	Status of S30 Incident with DEFF (open or closed)	Remarks
April-2022	None			
May - 2022	None			
Jun - 2022	None			
July - 2022	None			
Aug - 2022	None			
Sep - 2022	None			
Oct - 2022	None			
Nov - 2022	None			
Dec - 2022	None			
Jan - 2023	None			
Feb - 2023	None			
Mar - 2023	None			