

	<b>Matimba Power Station Emissions report</b>	<b>Matimba Power Station</b>
---	---	------------------------------

Title: **Matimba Power Station June 2022  
emissions report** Document Identifier: **RP/247/023**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area  
Applicability: **Environment**

Revision: **1**

Total Pages: **38**

Report Date: **June 2022**

Disclosure  
Classification: **Controlled**

**Compiled by**



**WC Mocke  
Environmental Officer**

Date: 2022/07/20

**Functional Responsibility**



**MC Mamabolo  
Environmental Manager**

Date: 29/07/2022

**Authorized by**



**Obakeng Mabotja  
General Manager**

Date: 2022/07/29

## Content

	Page
1. Report Summary .....	4
2. Emission information .....	5
2.1 Raw materials and products.....	5
2.2 Abatement technology.....	5
2.3 Energy source characteristics .....	6
2.4 Emissions reporting.....	6
2.4.1 Particulate Matter Emissions .....	6
2.4.2 Gaseous Emissions .....	12
2.4.3 Total Volatile Organic Compounds .....	24
2.4.4 Greenhouse gas (CO <sub>2</sub> ) emissions .....	25
2.5 Daily power generated .....	25
2.6 Pollutant Tonnages .....	32
2.7 Reference values .....	32
2.8 Continuous Emission Monitors.....	33
2.8.1 Reliability.....	33
2.8.2 Changes, downtime and repairs .....	33
2.8.3 Sampling dates and times.....	34
2.9 Units Start-up information .....	34
2.10 Emergency generation .....	36
2.11 Complaints register .....	36
2.12 Air quality improvements and social responsibility conducted .....	36
2.12.1 Air quality improvements.....	36
2.12.2 Social responsibility conducted.....	36
2.13 Ambient air quality monitoring.....	37
2.14 Electrostatic precipitator and Sulphur plant status .....	37
2.15 General.....	38
3. Attachments.....	38
4. Report Conclusion .....	38
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	5
Table 2: Abatement Equipment Control Technology Utilised.....	5
Table 3: Energy Source Material Characteristics. ....	6
Table 4: Total volatile compound estimates .....	24
Table 5: Daily power generated per unit in MWh for the month of June 2022 .....	25
Table 6: Pollutant tonnages for the month of June 2022.....	32
Table 7: Reference values for data provided, June 2022.....	32
Table 8: Average percentage (%) availability of monitors for the month of June 2022.....	33
Table 9: Dates of last conducted CEMS verification tests for PM, SO <sub>2</sub> and NO <sub>x</sub> .....	34

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Start-up information .....	34
Table 11: Emergency generation .....	36
Table 12: Complaints.....	36

## Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of June 2022.....	6
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of June 2022.....	7
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of June 2022.....	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of June 2022.....	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of June 2022.....	10
Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of June 2022.....	11
Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 1 for the month of June 2022 .....	12
Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of June 2022 .....	13
Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of June 2022 .....	14
Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 4 for the month of June 2022 .....	15
Figure 11: SO <sub>2</sub> daily average emissions against emission limit for unit 5 for the month of June 2022 .....	16
Figure 12: SO <sub>2</sub> daily average emissions against emission limit for unit 6 for the month of June 2022 .....	17
Figure 13: Figure 14: NO <sub>x</sub> daily average emissions against emission limit for unit 1 for the month of June 2022.....	18
Figure 15: NO <sub>x</sub> daily average emissions against emission limit for unit 2 for the month of June 2022 .....	19
Figure 16: NO <sub>x</sub> daily average emissions against emission limit for unit 3 for the month of June 2022 .....	20
Figure 17: NO <sub>x</sub> daily average emissions against emission limit for unit 4 for the month of June 2022.....	21
Figure 18: NO <sub>x</sub> daily average emissions against emission limit for unit 5 for the month of June 2022 .....	22
Figure 19: NO <sub>x</sub> daily average emissions against emission limit for unit 6 for the month of June 2022 .....	23
Figure 20: Unit 1 daily generated power in MWh for the month of June 2022 .....	26
Figure 21: Unit 2 daily generated power in MWh for the month of June 2022 .....	27
Figure 22: Unit 3 daily generated power in MWh for the month of June 2022 .....	28
Figure 23: Unit 4 daily generated power in MWh for the month of June 2022 .....	29
Figure 24: Unit 5 daily generated power in MWh for the month of June 2022 .....	30
Figure 25: Unit 6 daily generated power in MWh for the month of June 2022 .....	31

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in November 2021. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for June 2022.



During the period under review, four exceedances of the daily particulate matter emission limit ( $50\text{mg}/\text{Nm}^3$ ) occurred. All exceedances remained within the 48-hour grace period. No exceedances of the monthly  $\text{SO}_x$  limit ( $3500\text{mg}/\text{Nm}^3$ ) or the daily  $\text{NO}_x$  emission limit ( $750\text{mg}/\text{Nm}^3$ ) occurred.

More information regarding above mentioned issues is provided in the relevant sections within the report.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2. Emission information

### 2.1 Raw materials and products

**Table 1:** Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	1 194 472
	Fuel Oil	Tons/month	1 200	572,363
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	2893

The consumption rates for the month of June 2022 were within the permitted maximum limits.

### 2.2 Abatement technology

**Table 2:** Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99,88%
Unit 2	Electrostatic Precipitator	100%	99,93%
Unit 3	Electrostatic Precipitator	100%	99,87%
Unit 4	Electrostatic Precipitator	100%	99,93%
Unit 5	Electrostatic Precipitator	100%	99,93%
Unit 6	Electrostatic Precipitator	100%	99,96%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO <sub>3</sub> Plant	100%	93,43%
Unit 2	SO <sub>3</sub> Plant	100%	98,61%
Unit 3	SO <sub>3</sub> Plant	100%	93,54%
Unit 4	SO <sub>3</sub> Plant	100%	97,62%
Unit 5	SO <sub>3</sub> Plant	100%	92,36%
Unit 6	SO <sub>3</sub> Plant	100%	94,72%

Flue gas conditioning plant availability was below the required 100% for all six (06) units due to maintenance and low energy production rates.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.3 Energy source characteristics

**Table 3:** Energy Source Material Characteristics.


	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1,15%
	Ash Content	40%	34,46%

Energy source characteristics remained within the ranges stipulated in the license.

## 2.4 Emissions reporting

### 2.4.1 Particulate Matter Emissions

#### Unit 1 Particulate Emissions



**Figure 1:** Particulate matter daily average emissions against emission limit for unit 1 for the month of June 2022

#### Interpretation:


Unit 1 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 3 June 2022. The exceedance was due to breakdowns on the flue gas conditioning plant. The plant was repaired, and emissions returned to below the limit. The exceedance remained within the 48-hour grace period.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 2 Particulate Emissions



**Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of June 2022**

**Interpretation:**


All daily averages below Particulate matter emission daily limit of 50 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 3 Particulate Emissions



**Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of June 2022**

**Interpretation:**

Unit 3 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 1 June 2022, 3 June 2022, and 27 June 2022. The exceedances were due to breakdowns on the ash removal system leading to ash backlog within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The defective plants were repaired, and the exceedances remained within the 48-hour grace period.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## Unit 4 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of June 2022**

**Interpretation:**


All daily averages below Particulate matter emission daily limit of 50 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 5 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of June 2022**

**Interpretation:**


All daily averages below Particulate matter emission daily limit of 50 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 6 Particulate Emissions



**Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of June 2022**

**Interpretation:**

All daily averages below Particulate matter emission daily limit of 50 mg/Nm<sup>3</sup>.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.4.2 Gaseous Emissions

### Unit 1 SO<sub>2</sub> Emissions



**Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 1 for the month of June 2022**


#### Interpretation:

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO<sub>2</sub> Emissions

**Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of June 2022**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 SO<sub>2</sub> Emissions

**Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of June 2022**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO<sub>2</sub> Emissions

**Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 4 for the month of June 2022**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 SO<sub>2</sub> Emissions

**Figure 11: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of June 2022**

**Interpretation:**


All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Unit 6 SO<sub>2</sub> Emissions**

**Figure 12: SO<sub>2</sub> daily average emissions against emission limit for unit 6 for the month of June 2022**


**Interpretation:**

All daily averages remained below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 NO<sub>x</sub> Emissions

**Figure 13: Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 1 for the month of June 2022**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO<sub>x</sub> Emissions

**Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 2 for the month of June 2022**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 NO<sub>x</sub> Emissions

**Figure 16: NO<sub>x</sub> daily average emissions against emission limit for unit 3 for the month of June 2022**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 NO<sub>x</sub> Emissions

**Figure 17: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of June 2022**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO<sub>x</sub> Emissions

**Figure 18: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of June 2022**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 6 NO<sub>x</sub> Emissions****Figure 19: NO<sub>x</sub> daily average emissions against emission limit for unit 6 for the month of June 2022****Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.4.3 Total Volatile Organic Compounds

**Table 4:** Total volatile compound estimates

		
<b>CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*</b>		
<b>Date:</b>	Tuesday, 12 July 2022	
<b>Station:</b>	Matimba Power Station	
<b>Province:</b>	Limpopo Province	
<b>Tank no.</b>	1-4	
<b>Description:</b>	Outdoor fuel oil storage tank	
<b>Tank Type:</b>	Vertical fixed roof (vented to atmosphere)	
<b>Material stored:</b>	Fuel Oil 150	
<p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <u>blue cells</u> below</p> <p align="center">Choose from a dropdown menu in the <u>green cells</u></p> <p align="center">The total VOC emissions for the month are in the <u>red cells</u></p> <p align="center">IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE</p>		
<b>MONTH:</b>	June	
<b>GENERAL INFORMATION:</b>	<b>Data</b>	<b>Unit</b>
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	572,363	
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
<b>METEROLOGICAL DATA FOR THE MONTH</b>	<b>Data</b>	<b>Unit</b>
Daily average ambient temperature	16,61	°C
Daily maximum ambient temperature	25,19	°C
Daily minimum ambient temperature	9,38	°C
Daily ambient temperature range	15,81	°C
Daily total insolation factor	3,45	kWh/m²/day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
<b>FINAL OUTPUT:</b>	<b>Result</b>	<b>Unit</b>
Breathing losses:	0,54	kg/month
Working losses:	0,02	kg/month
<b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>	<b>0,55</b>	<b>kg/month</b>
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.4.4 Greenhouse gas (CO<sub>2</sub>) emissions

CO<sub>2</sub> emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

## 2.5 Daily power generated


**Table 5:** Daily power generated per unit in MWh for the month of June 2022

<b>Date</b>	<b>Unit 1</b>	<b>Unit 2</b>	<b>Unit 3</b>	<b>Unit 4</b>	<b>Unit 5</b>	<b>Unit 6</b>
2022/06/01	12726	14819	14218	14014	13787	12236
2022/06/02	13825	14369	13792	14163	13552	12250
2022/06/03	14158	14692	13700	12024	14403	11776
2022/06/04	13890	14261	8765	14003	13374	11147
2022/06/05	12487	13744	11418	10273	12588	11146
2022/06/06	13343	13191	12381	11788	12842	11144
2022/06/07	13397	13428	12787	8826	13362	11187
2022/06/08	13121	13418	13189	11918	12892	11495
2022/06/09	13507	14169	13848	11867	13426	11722
2022/06/10	14879	14733	14522	15042	14232	11893
2022/06/11	13542	13763	12796	13559	13473	11596
2022/06/12	10937	13725	12807	11726	12411	11134
2022/06/13	0	14527	14902	14773	14136	11132
2022/06/14	0	14075	14377	15038	14099	11316
2022/06/15	0	14589	14487	12777	12164	10967
2022/06/16	0	14439	14218	13634	13885	11138
2022/06/17	0	14510	14602	15015	13879	11142
2022/06/18	0	14331	14173	14728	13738	11139
2022/06/19	0	14541	13989	14999	13865	11138
2022/06/20	3447	14469	14253	15151	14110	11138
2022/06/21	13332	14495	15155	15358	14353	11140
2022/06/22	15035	14518	14824	15332	12993	11140
2022/06/23	14338	14582	14551	15222	14228	11138
2022/06/24	14941	12307	15101	15761	14555	11354
2022/06/25	15439	12116	14312	15755	8146	11497
2022/06/26	15169	11940	14403	15268	8534	11492
2022/06/27	15221	13795	13857	15311	12848	11500
2022/06/28	16056	15014	12829	16081	14318	11496
2022/06/29	16044	14892	15117	16073	14288	11499
2022/06/30	15968	14415	15244	15460	13945	11491

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 20: Unit 1 daily generated power in MWh for the month of June 2022**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 21: Unit 2 daily generated power in MWh for the month of June 2022**

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 22: Unit 3 daily generated power in MWh for the month of June 2022**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 23: Unit 4 daily generated power in MWh for the month of June 2022**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 24: Unit 5 daily generated power in MWh for the month of June 2022**

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 25: Unit 6 daily generated power in MWh for the month of June 2022**

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.6 Pollutant Tonnages

The emitted pollutant tonnages for June 2022 are provided in table 6. CO<sub>2</sub> values for units 3 and 4 were calculated per balance, using O<sub>2</sub> values, due to analyser providing unreliable data. Averaged values were used for O<sub>2</sub> data for Units 5 and 6 from 17 to 30 June 2022 due to the analysers being defective and providing unreliable data. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data.

**Table 6:** Pollutant tonnages for the month of June 2022

<b>Associated Unit/Stack</b>	<b>PM (tons)</b>	<b>SO<sub>2</sub> (tons)</b>	<b>NO<sub>x</sub> (tons)</b>
Unit 1	55,4	2 682,4	512,9
Unit 2	41,5	8 703,2	1 605,8
Unit 3	82,7	5 579,4	1 012,3
Unit 4	47,0	4 779,2	1 116,2
Unit 5	43,2	3 906,5	682,8
Unit 6	22,9	4 883,9	799,9
<b>SUM</b>	<b>292,5</b>	<b>30 534,7</b>	<b>5 729,9</b>

## 2.7 Reference values

**Table 7:** Reference values for data provided, June 2022

<b>Compound / Parameter</b>	<b>Units of Measure</b>	<b>Unit 1</b>	<b>Unit 2</b>	<b>Unit 3</b>	<b>Unit 4</b>	<b>Unit 5</b>	<b>Unit 6</b>
Oxygen	%	6,54	10,36	6,45	6,70	7,50	9,25
Moisture	%	4,69	4,62	5,42	3,82	4,97	2,88
Velocity	m/s	24,8	34,1	29,2	24,5	25,6	26,3
Temperature	°C	135,0	130,0	126,2	133,3	119,4	123,8
Pressure	mBar	935,9	1 194,0	917,7	870,6	934,8	928,2

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.8 Continuous Emission Monitors

### 2.8.1 Reliability

CO<sub>2</sub> values for units 3 and 4 were calculated per balance, using O<sub>2</sub> values, due to analyser providing unreliable data. Averaged values were used for O<sub>2</sub> data for Units 5 and 6 from 17 to 30 June 2022 due to the analysers being defective and providing unreliable data.

**Table 8:** Average percentage (%) availability of monitors for the month of June 2022.

Associated Unit/Stack	PM	SO <sub>2</sub>	NO
Unit 1	100,0	100,0	96,4
Unit 2	100,0	92,2	92,2
Unit 3	100,0	100,0	100,0
Unit 4	100,0	100,0	100,0
Unit 5	100,0	100,0	100,0
Unit 6	100,0	100,0	100,0

### 2.8.2 Changes, downtime and repairs

#### Unit 1

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 2

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 3

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 4

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 5

- U No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 6

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.8.3 Sampling dates and times

**Table 9:** Dates of last conducted CEMS verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub>

<b>Name of service provider:</b>		Stacklabs Environmental Services CC		
<b>Address of service provider:</b>		10 Chisel Street Boltonia Krugersdorp 1739		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
1	2020/09/30 06h04	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00
2	2021/01/26 04h52	2021/01/27 13h00	2021/01/27 13h00	2021/01/27 13h00
3	2021/08/10 12h05	2020/09/24 07h00	2020/09/24 07h00	2020/09/24 07h00
4	2021/07/13 14h31	2020/09/16 02h00	2020/09/16 02h00	2020/09/16 02h00
5	2020/10/06 05h39	2020/10/08 02h30	2020/10/08 02h30	2020/10/08 02h30
6	2020/09/09 06h41	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00

## 2.9 Units Start-up information

**Table 10:** Start-up information

<b>Unit</b>	1	
<b>Fires in</b>	2022/06/20	10H54
<b>Synchronization with Grid</b>	2022/06/20	16H31
<b>Emissions below limit</b>	2022/06/20	23H37
<b>Fires in to synchronization</b>	5,62	HOURS
<b>Synchronization to &lt; Emission limit</b>	7,1	HOURS

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	3	
<b>Fires in</b>	2022/06/04	14H45
<b>Synchronization with Grid</b>	2022/06/04	16H53
<b>Emissions below limit</b>	2022/06/04	20H02
<b>Fires in to synchronization</b>	2,13	HOURS
<b>Synchronization to &lt; Emission limit</b>	3,15	HOURS

<b>Unit</b>	4	
<b>Fires in</b>	2022/06/07	17H57
<b>Synchronization with Grid</b>	2022/06/07	20H05
<b>Emissions below limit</b>	2022/06/07	23H28
<b>Fires in to synchronization</b>	2,13	HOURS
<b>Synchronization to &lt; Emission limit</b>	3,38	HOURS

<b>Unit</b>	5	
<b>Fires in</b>	2022/06/22	08H24
<b>Synchronization with Grid</b>	2022/06/22	08H47
<b>Emissions below limit</b>	2022/06/22	08H47
<b>Fires in to synchronization</b>	0,38	HOURS
<b>Synchronization to &lt; Emission limit</b>	0	HOURS

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.10 Emergency generation

**Table 11:** Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
<b>Emergency Generation hours declared by national Control</b>	125	312	312	304	311	312
<b>Emergency Hours declared including hours after stand down</b>	147	334	334	326	333	334
<b>Days over the Limit during Emergency Generation</b>	1	0	2	0	0	0

Unit 1 exceeded the 50mg/Nm<sup>3</sup> limit for one day during emergency generation, on 3 June 2022. Unit 3 exceeded the 50mg/Nm<sup>3</sup> limit for two days during emergency generation, on 1 and 3 June 2022.

## 2.11 Complaints register

**Table 12:** Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
N/A					

## 2.12 Air quality improvements and social responsibility conducted

### 2.12.1 Air quality improvements

None

### 2.12.2 Social responsibility conducted

None

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.13 Ambient air quality monitoring

Eight exceedances of the PM<sub>2.5</sub> daily limit and fourteen exceedances for the PM<sub>10</sub> daily limit occurred during the period under review. The SO<sub>2</sub> national ambient air quality hourly standard was exceeded once and three exceedances of the SO<sub>2</sub> national ambient air quality 10-minute limit were recorded.

The average data recovery for the period was 99.4% and the station availability was 99.7%.

Ambient NO<sub>2</sub>, PM<sub>2.5</sub> and PM<sub>10</sub> concentrations at Marapong monitoring site show influence of emissions from low level sources in the area and ambient SO<sub>2</sub> concentrations are contributed to by emissions from high level sources.

Detailed results can be found in Attachment 1, "Marapong Monthly Report\_June 2022".

## 2.14 Electrostatic precipitator and Sulphur plant status

### Unit 1

- 3 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 2

- All precipitator fields in service.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 3

- All precipitator fields in service.
- Unit 3 Variable speed drive failed and was replaced.

### Unit 4

- 1 field out of service, will be inspected next opportunity.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 5

- 1 field out of service, will be inspected next opportunity.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 6

- All precipitator fields in service.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### SO<sub>3</sub> common plant

- No abnormalities on the sulphur storage plant.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.15 General

### Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. Eskom internal standard 240-56242363 Emissions Monitoring and Reporting Standard

### Sampling locations:

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues

## 3. Attachments

Marapong Monthly Report\_June 2022

## 4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.