

Lukhanyo Mgadle Chief Air Quality Officer Buffalo City Metropolitan Municipality 2 Beaconsfield Road North End East London 5201 Date: 3 *June 2022*

Enquiries: Hilton Westman

(021) 9415856

Ref: PRX/2022/05

Dear Mr Mgadle

ESKOM PORT REX POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF MAY 2022

Atmospheric Emissions License: ECBC_000603

This serves as the monthly report and the information is applicable for the month of May 2022.

1. Raw Materials and Products (Licence 6.1)

Quantity of Raw Materials and Products used/produced for the month

Element	Performance	Reporting Unit
Fuel type : Diesel		
Total Fuel Consumption	28.565	Tons
Electricity Produced	94	MWh
Average Fuel Consumption	0.303	Tons / MWh
Maximum fuel consumption rate	14 283	Kg / per hour

2. Operating times of units (Licence 5.4)

a. Total Hours

	Hours operated	Total Fuel Consumption	Energy Production		
	Hours and minutes	Litres	MWh		
Unit One	0		0		
Unit Two	2hrs 00 min	33 320	94		
Unit Three	0		0		

b. Detailed operating times

See Annexure 1

3. Complaints Register (Licence 7.6)

No complaints were registered for the month of May 2022.

4. General

Port Rex was requested to generate for the grid to supplement power availability and minimise national load shedding.

We trust that the above information complies with your requirements.

Yours sincerely

Pamela Mrubata Plant Manager

PORT REX POWER STATION

Annexure 1. Port Rex Hours of operation

	Unit One		Unit two		Unit 3				
Date	Start	Finish	Total Hours	Start	Finish	Total Hours	Start	Finish	Total Hours
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31				17:37:00	19:37:00	02:00:00			

Load factor

0.27 %