

Mrs Mpho Nembilwi
Nkangala District
P.O Box 437
MIDDLEBERG
1050
By email: nembilwim@nkangaladm.gov.za'

Date:
28 November 2022

Enquiries: S Chokoe
Tel +27 13 647 6970

Dear Mrs. Mpho Nembilwi

Ref: Kendal Power Station AEL (17/4/AEL/MP312/11/15)

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF OCTOBER 2022.

This is a monthly report required in terms of Section 7.4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Compiled by:


Irene Motswenyane
ENVIRONMENTAL OFFICER- KENDAL

Date: 28 / 11 / 2022

Supported by:


Solly Chokoe
ENVIRONMENTAL MANAGER- KENDAL

Date: 28 / 11 / 2022

Generation Division (Cluster 1)
(Kendal Power Station)
N12 Balmoral Off Ramp, Emalahleni
Private Bag x7272, Emalahlani 1035 SA
Tel +27 13 647 6970 Fax +27 13 647 6904 www.eskom.co.za

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF OCTOBER 2022


Verified by:



Fulufhelo Nganke
BOILER ENGINEERING: SYSTEM ENGINEER-KENDAL

Date: 28/11/2022


Validated by:



Tendani Rasivhetshela
BOILER ENGINEERING MANAGER-KENDAL

Date: 29/11/2022

Supported by:



Malibongwe Mabizela
ENGINEERING MANAGER-KENDAL

Date: 01/12/2022

Approved by:



Kobus Steyn
GENERAL MANAGER-KENDAL

Date: 1 Dec 2022

KENDAL POWER STATION MONTHLY EMISSIONS REPORT
 Atmospheric Emission License 17/4/AEL/MP312/11/15



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Oct-2022
	Coal	Tons	2 260 000	687 892
	Fuel Oil	Tons	5 000	11735

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Oct-2022
	Energy	GWh(MW)	(3,153,600)4380	1 161 009.00
	Ash	Tons	770 000	211 870.7
	RE Ash	kg/MWh	not specified	1.370

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	<1 (%)	0.720
Ash Content	%	40 (%)	30.800

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Oct-2022	Technology Type	SO ₂ Utilization Oct-2022
Unit 1	ESP + SO ₂	98.401%	SO ₂	51.3%
Unit 2	ESP + SO ₂	98.727%	SO ₂	43.1%
Unit 3	ESP + SO ₂	99.379%	SO ₂	0.0%
Unit 4	ESP + SO ₂	99.718%	SO ₂	68.8%
Unit 5	ESP + SO ₂	98.910%	SO ₂	81.4%
Unit 6	ESP + SO ₂	99.498%	SO ₂	71.5%

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised

Unit 1, 2, 4, 5 & 6: SO₂ utilization is less than 100% due to SO₃ plant off due to OPCR pumps that are faulty.
 - SO₃ plant off due to low steam temperature.
 - SO₃ plant on hold mode due to RH flue gas temperature low.
 Unit 3: Faulty server with no readings for the month of October.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	91.7	99.8	84.9	99.0
Unit 2	87.5	40.4	27.3	98.6
Unit 3	99.0	100.0	99.9	77.8
Unit 4	99.6	99.7	48.4	32.5
Unit 5	99.5	62.1	62.1	99.9
Unit 6	80.9	22.9	1.0	0.0

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

Note: Unit 2 SO₂ and NO, Unit3 O₂ and Unit4 NO and O₂, Unit 5 SO₂ and NO, Unit 6 SO₂,NO and O₂ monitor reliabilities is low due to defective monitors.

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of October 2022

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	606.5	3 020	998
Unit 2	142.7	321	154
Unit 3	218.0	1 960	646
Unit 4	70.8	1 479	393
Unit 5	461.0	2 562	896
Unit 6	89.2	1 713	766
SUM	1 588.30	11 055	3 853

Table 6.2: Operating days in compliance to PM AEL Limit - October 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	8	6	0	9	15	376.6
Unit 2	3	2	0	3	5	483.1
Unit 3	25	4	0	0	4	65.2
Unit 4	16	2	0	8	10	250.9
Unit 5	4	13	0	11	24	409.6
Unit 6	7	2	0	6	8	162.5
SUM	63	29	0	37	66	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - October 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	24	0	0	0	0	2 719.4
Unit 2	9	0	0	0	0	1 030.0
Unit 3	31	0	0	0	0	1 745.0
Unit 4	29	0	0	0	0	1 922.3
Unit 5	29	0	0	0	0	1 537.1
Unit 6	20	0	0	0	0	1 734.9
SUM	142	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - October 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm ³)
Unit 1	24	0	0	0	0	883.4
Unit 2	9	0	0	0	0	489.0
Unit 3	31	0	0	0	0	573.7
Unit 4	29	0	0	0	0	539.6
Unit 5	29	0	0	0	0	537.4
Unit 6	20	0	0	0	0	775.6
SUM	142	0	0	0	0	

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contra-vention	Red	Emissions above ELV but outside grace or S30 incident conditions







Figure 3: Kendal Unit 3 PM Emissions - October 2022




High PM emissions can be attributed to Precip fields 11,15,24,27 and 41,42,43 out of commission and failing to reset due to under voltage. RH precip fields off due to RH draught group off.

Figure 4: Kendal Unit 4 PM Emissions - October 2022




High PM emissions can be attributed to ESP chain conveyor 11 not running due to conveyor flights bent. SO3 plant on hold mode due to RH flue gas temperature low.

Figure 5: Kendal Unit 5 PM Emissions - October 2022



High PM emissions can be attributed to DHP trip due to high compartments levels, ESP conveyor 14,23 & 24 that kept on tripping, and DHP off and failing to restart due to PLC failure.

Figure 6: Kendal Unit 6 PM Emissions - October 2022



High PM emissions can be attributed to DHP off due to high compartment levels, DHP stopped due to ash leaking badly on the side of bucket elevator, and SO3 plant off due to low steam temperatures.

Figure 7: Kendal Unit 1 SO₂ Emissions - October 2022




Figure 8: Kendal Unit 2 SO₂ Emissions - October 2022














Figure 9: Kendal Unit 3 SO₂ Emissions - October 2022







COMPLAINTS

There were no complaints for this months

Source Code / Name	Root Cause Analysis	Calculation of impacts / emissions associated	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

ADDENDUM TO MONTHLY EMISSIONS REPORT

Abatement Technology-Table 4

In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as

- ☑ Coal ash content (%) and burnt rate mass
- ☑ Fly : Coarse ash ratio of 80:20 - 80% of fly-ash mass obtained from burnt coal goes to ESP
- ☑ Measurement of dust emission by Dust Monitor over a period of time (monthly)

Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \frac{(\text{Dust Emission From AQR Report Dust Monitor (tons)} \times 100)}{(\text{Coal Burnt (tons)} \times \% \text{ Ash Content} \times 80\%)}$$

Monitor Reliability-Table 5

In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average.

The **monitor reliability** refers to **data reliability** because the assumed value of 99.325% reliability is compared to the dust concentration signal. If the dust concentration signal is above 99.325% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g 24 hours

The formula is as follows:

$$= (1 - (\text{count hours above } 99.325\% / 24 \text{ hours})) \times 100$$

Emissions Performance:

- Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2, 4, 5 & 6 due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- Unit 5 Monitor still using the old monitor correlation. After new correlations are done, new correlation factors will be implemented and backfitted to the date of monitor installation.
- Unit 4 dust monitor output 2 is faulty, where output 1 is greater or equal to 87.5, output 1 readings were copied to output 2.
- Average values for Unit 1 NOx from the 28th to the 31st and moisture from the 26th to the 31st were used from the available data as the monitors were defective.
- Average emissions for Unit 5 SOx and NOx for the whole month were used from the QAL 2 report as the monitors were defective
- Average emissions for Unit 6 SOx from the 1st until the 20th, NOx and O2 for the whole month were used from the QAL 2 report as the monitors were defective.
- Average emissions for Unit 6 dust from the 07th to the 08th, 12th to 14th was used where the monitor was defective.
-
- Unit 1
 - Findings: The high emissions can be attributed to SO3 plant off due to no Sulphur flow. ESP conveyor 11, 12, 13, 14, 21, 22, 23 & 24 checked in, ESP conveyor 11 choked, SO3 plant on hold mode due to low temperature, SO3 plant off due to OPCR pumps that are faulty and DHP off due to compartments level high..
 - Resolution: Plant repaired
- Unit 2
 - Findings: The high emissions can be attributed to SO3 plant off due to low steam temperature, and DHP tripped due to Stream 2 bucket elevator flopper gate which had two limit for bunker and chute.
 - Resolution: Plant repaired.
- Unit 3
 - Findings: High PM emissions can be attributed to ESP chain conveyor 11 not running due to conveyor flights bent. SO3 plant on hold mode due to RH flue gas temperature low.
 - Resolution: Plant repaired.
- Unit 4
 - Findings: High PM emissions can be attributed to ESP chain conveyor 11 not running due to conveyor flights bent. SO3 plant on hold mode due to RH flue gas temperature low.
 - Resolution: Plant repaired.
- Unit 5
 - Findings: High PM emissions can be attributed to DHP trip due to high compartments levels, ESP conveyor 14, 23 & 24 that kept on tripping, and DHP off and failing to restart due to PLC failure.
 - Resolution: Plant repaired.
- Unit 6
 - Findings: High PM emissions can be attributed to DHP off due to high compartment levels high, DHP stopped due to ash leaking badly on the side of bucket elevator, and SO3 plant off due to low steam temperatures.
 - Resolution: Plant repaired.