

CAMDEN POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License CPS/0012/2019/F03



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption	Actual Consumption Feb-2023
	Coal	Tons	550 000	229 706.75
	Fuel Oil	Tons	5 000	5 758.20
Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Actual Production Feb-2023
	Energy	GWh	1600	486.00
	Ash	Tons	not specified	51 202
	RE PM	kg/MWh	not specified	0.241

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	19.56	22.59
Sulphur Content	%	< 2	0.90
Ash Content	%	25 to 35	22.29

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
Stack 1	100	3500	1100
Stack 2	100	3500	1100
Stack 3	100	3500	1100
Stack 4	100	3500	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Feb-2023
Unit 1	Fabric Filter Plant (FFP)	99.996%
Unit 2	Fabric Filter Plant (FFP)	99.998%
Unit 3	Fabric Filter Plant (FFP)	99.995%
Unit 4	Fabric Filter Plant (FFP)	99.995%
Unit 5	Fabric Filter Plant (FFP)	99.998%
Unit 6	Fabric Filter Plant (FFP)	99.999%
Unit 7	Fabric Filter Plant (FFP)	100.000%
Unit 8	Fabric Filter Plant (FFP)	100.000%

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	CO ₂	O ₂
Stack 1	100.0	97.9	96.1	0.0	0.0
Stack 2	100.0	89.4	89.7	0.0	0.0
Stack 3	100.0	88.2	53.3	0.0	0.0
Stack 4	96.7	77.7	77.7	0.0	0.0

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of February-2023

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
1	15.7	761	313
2	15.1	867	376
3	27.8	636	352
4	34.9	757	392
5	17.9	913	247
6	4.5	500	126
7	0.9	830	369
8	0.4	257	110
SUM	117.1	5 520	2 286

Table 6.2: Operating days in compliance to PM AEL Limit - February 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Stack 1	25	0	0	0	0	27.5
Stack 2	25	2	0	0	2	73.5
Stack 3	28	0	0	0	0	26.9
Stack 4	25	0	0	0	0	1.3
SUM	103	2	0	0	2	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - February 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Stack 1	26	0	0	0	0	1 433.4
Stack 2	28	0	0	0	0	1 454.9
Stack 3	28	0	0	0	0	1 453.1
Stack 4	26	0	0	0	0	1 143.7
SUM	108	0	0	0	0	

Table 6.4: Operating days in compliance to NO_x AEL Limit - February 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
Stack 1	26	0	0	0	0	631.1
Stack 2	28	0	0	0	0	772.3
Stack 3	28	0	0	0	0	425.3
Stack 4	26	0	0	0	0	508.4
SUM	108	0	0	0	0	

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Camden Stack 1 PM Emissions - February 2023




Figure 2: Camden Stack 2 PM Emissions - February 2023




Figure 3: Camden Stack 3 PM Emissions - February 2023




Figure 4: Camden Stack 4 PM Emissions - February 2023




Figure 5: Camden Stack 1 SO₂ Emissions - February 2023




Figure 6: Camden Stack 2 SO₂ Emissions - February 2023




Figure 7: Camden Stack 3 SO₂ Emissions - February 2023




Figure 8: Camden Stack 4 SO₂ Emissions - February 2023




Figure 9: Camden Stack 1 NOx Emissions - February 2023




Figure 10: Camden Stack 2 NOx Emissions - February 2023




Figure 11: Camden Stack 3 NOx Emissions - February 2023





Figure 12: Camden Stack 4 NOx Emissions - February 2023



10 GENERAL / ABNORMALITIES

Unit 1:

None

Unit 2:

None

Unit 3:

None

Unit 4:

None

Unit 5:

None

Unit 6:

None

Unit 7:

None

Unit 8:

None

Comments on Use of averages for O2 and CO2 from QAL2 tests as per previous months
 Fuel Oil Tonnage burnt exceeded the 5000 tons limit for the month of February 2023
 Stack 3 - Low reliability issues as per letter from C&I
 Stack 4 - SOx & NOx also experienced lower than 80% reliability due to a purge air line that was disconnected and affected reading from the 3-8 February 2023. This was rectified on the 9th February 2023.



Engineering Manager

27/03/2023

Date



Environmental Manager

31/03/2023

Date

Compiled by: Environmental Department & verified by Boiler Eng

Env. Practitioner & System Eng

For: Department of Environment, Forestry & Fisheries

Chief Air Pollution Control Officer

Copies: Eskom Environmental Management

D Herbst
 B Mccourt

Gx Compliance Management
 Gx Asset Management

R Rampiar
 E Patel

Camden Power Station:

Engineering Manager
 Operating Manager
 Maintenance Manager
 Production Managers
 Boiler Engineering Manager
 System Engineer
 Environmental Manager
 Environmental Officer
 P&T and Process Engineering Manager