



Generation

Nkangala District Municipality
P O Box 437
Middleburg
1050

Attention:

Mr V Mahlangu

AND

Directorate: Air Quality Management
Services
The Chief Director:
Mr S S Maluleka
Department of Environmental Services
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

Date: 2023/02/23

Enquiries: Duvha Environmental Management

☎ +27 13 690 0445

☎ +27 66 212 2105

Enquiries: Ms Simthandile Nhlapo

☎ +27 13 690 0445

☎ +27 66 212 2105

Total number of pages: 15

Total number of annexes:1

DUVHA POWER STATION

Atmospheric Emission License 17/4/AEL/MP312/11/07

GENERAL MANAGER

2023/03/02

DATE

DUVHA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/07



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Jan-2023
	Coal	Tons	1 400 000	355 806.63
Fuel Oil	Tons	5 000	3728.68	

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Jan-2023
	Energy	GWh	3600	597.50
Ash	Tons	not specified	95 676.40	

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 TO >1.2	0.85
Ash Content	%	27 TO 30	26.89

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jan-2023	Technology Type	SO ₃ Utilization Jan-2023
Unit 1	FFP	99.9%	n/a	n/a
Unit 4	ESP + SO ₃	97.1%	SO ₃	99.7%
Unit 5	ESP + SO ₃	99.6%	SO ₃	100.0%
Unit 6	ESP + SO ₃	99.5%	SO ₃	99.8%

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	100.0	99.7	99.7	100.0
Unit 4	74.6	52.9	51.9	100.0
Unit 5	100.0	100.0	100.0	100.0
Unit 6	99.0	58.2	58.4	100.0

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of January 2023

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	19.2	1 790	908
Unit 4	805.5	2 675	1 418
Unit 5	19.8	335	154
Unit 6	140.2	2 119	1 037
SUM	984.64	6 919	3 516

Table 6.2: Operating days in compliance to PM AEL Limit - January 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	15	0	0	0	0	19.1
Unit 4	9	2	13	0	15	530.9
Unit 5	1	3	0	0	3	122.8
Unit 6	19	6	0	0	6	103.9
SUM	44	11	13	0	24	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - January 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	16	0	0	0	0	1 562.9
Unit 4	26	0	0	0	0	1 870.5
Unit 5	6	0	0	0	0	1 421.6
Unit 6	28	0	0	0	0	1 585.4
SUM	76	0	0	0	0	

Table 6.4: Operating days in compliance to NO_x AEL Limit - January 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
Unit 1	16	0	0	0	0	795.7
Unit 4	26	0	0	0	0	998.7
Unit 5	6	0	0	0	0	635.8
Unit 6	28	0	0	0	0	769.3
SUM	76	0	0	0	0	

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Duvha Unit 1 PM Emissions - January 2023




Figure 2: Duvha Unit 4 PM Emissions - January 2023




Figure 3: Duvha Unit 5 PM Emissions - January 2023




Figure 4: Duvha Unit 6 PM Emissions - January 2023




Figure 5: Duvha Unit 1 SO₂ Emissions - January 2023




Figure 6: Duvha Unit 4 SO₂ Emissions - January 2023




Figure 7: Duvha Unit 5 SO₂ Emissions - January 2023




Figure 8: Duvha Unit 6 SO₂ Emissions - January 2023




Figure 9: Duvha Unit 1 NOx Emissions - January 2023




Figure 10: Duvha Unit 4 NOx Emissions - January 2023




Figure 11: Duvha Unit 5 NOx Emissions - January 2023





Figure 12: Duvha Unit 6 NOx Emissions - January 2023



7 SHUT DOWN AND LIGHT UP INFORMATION

Tables 7.1: Shut-down and light-up information for the month of January 2023

Unit No.1	<i>Event 1</i>		<i>Event 2</i>		<i>Event 3</i>	
Breaker Open (BO)	<i>11:10 am</i>	<i>2023/01/01</i>	<i>11:40 pm</i>	<i>2023/01/02</i>	<i>4:15 pm</i>	<i>2023/01/16</i>
Draught Group (DG) Shut Down (SD)	<i>DG did not trip or SD</i>	<i>DG did not trip or SD</i>	<i>DG did not trip or SD</i>	<i>DG did not trip or SD</i>	<i>9:30 pm</i>	<i>2023/01/16</i>
BO to DG SD (duration)	<i>n/a</i>	DD:HH:MM	<i>n/a</i>	DD:HH:MM	<i>00:05:15</i>	DD:HH:MM
Fires in time						
Synch. to Grid (or BC)	<i>4:50 pm</i>	<i>2023/01/01</i>				
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)						
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No.4	<i>Event 1</i>		<i>Event 2</i>	
Breaker Open (BO)	<i>7:00 pm</i>	<i>2023/01/13</i>	<i>10:10 am</i>	<i>2023/01/30</i>
Draught Group (DG) Shut Down (SD)	<i>2:10 pm</i>	<i>2023/01/14</i>	<i>10:25 am</i>	<i>2023/01/31</i>
BO to DG SD (duration)	<i>00:19:10</i>	DD:HH:MM	<i>01:00:15</i>	DD:HH:MM
Fires in time	<i>1:25 am</i>	<i>2023/01/19</i>		
Synch. to Grid (or BC)	<i>4:20 am</i>	<i>2023/01/06</i>		
Fires in to BC (duration)	<i>00:10:35</i>	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	<i>12:00 am</i>	<i>2023/01/21</i>		
Emissions below limit from BC (duration)	<i>14:19:40</i>	DD:HH:MM		DD:HH:MM

Unit No.5	<i>Event 1</i>	
Breaker Open (BO)	<i>BO previously</i>	<i>BO previously</i>
Draught Group (DG) Shut Down (SD)	<i>n/a</i>	<i>n/a</i>
BO to DG SD (duration)	<i>n/a</i>	DD:HH:MM
Fires in time	<i>2:20 am</i>	<i>2023/01/26</i>
Synch. to Grid (or BC)	<i>5:35 am</i>	<i>2023/01/27</i>
Fires in to BC (duration)	<i>01:03:15</i>	DD:HH:MM
Emissions below limit from BC (end date)	<i>12:00 am</i>	<i>2023/01/30</i>
Emissions below limit from BC (duration)	<i>02:18:25</i>	DD:HH:MM

Unit No.6	Event 1		Event 2		Event 3	
Breaker Open (BO)	10:55 pm	2023/01/05	10:05 pm	2023/01/10	9:50 am	2023/01/27
Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD
BO to DG SD (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM	n/a	DD:HH:MM
Fires in time						
Synch. to Grid (or BC)						
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)						
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM

8 GENERAL

Unit 2 was offload during the month of January 2023.

Exceedances:

Unit 4:

27-31/12/2022-13/01/2023

- The 72 hours allowable for a cold unit light-up were exceeded from the 29th of December 2022 on unit 4. The final investigation report will be submitted to your office once the investigation is completed.

20/01/2023

- Cold unit light up.

23/01/2023

- High backend temperatures after sootblowing conducted.

30/01/2023

- Hot unit light up.

Unit 5:

28-29/01/2023

- Cold unit light up.

31/01/2023

- Cold unit light up.

Unit 6:

03/01/2023

- The SO3 plant kept on tripping on process air flow deviation alarm.

05/01/2023

- The SO3 plant kept on tripping on process air flow deviation alarm.
- The Electrostatic precipitator fields computer screen was not working.

09/01/2023

- Hot unit light up.

16-17/01/2023

- Underperforming ESPs and a total of 4 ESPs tripped on undervoltage,
- High backend temperatures after sootblowing conducted due to low availability of sootblowers,
- Blocked DHP dust hoppers

19/01/2023

- Underperforming ESPs and a total of 4 ESPs tripped on undervoltage,
- High backend temperatures after sootblowing conducted due to low availability of sootblowers

Unit 4 PM emissions monitors reliability for the month of January 2023 were less than 80% due to the monitor maxing out. The correlation spot check surrogate values were used during the period the monitors maxed out.

Units 4, 5 and 6 gaseous emissions monitors reliabilities were below the 80% threshold due to the control air that was isolated for statutory work on unit 5 during the outage. The control air was bypassed, and the monitors started reading.

The averages Oxygen(O2) and Carbon Dioxide (CO2) data from the QAL 2 tests reports were used for reporting for Units 1, 4, 5, and 6 due to poor performance of the O2 and CO2 gaseous monitors. These poor performances of the gaseous monitors were identified to be caused by the incorrect installation of O2 analyser. The monitors have been relocated successfully and are being verified.

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report which will be sent to your office

9 Complaints and 10 S30 Incidents Register

Refer to addendum A


Boiler Plant Engineering
Manager

01/03/2023
Date


Environmental
Manager

01/03/2023
Date


Engineering Manager

21/03/2023
Date

Compiled by:	Environmental Officer	
For:	Nkangala District Municipality	Air Quality Officer
Copies:	Generation Environmental Management	D Herbst B Mccourt
	Generation Compliance Management	R Rampiar
	Generation Asset Management	E Patel
	Duvha Power Station:	Engineering Manager Operating Manager Maintenance Manager Production Manager Boiler Engineering Manager System Engineer Environmental Manager

9 COMPLAINTS REGISTER

Table 9. Complaints for the month of January 2023

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date measure will be implemented
No complaints were received during the month of January 2023.					

10 S30 INCIDENT OR LEGAL CONTRAVENTION REGISTER

To be completed in the case of a S30 incident or a legal contravention:

Unit no	Incident Start Date	Incident End Date	Incident Cause	Remedial action	S30 initial notification sent	Date S30 investigation report sent	Date DEA Acknowledgment	Date DEA Acceptable	Comments / Reference No.
Unit 4	29/12/2022	13/01/2023	Incident still under investigation		03/01/2023	Incident still under investigation	Not yet received	N/A	The 72 hours allowable for a cold unit light-up were exceeded from the 29 th of December 2022 on unit 4. The final investigation report will be submitted to your office once the investigation is completed.