



Generation

Nkangala District Municipality
P O Box 437
Middleburg
1050

Attention:

Mr V Mahlangu

AND

Directorate: Air Quality Management
Services
The Chief Director:
Mr S S Maluleka
Department of Environmental Services
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

Date: 2022/11/28

Enquiries: Duvha Environmental Management

☎ +27 13 690 0445

☎ +27 66 212 2105

Enquiries: Ms Simthandile

Nhlapo

☎ +27 13 690 0445

☎ +27 66 212 2105

Total number of pages: 12

Total number of annexes: 1

DUVHA POWER STATION

Atmospheric Emission License 17/4/AEL/MP312/11/07


GENERAL MANAGER


DATE

DUVHA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/07



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Mar-2022
	Coal	Tons	1 400 000	347 112.59
Fuel Oil	Tons	5 000	3123.33	

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Mar-2022
	Energy	GWh	3600	630.44
Ash	Tons	not specified	92 227.82	

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 TO >1.2	0.92
Ash Content	%	27 TO 30	26.57

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO _x	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMET TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Mar-2022	Technology Type	SO ₃ Utilization Mar-2022
Unit 4	ESP + SO ₃	99.5%	SO ₃	86.6%
Unit 5	ESP + SO ₃	99.7%	SO ₃	99.0%
Unit 6	ESP + SO ₃	99.5%	SO ₃	100.0%

Note: ESP and FFP plants does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO
Unit 4	99.9	99.7	98.6
Unit 5	100.0	99.6	99.7
Unit 6	81.8	99.6	99.6

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of March 2022

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 4	83.2	1 405	774
Unit 5	112.2	3 041	1 460
Unit 6	116.3	1 760	929
SUM	311.71	6 205	3 162

Table 6.2: Operating days in compliance to PM AEL Limit - March 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Unit 4	7	7	0	0	7	146.9
Unit 5	27	3	0	0	3	56.4
Unit 6	12	8	0	0	8	100.1
SUM	46	18	0	0	18	

Table 6.3: Operating days in compliance to SOx AEL Limit - March 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm ³)
Unit 4	20	0	0	0	0	1 365.6
Unit 5	30	0	0	0	0	1 488.0
Unit 6	22	0	0	0	0	1 677.6
SUM	72	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - March 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm ³)
Unit 4	20	0	0	0	0	732.5
Unit 5	30	0	0	0	0	711.8
Unit 6	22	0	0	0	0	877.0
SUM	72	0	0	0	0	

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Duvha Unit 4 PM Emissions - March 2022





Figure 2: Duvha Unit 5 PM Emissions - March 2022







Figure 5: Duvha Unit 5 SOx Emissions - March 2022




Figure 6: Duvha Unit 6 SOx Emissions - March 2022




Figure 7: Duvha Unit 4 NOx Emissions - March 2022






Figure 8: Duvha Unit 5 NOx Emissions - March 2022





7 SHUT DOWN AND LIGHT UP INFORMATION

Tables 7.1: Shut-down and light-up information for the month of March 2022

Unit No.4	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	<i>BO previously</i>	<i>BO previously</i>	11:55 pm	2022/03/07	7:05 am	2022/03/22	12:55 pm	2022/03/28
Draught Group (DG) Shut Down (SD)	<i>n/a</i>	<i>n/a</i>	11:40 pm	2022/03/09	9:45 pm	2022/03/22	10:00 am	2022/03/29
BO to DG SD (duration)	<i>n/a</i>	DD:HH:MM	01:23:45	DD:HH:MM	00:14:40	DD:HH:MM	00:21:05	DD:HH:MM
Fires in time			6:40 pm	2022/03/17	10:20 pm	2022/03/24		
Synch. to Grid (or BC)			9:00 am	2022/03/18	3:55 am	2022/03/25		
Fires in to BC (duration)		DD:HH:MM	00:14:20	DD:HH:MM	00:05:35	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)			6:00 am	2022/03/20	4:00 pm	2022/03/26		
Emissions below limit from BC (duration)		DD:HH:MM	01:21:00	DD:HH:MM	01:12:05	DD:HH:MM		DD:HH:MM

Unit No.5	Event 1		Event 2	
Breaker Open (BO)	12:45 am	2022/03/11	12:25 am	2022/03/15
Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD
BO to DG SD (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM
Fires in time				
Synch. to Grid (or BC)				
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)				
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM

Unit No.6	Event 1		Event 2		Event 3	
Breaker Open (BO)	BO previously	BO previously	12:25 am	2022/03/15	5:35 am	2022/03/19
Draught Group (DG) Shut Down (SD)	n/a	n/a	9:40 am	2022/03/15	11:45 am	2022/03/19
BO to DG SD (duration)	n/a	DD:HH:MM	00:09:15	DD:HH:MM	00:06:10	DD:HH:MM
Fires in time			1:35 pm	2022/03/16	2:45 am	2022/03/28
Synch. to Grid (or BC)			7:45 pm	2022/03/16	7:30 am	2022/03/28
Fires in to BC (duration)		DD:HH:MM	00:06:10	DD:HH:MM	00:04:45	DD:HH:MM
Emissions below limit from BC (end date)			10:00 pm	2022/03/18	not > limit	not > limit
Emissions below limit from BC (duration)		DD:HH:MM	02:02:15	DD:HH:MM	n/a	DD:HH:MM

8 GENERAL

Units 2 and 3 were offload during the month of March 2022.

The averages Oxygen(O₂) and Carbon Dioxide (CO₂) data from the QAL 2 tests reports were used for reporting for Units 1, 5 and 6 due to poor performance of the O₂ and CO₂ gaseous monitors. These poor performances of the gaseous monitors were identified to be caused by the incorrect installation of O₂ analyser. An action is being implemented to relocate all the units' O₂ monitors to their own measurement port. This action will be completed no later than 31 December 2022.

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report which will be sent to your office.

9 and 10 Complaints and S30 Incidents Register

Refer to addendum A


Type text here


Boiler Plant Engineering
Manager

14 Dec 2022
Date


Environmental
Manager pp

15/12/2022
Date


Engineering Manager

2022/12/14
Date

Compiled by:

Environmental Officer

For:

Nkangala District
Municipality

Air Quality Officer

Copies:

Generation Environmental
Management

D Herbst
B
Mccourt

Generation Compliance Management
Generation Asset
Management

R
Rampiar
E Patel

Duvha Power Station:

Engineering
Manager
Operating
Manager
Maintenance
Manager
Production
Manager
Boiler Engineering Manager
System Engineer
Environmental Manager

