

Lukhanyo Mgadle Chief Air Quality Officer Buffalo City Metropolitan Municipality 2 Beaconsfield Road North End East London 5201

Date: 2 November 2022

Enquiries: Hilton Westman (021) 9415856

Ref: PRX/2022/10

Dear Mr Mgadle

# ESKOM PORT REX POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF OCTOBER 2022

#### Atmospheric Emissions License: ECBC\_000603

This serves as the monthly report and the information is applicable for the month of October 2022.

### 1. Raw Materials and Products (Licence 6.1)

Quantity of Raw Materials and Products used/produced for the month

Element	Performance	Reporting Unit
Fuel type: Diesel		
Total Fuel Consumption	134.386	Tons
Electricity Produced	437	MWh
Average Fuel Consumption	0.307	Tons / MWh
Maximum fuel consumption rate	13 769	Kg / per hour

## 2. Operating times of units (Licence 5.4)

#### a. Total Hours

	Hours operated	Total Fuel Consumption	Energy Production	
	Hours and minutes	Litres	MWh	
Unit One	2hrs 56min		148	
Unit Two	3hrs 56min	156 755	151	
Unit Three	2hrs 54min		138	

## b. Detailed operating times

See Annexure 1

## 3. Complaints Register (Licence 7.6)

No complaints were registered for the month of October 2022.

## 4. General

Port Rex was requested to generate for the grid to supplement power availability and minimise national load shedding.

We trust that the above information complies with your requirements.

Yours sincerely

1 AAL

Pamela Mrubata Plant Manager **PORT REX POWER STATION** 

	Unit One			Unit two			Unit 3		
Date	Start	Finish	Total Hours	Start	Finish	Total Hours	Start	Finish	Total Hours
1				13:00:00	14:00:00	01:00:00			
2									
3									
4	17:36:00	20:32:00	02:56:00	17:36:00	20:32:00	02:56:00	17:38:00	20:32:00	02:54:00
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19 20									
20									
21									
23									
24									
25									
26									
27									
28									
29									
30									
31									

## Annexure 1. Port Rex Hours of operation

#### Load factor

0.39 %