

Lukhanyo Mgadle
 Chief Air Quality Officer Buffalo City Metropolitan Municipality
 2 Beaconsfield Road North End
 East London
 5201

Date:
 10 January 2023

Enquiries: Hilton Westman
 (021) 9415856

Ref: PRX/2022/12

Dear Mr Mgadle

ESKOM PORT REX POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF DECEMBER 2022

Atmospheric Emissions License: ECBC_000603

This serves as the monthly report and the information is applicable for the month of December 2022.

1. Raw Materials and Products (Licence 6.1)

Quantity of Raw Materials and Products used/produced for the month

Element	Performance	Reporting Unit
Fuel type: Diesel		
Total Fuel Consumption	0.520	Tons
Electricity Produced	0.00	MWh
Average Fuel Consumption	0.00	Tons / MWh
Maximum fuel consumption rate	0.00	Kg / per hour

2. Operating times of units (Licence 5.4)

a. Total Hours

	Hours operated	Total Fuel Consumption	Energy Production
	Hours and minutes	Litres	MWh
Unit One	0.00	606	0.00
Unit Two	0.00		0.00
Unit Three	0.00		0.00

Peaking

Port Rex Power Station
 9 Wells Road Woodbrook East London
 PO Box 1281 East London 5201
 Tel +27 043 703 5771

b. Detailed operating times

Not applicable

3. Complaints Register (Licence 7.6)

No complaints were registered for the month of December 2022.

4. General

Port Rex was not requested to generate for the grid to supplement power availability and minimise national load shedding.

C service 4 monthly's was completed on Unit 2 and tested upon start up.
We trust that the above information complies with your requirements.

Yours sincerely



Pamela Mrubata
Plant Manager

PORT REX POWER STATION